

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2016	2016-02	2016-03	2016-04	2016-05	2016-06	2016-07	2016-08	2016-09	2016-10	2016-11	2016-12	2017	2017-02	2017-03	2017-04	2017-05	2017-06	2017-07	2017-08	2017-09	2017-10	2017-11	2017-12	2018
Basin Creek	MEAN	5.	3.78	2.415	0.882	0.164	0.	0.945	3.258	2.207	1.532	2.18	3.864	2.902	1.513	1.083	0.587	0.047	0.407	2.982	1.39	0.515	1.585	3.254	3.504	
	PS	1.544	0.907	0.502	0.168	0.	0.	0.	1.558	0.417	0.532	1.036	2.199	1.39	0.595	0.253	0.056	0.	0.	2.003	0.718	0.156	0.783	1.923	2.051	
	P95	7.482	6.546	4.287	1.778	0.649	0.	3.016	5.299	4.267	3.226	3.777	6.073	4.364	2.512	1.96	1.368	0.235	1.344	4.148	2.239	1.14	2.311	4.922	4.942	
CCLP	MEAN	12.112	10.428	7.778	10.112	11.411	4.246	7.396	6.798	9.807	11.893	11.225	11.132	11.41	10.624	7.689	10.81	10.84	4.273	7.411	7.168	9.987	11.822	11.28	12.377	11.707
	PS	11.727	9.898	6.974	9.546	11.053	3.844	6.309	6.181	9.514	11.531	10.715	10.759	10.984	10.193	6.666	10.13	10.392	3.844	6.309	6.398	9.514	11.49	10.715	11.936	11.233
	P95	12.512	11.058	8.667	10.728	11.879	5.04	8.387	7.425	10.299	12.324	11.801	11.545	11.883	11.095	8.515	11.425	11.387	4.897	8.544	7.947	10.644	12.262	11.796	12.813	12.142
Colstrip 3	MEAN	31.038	26.857	23.443	19.583	15.696	9.632	27.645	28.155	30.768	31.859	30.551	31.133	31.801	27.888	27.934	25.554	1.162	2.771	29.035	30.244	31.741	32.291	32.436	34.483	33.328
	PS	25.019	21.529	18.596	13.726	11.379	7.869	18.96	21.952	24.125	23.458	25.643	24.792	25.835	23.195	21.766	21.31	0.682	0.952	21.659	24.688	25.139	25.394	26.769	27.637	26.805
	P95	34.589	30.342	27.303	23.581	20.066	11.433	34.863	32.	34.117	35.531	33.8	33.868	35.119	30.759	31.289	29.606	1.941	4.502	34.905	33.242	34.404	35.225	34.921	37.313	36.105
Colstrip 4	MEAN	31.333	27.547	23.411	19.159	2.82	1.056	27.563	27.933	30.484	31.768	30.504	31.317	31.617	28.474	27.8	25.21	18.73	11.937	28.985	30.04	31.486	32.144	32.554	35.278	33.493
	PS	26.14	23.727	17.918	14.133	1.36	0.471	19.25	22.954	24.021	25.266	24.728	25.716	25.727	22.574	21.08	19.716	13.736	7.636	21.269	24.515	23.754	26.255	27.384	29.34	28.085
	P95	34.527	30.23	27.382	22.807	4.377	1.423	34.729	32.107	33.92	35.389	33.836	33.736	34.828	30.833	31.299	29.708	23.903	18.883	34.955	33.23	34.559	35.207	34.921	37.338	35.981
CX FrameCT1	MEAN																									
	PS																									
	P95																									
CX FrameCT1	MEAN																									
	PS																									
	P95																									
CX Recip1	MEAN																									
	PS																									
	P95																									
CX Recip10	MEAN																									
	PS																									
	P95																									
CX Recip2	MEAN																									
	PS																									
	P95																									
CX Recip3	MEAN																									
	PS																									
	P95																									
CX Recip4	MEAN																									
	PS																									
	P95																									
CX Recip5	MEAN																									
	PS																									
	P95																									
CX Recip6	MEAN																									
	PS																									
	P95																									
CX Recip7	MEAN																									
	PS																									
	P95																									
CX Recip8	MEAN																									
	PS																									
	P95																									
CX Recip9	MEAN																									
	PS																									
	P95																									
David Gates Generating Station	MEAN	19.63	15.986	13.994	10.627	10.559	9.12	11.983	15.355	13.413	12.219	13.269	16.04	14.831	11.088	11.11	10.515	9.892	9.12	10.994	14.644	11.679	10.459	11.999	15.681	15.802
	PS	12.483	9.968	9.998	9.37	10.32	9.12	10.32	12.398	10.263	10.54	11.3	13.26	12.34	9.59	9.56	9.6	9.84	9.12	10.32	12.76	10.5	9.84	10.4	12.958	13.128
	P95	25.095	21.78	18.31	12.57	11.52	9.12	15.52	19.548	17.225	14.965	15.85	20.035	17.465	12.84	13.073	11.875	10.165	9.12	12.82	16.685	13.175	11.365	13.65	18.958	18.815
FrameCT_ram p_2018	MEAN																									3.221
	PS																									0.
	P95																									6.655
FrameCT_ram p_2020	MEAN																									
	PS																									
	P95																									
FrameCT_ram p_2022	MEAN																									
	PS																									
	P95																									
Recip_ramp_2 018	MEAN																									1.616
	PS																									1.088
	P95																									2.142
Recip_ramp_2 020	MEAN																									
	PS																									
	P95																									
Recip_ramp_2 022	MEAN																									

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2016	2016-02	2016-03	2016-04	2016-05	2016-06	2016-07	2016-08	2016-09	2016-10	2016-11	2016-12	2017	2017-02	2017-03	2017-04	2017-05	2017-06	2017-07	2017-08	2017-09	2017-10	2017-11	2017-12	2018
Judith Gap	PS	23.148	14.556	12.766	11.411	10.729	7.631	6.197	6.051	7.727	12.642	17.175	17.774	22.57	14.441	12.655	11.82	8.882	7.358	7.046	6.104	7.807	13.651	17.198	20.221	23.439
	P95	33.455	22.441	21.844	20.088	19.312	14.837	14.16	14.502	14.704	22.892	25.713	27.695	33.902	23.206	20.829	20.689	18.435	15.205	14.28	13.135	17.018	22.456	24.983	28.992	33.173
	MEAN	1.451	1.254	0.996	1.12	0.703	0.73	0.528	0.505	0.653	0.877	1.104	1.106	1.471	1.262	0.992	1.168	0.658	0.741	0.537	0.501	0.67	0.872	1.11	1.218	1.465
Musselshell 1	PS	1.061	1.003	0.735	0.894	0.507	0.544	0.359	0.341	0.477	0.612	0.78	0.711	1.027	1.045	0.71	0.954	0.422	0.53	0.364	0.34	0.495	0.651	0.792	0.888	1.093
	P95	1.887	1.504	1.284	1.374	0.988	0.944	0.754	0.734	0.846	1.21	1.411	1.595	1.893	1.587	1.283	1.404	0.944	0.956	0.717	0.688	0.921	1.154	1.382	1.592	1.856
	MEAN	1.605	1.409	1.163	1.344	0.893	0.869	0.637	0.641	0.812	1.018	1.354	1.274	1.631	1.418	1.156	1.402	0.84	0.88	0.647	0.638	0.833	1.011	1.358	1.403	1.625
Musselshell 2	PS	1.182	1.134	0.883	1.076	0.681	0.65	0.447	0.438	0.61	0.703	1.019	0.874	1.138	1.175	0.872	1.162	0.554	0.638	0.447	0.452	0.625	0.754	1.004	1.025	1.237
	P95	2.087	1.704	1.494	1.632	1.2	1.139	0.892	0.908	1.056	1.376	1.689	1.707	2.066	1.761	1.465	1.655	1.148	1.12	0.868	0.87	1.166	1.327	1.667	1.745	2.03
	MEAN	0.048	0.053	0.078	0.112	0.177	0.156	0.22	0.127	0.127	0.08	0.039	0.027	0.042	0.053	0.078	0.132	0.152	0.154	0.222	0.126	0.128	0.08	0.04	0.04	0.04
Ragen Ranch Solar	PS	0.012	0.007	0.029	0.043	0.073	0.035	0.108	0.048	0.016	0.015	0.012	0.013	0.006	0.013	0.026	0.053	0.061	0.025	0.103	0.043	0.02	0.011	0.012	0.022	0.008
	P95	0.109	0.116	0.129	0.201	0.288	0.285	0.303	0.182	0.229	0.15	0.084	0.048	0.098	0.115	0.137	0.221	0.256	0.286	0.309	0.181	0.232	0.147	0.086	0.068	0.091
	MEAN	0.025	0.03	0.051	0.056	0.114	0.094	0.136	0.07	0.074	0.044	0.026	0.016	0.022	0.028	0.051	0.07	0.097	0.094	0.136	0.068	0.076	0.045	0.028	0.024	0.021
River Bend Solar	PS	0.001	0.	0.	0.001	0.041	0.029	0.082	0.03	0.001	0.	0.001	0.003	0.	0.	0.	0.001	0.036	0.027	0.079	0.026	0.003	0.	0.001	0.007	0.
	P95	0.067	0.068	0.099	0.097	0.172	0.154	0.185	0.103	0.137	0.097	0.071	0.041	0.058	0.067	0.101	0.121	0.148	0.153	0.188	0.103	0.149	0.096	0.071	0.054	0.054
	MEAN	0.044	0.05	0.081	0.108	0.191	0.169	0.237	0.129	0.129	0.076	0.046	0.027	0.039	0.049	0.082	0.128	0.165	0.171	0.24	0.128	0.132	0.078	0.047	0.039	0.038
South Mills Solar	PS	0.006	0.004	0.018	0.031	0.069	0.046	0.123	0.057	0.013	0.008	0.016	0.013	0.001	0.007	0.02	0.034	0.064	0.049	0.127	0.053	0.027	0.008	0.014	0.021	0.004
	P95	0.114	0.115	0.143	0.189	0.293	0.279	0.324	0.177	0.226	0.152	0.094	0.046	0.093	0.118	0.147	0.22	0.254	0.274	0.327	0.177	0.228	0.151	0.099	0.066	0.099
	MEAN	8.155	5.934	5.567	4.446	3.059	2.817	3.158	2.319	3.899	4.928	6.385	7.091	7.726	5.967	5.56	4.653	2.874	2.856	3.192	2.304	3.981	4.885	6.379	7.747	7.775
Spion Kop	PS	6.518	4.289	4.218	3.114	2.025	1.828	1.974	1.525	2.781	3.61	4.79	5.523	5.797	4.695	4.237	3.31	1.761	1.83	2.181	1.514	2.882	3.469	4.985	6.242	6.283
	P95	9.936	7.673	6.926	5.799	4.623	3.983	4.578	3.386	5.231	6.605	7.829	8.826	9.256	7.54	6.992	6.053	4.304	3.996	4.341	3.315	5.768	6.454	7.719	9.013	9.181
	MEAN	2.092	1.325	1.402	1.418	0.546	0.94	0.693	0.592	0.779	1.499	1.699	1.488	2.13	1.327	1.392	1.478	0.508	0.953	0.704	0.589	0.802	1.494	1.701	1.642	2.126
Two Dot Wind	PS	1.722	1.029	1.102	1.14	0.361	0.719	0.482	0.401	0.567	1.214	1.397	1.109	1.722	1.061	1.04	1.236	0.283	0.71	0.491	0.398	0.589	1.254	1.41	1.245	1.764
	P95	2.468	1.666	1.716	1.686	0.836	1.168	0.957	0.852	1.048	1.847	2.014	1.924	2.5	1.683	1.709	1.719	0.787	1.19	0.922	0.815	1.108	1.773	1.983	1.964	2.469
	MEAN	50.623	34.241	33.391	30.753	25.5	22.11	20.154	17.986	22.41	33.032	40.49	40.69	51.018	34.37	33.252	32.309	23.832	22.367	20.472	17.951	23.001	32.909	40.491	45.065	63.204
Wind/Solar Asset - Total	PS	41.823	26.933	26.753	24.149	19.846	16.719	14.275	12.615	16.628	24.851	32.981	32.388	40.996	27.6	26.415	25.348	17.156	16.263	15.703	13.009	17.182	26.211	33.006	37.252	53.742
	P95	59.803	42.427	41.341	37.443	33.496	28.422	27.685	25.36	28.596	42.027	47.95	50.57	59.609	42.544	40.241	38.889	31.997	28.572	27.249	23.596	32.612	40.668	47.161	52.059	71.866
	MEAN	29.16	13.311	15.852	25.996	7.059	-20.418	-0.956	7.372	18.224	22.832	17.127	12.66	33.567	3.308	20.613	34.763	10.352	-15.556	-1.019	-11.267	19.185	21.021	19.644	6.936	60.157
Total	PS	(8.2)	-13.245	-9.057	3.064	-26.264	-48.041	-31.857	-21.809	-5.011	-1.468	-10.008	-19.25	0.291	-18.952	-2.613	4.27	-21.052	-45.022	-37.866	-11.096	-4.76	-1.702	-1.624	-23.912	30.119
	P95	65.452	46.884	48.257	57.239	44.405	16.263	33.644	40.695	49.286	52.924	42.637	42.618	72.612	27.914	51.417	73.189	51.531	22.278	41.089	35.945	41.901	50.326	45.559	36.624	95.709
	MEAN																									

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2018-02	2018-03	2018-04	2018-05	2018-06	2018-07	2018-08	2018-09	2018-10	2018-11	2018-12	2019	2019-02	2019-03	2019-04	2019-05	2019-06	2019-07	2019-08	2019-09	2019-10	2019-11	2019-12	2020	2020-02
Basin Creek	MEAN	1.959	1.308	0.498	0.054	0.138	0.138	1.384	0.447	0.885	2.289	3.842	3.625	1.947	1.681	0.398	0.041	0.231	1.978	0.774	1.059	2.681	4.399	4.953	3.2	
	PS	1.092	0.517	0.045	0.	0.	0.469	0.056	0.342	1.163	2.401	2.33	0.758	0.694	0.022	0.	0.	0.	1.081	0.149	0.353	1.354	2.747	2.678	1.002	
	P95	2.964	2.205	1.253	0.316	0.589	2.281	1.006	1.633	3.541	5.39	4.824	3.012	2.818	1.116	0.182	0.737	2.914	1.789	2.148	4.248	6.089	7.254	5.315		
CELLP	MEAN	10.757	8.085	10.919	10.881	4.386	7.112	6.602	10.356	11.268	11.338	12.515	11.752	10.824	8.846	10.272	10.808	4.97	6.707	6.938	10.459	11.316	11.434	12.54	11.954	10.892
	PS	10.372	7.162	10.289	10.433	3.844	6.309	5.805	10.134	10.871	10.695	11.998	11.243	10.393	7.731	9.593	10.454	4.381	5.648	6.062	10.134	10.912	10.777	12.08	11.542	10.315
	P95	11.198	8.78	11.564	11.528	4.938	8.073	7.378	10.811	11.783	11.939	13.082	12.203	11.274	9.748	10.991	11.261	5.654	7.759	7.838	11.084	11.796	12.048	13.175	12.314	11.406
Colstrip 3	MEAN	29.906	30.27	27.389	21.779	16.015	28.245	29.361	33.414	31.481	32.601	35.227	33.226	29.759	31.579	25.873	21.123	15.201	25.877	29.923	32.663	31.565	32.4	35.576	33.98	30.738
	PS	23.974	23.948	20.488	16.213	9.766	20.612	23.762	26.769	23.826	27.475	28.149	27.028	24.344	24.776	20.805	14.642	10.053	19.304	24.112	25.031	23.536	26.811	28.053	27.818	25.802
	P95	31.454	33.217	31.826	26.978	24.335	34.772	32.692	35.969	33.949	34.928	37.821	36.1	31.667	34.903	29.719	26.31	24.296	33.135	32.691	35.876	33.935	35.056	37.738	36.296	32.683
Colstrip 4	MEAN	29.871	29.817	27.392	21.635	15.814	28.339	29.399	32.762	31.694	32.673	35.674	33.571	30.073	31.107	25.148	5.68	4.412	25.984	29.618	32.999	31.792	32.848	35.753	33.968	30.828
	PS	24.996	22.876	20.89	15.317	9.151	19.797	23.912	27.002	25.813	30.777	29.061	24.566	23.8	17.756	3.515	2.221	18.713	24.45	26.81	26.226	25.589	30.431	27.983	23.86	
	P95	31.565	33.024	31.771	26.816	23.669	34.718	32.887	35.859	34.07	34.883	37.792	36.056	31.721	34.763	29.481	7.813	7.855	33.182	32.626	35.87	33.935	35.044	37.747	36.341	32.685
CX FrameCT1	MEAN																									
	PS																									
	P95																									
CX FrameCT1	MEAN																									
	PS																									
	P95																									
CX Recip1	MEAN																									
	PS																									
	P95																									
CX Recip10	MEAN																									
	PS																									
	P95																									
CX Recip2	MEAN																									
	PS																									
	P95																									
CX Recip3	MEAN																									
	PS																									
	P95																									
CX Recip4	MEAN																									
	PS																									
	P95																									
CX Recip5	MEAN																									
	PS																									
	P95																									
CX Recip6	MEAN																									
	PS																									
	P95																									
CX Recip7	MEAN																									
	PS																									
	P95																									
CX Recip8	MEAN																									
	PS																									
	P95																									
CX Recip9	MEAN																									
	PS																									
	P95																									
David Gates Generating Station	MEAN	11.818	11.453	10.328	9.914	9.12	10.54	11.627	10.628	10.491	13.166	16.592	15.904	11.653	12.448	9.689	9.88	9.6	10.199	12.579	11.061	10.719	13.79	17.596	18.339	14.167
	PS	10.19	9.96	9.6	9.84	9.12	10.32	10.06	10.08	9.61	11.15	13.708	13.278	9.49	10.765	9.12	9.84	9.6	9.84	11.048	10.18	9.66	11.575	14.77	14.465	10.63
	P95	13.865	13.21	11.875	10.378	9.12	11.395	13.31	11.705	11.81	15.863	19.42	18.415	13.628	14.39	10.82	10.04	9.6	11.165	14.323	12.855	12.26	16.85	20.295	22.053	17.48
FrameCT_ram p_2018	MEAN	0.779	0.14	0.04	0.011	0.289	2.856	0.411	0.162	0.754	2.424	0.453	0.225	0.026	0.004	0.376	2.717	0.217	0.016	0.798	1.762	4.308	1.379			
	PS	0.	0.	0.	0.	0.	0.242	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.831	0.	0.	0.	0.	0.	0.			
	P95	3.105	0.868	0.314	0.038	1.302	5.471	2.179	1.008	3.32	5.8	2.072	1.735	0.161	0.	1.266	5.038	1.205	0.	3.451	5.398	9.034	4.114			
FrameCT_ram p_2020	MEAN																									
	PS																									
	P95																									
FrameCT_ram p_2022	MEAN																									
	PS																									
	P95																									
Recip_ramp_2018	MEAN	1.006	0.688	0.179	0.012	0.072	0.77	0.632	0.411	0.738	1.207	1.53	0.913	0.78	0.153	0.008	0.061	0.657	0.298	0.571	1.228	1.865	2.04	1.399		
	PS	0.629	0.315	0.	0.	0.	0.374	0.247	0.153	0.357	0.663	1.046	0.417	0.383	0.	0.	0.	0.34	0.051	0.23	0.672	1.224	1.139	0.57		
	P95	1.377	1.046	0.451	0.085	0.281	1.097	1.139	0.748	1.241	1.743	2.023	1.343	1.275												

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2018-02	2018-03	2018-04	2018-05	2018-06	2018-07	2018-08	2018-09	2018-10	2018-11	2018-12	2019	2019-02	2019-03	2019-04	2019-05	2019-06	2019-07	2019-08	2019-09	2019-10	2019-11	2019-12	2020	2020-02
Hauser	P95	14.587	18.857	19.592	23.754	24.146	21.85	16.216	14.392	11.476	14.288	15.551	16.304	14.221	16.86	18.911	23.767	22.906	22.426	16.95	15.083	13.866	15.155	18.097	17.084	14.011
	MEAN	4.261	4.615	4.801	4.738	4.596	5.299	4.932	4.589	4.647	4.678	5.037	4.73	4.268	4.859	4.553	4.738	4.839	5.075	4.932	5.087	4.651	4.67	5.036	4.733	4.217
	PS	4.013	4.398	4.493	4.505	4.383	5.049	4.744	4.814	4.437	4.399	4.807	4.449	4.042	4.61	4.335	4.505	4.592	4.849	4.702	4.853	4.427	4.438	4.799	4.483	3.963
Holter	P95	4.513	4.879	4.905	4.89	4.812	5.525	5.11	5.32	4.816	4.899	5.277	4.79	4.482	5.101	4.783	4.974	5.042	5.255	5.177	5.204	4.895	4.954	5.277	5.014	4.415
	MEAN	2.564	2.939	11.244	12.05	11.443	11.774	9.267	9.629	8.891	9.805	11.091	10.459	9.273	10.465	10.661	12.034	12.057	11.276	9.265	9.625	9.778	11.086	9.78	11.086	10.45
	PS	7.721	8.388	9.119	10.065	9.389	9.716	7.819	8.064	7.5	8.139	9.367	8.634	7.696	8.715	8.9	9.823	9.969	9.158	7.609	8.079	7.358	8.195	9.203	8.814	7.64
Madison	P95	11.004	12.173	13.09	14.36	13.528	13.845	10.989	11.1	10.527	11.766	12.6	12.263	10.919	12.216	12.512	14.658	13.93	13.386	11.11	11.219	10.97	12.121	13.337	12.404	10.503
	MEAN	2.208	2.404	2.324	2.44	2.272	2.613	2.308	2.364	2.295	2.382	2.547	2.443	2.212	2.533	2.204	2.44	2.393	2.51	2.307	2.361	2.298	2.379	2.547	2.443	2.186
	PS	2.071	2.26	2.145	2.301	2.129	2.436	2.171	2.201	2.153	2.209	2.401	2.281	2.085	2.379	2.06	2.281	2.239	2.38	2.16	2.238	2.085	2.151	2.227	2.387	2.202
Morony	P95	2.349	2.585	2.448	2.599	2.424	2.788	2.438	2.495	2.429	2.519	2.688	2.598	2.337	2.686	2.333	2.587	2.533	2.671	2.475	2.506	2.468	2.572	2.734	2.591	2.295
	MEAN	8.438	8.944	10.377	11.622	11.622	11.371	8.901	9.125	8.569	9.843	9.884	9.65	8.474	8.901	9.819	12.129	12.247	11.009	8.9	9.102	8.59	8.901	9.621	8.813	
	PS	6.601	7.264	7.962	9.596	9.139	9.085	7.365	7.144	6.951	6.991	7.939	7.329	6.626	7.484	7.897	9.264	9.639	8.867	7.042	7.469	6.755	7.119	7.722	7.724	6.526
Mystic	P95	10.34	11.264	12.288	15.342	14.102	13.681	10.739	10.773	10.332	11.14	11.869	12.008	10.597	11.378	11.835	15.169	14.582	13.39	11.029	10.792	11.92	11.59	12.88	11.842	9.726
	MEAN	1.118	0.912	0.586	1.186	2.252	3.768	2.99	2.159	1.515	1.506	1.585	1.386	1.131	0.98	0.553	1.185	2.391	3.618	2.987	2.143	1.517	1.501	1.604	1.406	
	PS	0.784	0.734	0.502	1.023	1.919	3.481	2.326	1.749	1.123	1.136	1.122	0.979	0.819	0.769	0.479	1.022	2.041	3.34	2.386	1.807	1.141	1.164	1.604	1.09	
Rainbow	P95	1.514	1.142	0.661	1.398	2.641	4.065	3.532	2.554	1.905	1.956	2.133	1.889	1.513	1.203	0.623	1.395	2.772	3.83	3.64	2.531	1.972	1.981	2.364	1.996	
	MEAN	11.307	12.813	14.764	17.144	16.528	15.222	12.203	11.694	11.06	11.568	13.038	12.413	11.319	13.502	13.979	17.018	17.465	14.523	12.193	11.725	11.087	11.521	13.05	12.384	
	PS	4.544	5.678	6.137	7.537	7.332	6.732	5.642	5.782	5.565	5.309	5.533	5.826	5.732	6.18	5.989	6.814	7.028	6.708	5.433	4.812	5.886	5.945	5.284	5.005	
Ryan	P95	21.387	26.726	25.417	29.682	30.9	26.29	21.872	19.364	19.21	22.92	20.823	22.898	20.333	23.293	25.799	32.043	28.023	26.448	23.81	20.616	20.993	23.212	24.707	23.523	
	MEAN	13.698	15.369	16.904	18.739	17.509	17.287	14.656	15.167	14.485	15.052	15.333	13.743	16.172	16.024	18.759	18.477	16.652	14.66	15.14	14.513	15.034	15.995	15.324	13.532	
	PS	12.157	13.219	14.25	17.138	15.843	15.495	13.194	13.269	12.999	13.145	14.369	12.862	12.351	13.898	13.639	17.065	16.688	14.99	12.998	13.67	12.955	13.335	14.252	13.098	
Sleeping Giant	P95	15.22	17.809	18.943	20.311	19.194	16.008	16.687	15.877	16.583	17.73	17.788	15.251	18.207	18.263	20.315	19.874	17.943	16.406	16.771	18.082	17.767	14.771	11.935	11.935	
	MEAN	0.409	1.048	2.556	2.62	2.427	2.751	2.491	2.674	0.6	0.643	0.323	0.28	0.409	1.101	2.43	2.62	2.555	2.619	2.494	2.673	0.6	0.642	0.323	0.28	
	PS	0.405	1.033	2.526	2.59	2.399	2.721	2.457	2.62	0.593	0.631	0.319	0.267	0.405	1.085	2.4	2.592	2.585	2.468	2.634	0.593	0.632	0.319	0.266		
Thompson Falls	P95	0.414	1.063	2.582	2.65	2.459	2.782	2.522	2.709	0.607	0.654	0.327	0.293	0.416	1.119	2.458	2.656	2.586	2.654	2.524	2.704	0.607	0.653	0.328	0.296	
	MEAN	15.718	16.753	23.514	26.988	24.584	25.727	14.172	13.008	13.741	16.246	19.419	17.403	15.751	17.629	22.286	26.938	24.657	14.156	13.009	13.761	16.206	19.395	17.396		
	PS	12.293	13.177	17.525	20.951	18.827	19.515	11.113	10.12	10.762	12.565	15.21	13.308	12.271	13.606	17.286	20.114	19.904	16.733	10.677	12.858	14.114	13.713	12.156		
Hydro - Total	P95	19.444	21.759	28.693	33.952	30.263	31.737	17.393	15.535	17.115	20.354	23.268	21.473	19.327	21.69	27.363	33.676	31.296	30.94	19.779	16.093	18.116	21.369	24.875	21.802	
	MEAN	79.128	87.627	104.544	118.174	112.612	113.235	85.947	84.361	76.632	83.492	97.766	93.329	87.766	79.309	92.316	99.404	117.831	118.8	108.604	85.907	84.308	83.254	93.305	94.305	
	PS	58.668	65.889	74.081	88.118	82.428	82.165	65.567	64.564	58.991	62.815	70.365	63.667	60.571	68.113	74.264	86.605	88.607	82.99	62.764	63.458	57.421	63.172	67.56	65.526	
Load	P95	103.534	124.661	137.477	154.306	148.847	147.932	113.416	106.423	98.497	112.101	116.38	116.265	103.607	120.129	131.221	156.027	151.308	143.79	113.93	108.624	106.221	115.818	127.697	119.346	
	MEAN	-207.603	-196.913	-196.339	-191.225	-186.704	-231.743	-195.213	-201.732	-185.041	-215.893	-255.844	-216.085	-207.584	-208.635	-185.197	-191.766	-198.616	-216.132	-195.833	-202.106	-185.147	-215.485	-256.163	-215.727	
	PS	-213.082	-202.806	-202.801	-195.308	-189.504	-238.314	-199.428	-205.703	-190.328	-221.498	-263.605	-232.425	-214.485	-215.395	-190.012	-196.852	-201.974	-223.206	-200.342	-205.653	-190.609	-220.135	-264.786	-229.455	
Small QF1	P95	-202.062	-189.009	-190.692	-187.139	-183.96	-224.453	-190.347	-198.142	-180.219	-210.816	-248.031	-201.345	-200.82	-201.986	-181.286	-187.422	-195.902	-207.817	-191.847	-198.411	-186.101	-209.78	-246.685	-203.139	
	MEAN	0.352	0.7	0.688	0.657	1.255	4.318	0.95	1.811	0.94	0.758	0.713	0.552	0.352	0.736	0.653	0.657	1.32	4.085	0.919	1.777	0.909	0.726	0.68	0.52	
	PS	0.352	0.7	0.688	0.657	1.255	4.318	0.95	1.811	0.94	0.758	0.713	0.552	0.352	0.736	0.653	0.657	1.32	4.085	0.919	1.777	0.909	0.726	0.68	0.52	
Small Tier II	P95	1.356	2.16	2.481	2.196	2.872	3.109	2.334	2.842	2.901	2.508	2.169	1.785	1.356	2.271	2.357	2.196	3.023	2.965	2.334	2.842	2.887	2.494	2.149	1.765	
	MEAN	1.576	1.742	1.828	0.005	1.654	1.767	1.79	1.576	1.831	1.737	1.576	1.831	1.737	1.576	1.831	1.737	1.576	1.831	1.737	0.005	1.654	1.767	1.79		
	PS	1.576	1.742	1.828	0.005	1.654	1.767	1.79	1.576	1.831	1.737	1.576	1.831	1.737	1.576	1.831	1.737	1.576	1.831	1.737	0.005	1.654	1.767	1.79		
Turnbull	P95	1.576	1.742	1.828	0.005	1.654	1.767	1.79	1.576	1.831	1.737	1.576	1.831	1.737	1.576	1.831	1.737	1.576	1.831	1.737	0.005	1.654	1.767	1.79		
	MEAN	0.005	1.618	3.401	4.411	2.985	1.161	0.013	0.005	1.618	3.401	4.411	2.985	1.161	0											

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2018-02	2018-03	2018-04	2018-05	2018-06	2018-07	2018-08	2018-09	2018-10	2018-11	2018-12	2019	2019-02	2019-03	2019-04	2019-05	2019-06	2019-07	2019-08	2019-09	2019-10	2019-11	2019-12	2020	2020-02
Judith Gap	PS	14.415	13.228	11.758	9.21	6.81	5.803	6.037	7.055	12.169	17.29	19.378	23.179	14.131	12.5	10.993	9.459	7.491	5.792	6.145	8.039	12.582	17.039	19.876	23.535	13.031
	P95	23.078	22.029	19.76	17.602	16.24	13.652	13.257	16.701	21.556	24.927	30.129	33.869	22.526	23.145	19.703	18.053	15.709	13.095	13.165	16.385	20.419	26.808	29.281	34.155	22.299
	MEAN	1.255	0.995	1.179	0.649	0.733	0.525	0.514	0.699	0.826	1.118	1.224	1.435	1.259	1.045	1.103	0.658	0.769	0.5	0.503	0.693	0.845	1.119	1.224	1.48	1.252
Musselshell 1	PS	0.986	0.706	0.931	0.428	0.493	0.33	0.33	0.472	0.561	0.84	0.817	1.085	1.017	0.715	0.871	0.431	0.551	0.334	0.327	0.508	0.591	0.771	0.818	1.128	0.928
	P95	1.548	1.294	1.381	0.882	0.999	0.735	0.712	0.933	1.14	1.437	1.595	1.884	1.55	1.377	1.345	0.946	1.028	0.701	0.665	0.978	1.067	1.528	1.591	1.887	1.485
	MEAN	1.411	1.16	1.413	0.828	0.874	0.633	0.651	0.867	0.958	1.369	1.406	1.588	1.417	1.219	1.324	0.84	0.914	0.602	0.639	0.861	0.978	1.369	1.409	1.638	1.407
Musselshell 2	PS	1.117	0.844	1.135	0.574	0.584	0.409	0.433	0.61	0.648	1.034	0.985	1.197	1.142	0.837	1.063	0.586	0.639	0.41	0.433	0.655	0.676	0.982	0.979	1.244	1.066
	P95	1.719	1.493	1.639	1.077	1.168	0.872	0.881	1.131	1.32	1.702	1.786	2.065	1.726	1.586	1.577	1.167	1.213	0.822	0.848	1.176	1.231	1.788	1.793	2.084	1.672
	MEAN	0.053	0.076	0.134	0.151	0.152	0.221	0.125	0.147	0.062	0.04	0.041	0.04	0.053	0.095	0.109	0.15	0.174	0.19	0.122	0.144	0.065	0.038	0.04	0.043	0.051
Ragen Ranch Solar	PS	0.008	0.019	0.047	0.061	0.021	0.094	0.042	0.015	0.01	0.012	0.021	0.006	0.011	0.028	0.038	0.049	0.023	0.084	0.035	0.012	0.012	0.01	0.02	0.007	0.008
	P95	0.117	0.132	0.234	0.254	0.282	0.308	0.18	0.265	0.118	0.099	0.066	0.086	0.108	0.164	0.197	0.254	0.318	0.269	0.181	0.264	0.12	0.09	0.074	0.11	0.115
	MEAN	0.029	0.049	0.07	0.096	0.093	0.136	0.068	0.084	0.034	0.027	0.024	0.021	0.029	0.061	0.054	0.094	0.108	0.116	0.068	0.084	0.036	0.026	0.024	0.022	0.027
River Bend Solar	PS	0.	0.	0.002	0.032	0.027	0.078	0.028	0.001	0.	0.005	0.	0.	0.	0.	0.003	0.027	0.03	0.065	0.026	0.001	0.	0.	0.005	0.	0.
	P95	0.069	0.099	0.12	0.147	0.148	0.187	0.102	0.15	0.078	0.07	0.06	0.058	0.069	0.121	0.097	0.147	0.175	0.161	0.102	0.155	0.075	0.069	0.058	0.059	0.067
	MEAN	0.049	0.078	0.128	0.164	0.165	0.239	0.125	0.149	0.059	0.046	0.04	0.037	0.048	0.098	0.104	0.164	0.191	0.208	0.125	0.147	0.063	0.045	0.04	0.039	0.047
South Mills Solar	PS	0.004	0.014	0.029	0.057	0.034	0.123	0.044	0.01	0.003	0.012	0.02	0.004	0.006	0.018	0.026	0.051	0.049	0.111	0.044	0.011	0.005	0.013	0.019	0.003	0.005
	P95	0.118	0.143	0.22	0.257	0.272	0.323	0.176	0.263	0.122	0.102	0.067	0.094	0.115	0.171	0.19	0.256	0.305	0.284	0.176	0.263	0.12	0.095	0.072	0.104	0.108
	MEAN	5.929	5.567	4.67	2.822	2.825	3.138	2.956	4.127	4.603	6.426	7.77	7.667	5.976	5.853	4.363	2.853	2.985	3.003	2.314	4.102	4.669	6.453	7.807	7.812	5.94
Spion Kop	PS	4.112	4.094	3.273	1.761	1.647	1.832	1.54	2.65	3.258	4.838	6.107	6.25	4.287	4.346	2.939	1.736	1.707	1.818	1.466	2.993	3.191	4.696	6.012	6.106	4.39
	P95	7.424	7.132	6.053	4.007	4.19	4.443	3.273	5.665	6.469	7.873	8.994	9.27	7.595	7.557	5.961	4.099	4.1	4.263	3.246	5.605	5.811	8.004	9.489	9.131	7.423
	MEAN	1.325	1.4	1.489	0.5	0.944	0.689	0.602	0.833	1.414	1.709	1.64	2.087	1.33	1.467	1.396	0.506	0.995	0.657	0.591	0.827	1.434	1.708	1.64	2.131	1.32
Two Dot Wind	PS	1.024	1.097	1.196	0.297	0.663	0.449	0.394	0.58	1.131	1.4	1.21	1.745	1.003	1.103	1.154	0.292	0.74	0.455	0.379	1.745	1.176	1.334	1.221	1.772	0.961
	P95	1.616	1.772	1.725	0.732	1.231	0.964	0.841	1.091	1.722	2.001	2.041	2.469	1.649	1.822	1.662	0.796	1.25	0.884	0.768	1.139	1.636	2.107	1.995	2.526	1.599
	MEAN	43.067	41.459	40.419	29.219	27.587	24.849	22.351	30.014	39.794	52.64	58.63	62.933	43.3	43.664	37.681	29.579	29.306	23.501	21.994	29.764	40.255	52.727	58.702	77.35	51.755
Wind/Solar Asset - Total	PS	34.38	32.751	31.441	21.966	18.424	16.004	15.133	20.548	31.033	43.341	47.979	52.931	34.286	32.408	28.622	22.464	20.971	16.653	15.255	22.205	32.011	43.766	47.355	65.643	40.269
	P95	52.073	51.621	47.223	37.126	37.431	32.584	29.01	39.026	50.25	60.355	67.911	74.79	52.378	53.598	47.191	38.304	37.598	31.567	28.552	39.146	47.348	62.965	69.029	88.028	61.47
	MEAN	20.952	37.661	49.196	43.148	9.756	6.616	15.163	25.827	37.592	38.2	28.74	58.627	21.722	39.196	45.644	25.75	-4.699	9.614	16.912	25.104	39.258	40.784	33.131	90.774	47.625
Total	PS	-4.807	7.584	15.038	6.488	-25.925	-31.36	-10.184	-0.238	14.727	14.442	5.402	24.61	-3.017	12.462	17.399	-11.137	-40.893	-25.265	-8.488	-1.857	13.348	11.633	4.011	46.113	19.446
	P95	47.798	75.138	85.245	81.812	51.792	43.118	38.015	49.951	64.083	70.228	54.261	105.445	49.924	70.85	82.994	67.606	33.851	43.264	50.123	51.909	64.08	77.729	66.97	136.673	75.94
	MEAN																									

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2020-03	2020-04	2020-05	2020-06	2020-07	2020-08	2020-09	2020-10	2020-11	2020-12	2021	2021-02	2021-03	2021-04	2021-05	2021-06	2021-07	2021-08	2021-09	2021-10	2021-11	2021-12	2022	2022-02	2022-03
Hauser	P95	19.506	19.39	24.799	26.522	20.2	15.899	17.294	12.55	15.259	16.184	15.985	13.554	17.688	18.664	24.666	21.673	21.088	16.103	13.813	11.996	13.361	14.209	17.704	14.712	19.148
	MEAN	4.856	4.565	4.975	4.595	4.826	5.175	4.847	4.645	4.896	4.807	4.948	4.263	4.616	4.563	4.978	4.603	4.826	5.184	4.948	4.844	4.666	4.474	4.737	4.425	4.617
	PS	4.598	4.357	4.735	4.407	4.642	4.921	4.563	4.434	4.663	4.576	4.648	4.027	4.407	4.303	4.755	4.42	4.619	4.96	4.621	4.687	4.466	4.348	4.502	4.005	4.379
Holter	P95	5.12	4.795	5.295	4.785	4.988	5.398	4.882	5.086	5.042	5.222	4.447	4.849	4.805	5.246	4.974	5.009	5.39	5.385	5.117	4.852	4.799	4.975	5.147	4.975	4.867
	MEAN	10.458	10.717	12.626	11.464	10.696	9.734	9.158	10.265	10.587	10.901	10.458	9.257	9.937	10.698	13.627	11.485	10.722	9.75	9.137	9.366	9.382	10.068	10.443	9.234	9.947
	PS	8.572	9.207	10.667	9.768	9.213	8.235	7.51	7.433	8.472	8.648	8.711	7.972	8.573	8.784	10.659	9.765	8.771	8.011	7.608	8.125	8.349	8.132	8.822	7.588	8.248
Madison	P95	12.884	12.722	15.156	13.935	12.486	11.412	11.422	10.833	12.534	12.436	12.758	10.636	11.941	12.668	14.883	13.299	12.846	11.401	10.609	10.92	11.393	11.618	12.444	11.096	12.278
	MEAN	2.531	2.211	2.561	2.275	2.382	2.422	2.252	2.295	2.496	2.433	2.551	2.209	2.406	2.207	2.563	2.278	2.385	2.427	2.249	2.415	2.377	2.314	2.443	2.203	2.406
	PS	2.366	2.092	2.41	2.154	2.244	2.282	2.074	2.086	2.144	2.344	2.383	2.086	2.247	2.046	2.423	2.162	2.278	2.116	2.288	2.251	2.128	2.263	2.071	2.252	
Morony	P95	2.709	2.334	2.729	2.415	2.51	2.564	2.424	2.439	2.653	2.585	2.71	2.307	2.547	2.36	2.742	2.389	2.555	2.573	2.386	2.575	2.504	2.46	2.647	2.351	2.574
	MEAN	9.443	9.915	12.754	11.649	10.428	9.331	8.684	8.573	9.311	8.684	8.573	9.311	8.684	8.438	9.952	10.006	11.703	10.456	9.311	8.684	9.04	8.913	8.996	9.64	8.384
	PS	7.409	8.238	10.123	9.751	8.601	7.385	6.674	6.799	7.376	7.192	7.69	7.01	7.321	7.648	10.263	9.815	8.419	7.186	6.804	7.605	7.359	6.774	7.711	6.709	
Mystic	P95	11.864	11.839	15.935	14.203	12.27	11.418	11.013	10.627	11.802	11.927	12.2	9.934	10.872	12.108	15.718	13.679	12.761	11.416	10.392	11.056	10.587	11.105	11.645	10.218	11.232
	MEAN	0.976	0.559	1.252	2.258	3.438	3.158	2.039	1.517	1.585	1.498	1.461	1.133	0.911	0.554	1.249	2.273	3.444	3.178	2.05	1.617	1.503	1.401	1.395	1.118	
	PS	0.767	0.502	1.095	1.924	3.212	2.432	1.617	1.139	1.244	0.979	0.973	0.867	0.74	0.467	1.088	2.004	3.267	2.472	1.682	1.304	1.199	0.899	1.024	0.833	
Rainbow	P95	1.254	0.626	1.434	2.563	3.622	3.788	2.548	1.976	2.018	2.029	1.894	1.408	1.1	0.645	1.454	2.609	3.686	3.853	2.428	2.037	1.943	1.867	1.882	1.494	
	MEAN	13.426	14.092	17.938	16.552	13.804	12.832	11.105	11.068	12.073	12.501	12.873	11.288	12.83	14.056	17.881	16.639	13.841	12.868	11.035	11.661	11.5	11.842	12.36	11.256	
	PS	6.079	6.968	8.923	8.369	7.431	6.536	4.469	5.406	6.467	6.986	6.122	6.52	6.061	4.779	5.986	6.035	6.171	5.986	6.299	5.647	5.809	5.323	4.246		
Ryan	P95	27.106	26.224	30.465	32.492	24.105	21.056	22.576	19.866	22.813	23.256	23.425	18.947	23.432	24.972	30.859	27.373	24.606	21.557	18.736	20.4	20.259	19.218	25.13	20.654	
	MEAN	16.168	16.103	19.708	17.533	15.815	15.362	14.458	14.474	15.749	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	15.311	
	PS	13.668	14.282	17.997	16.221	14.37	13.791	12.517	12.932	14.109	13.529	13.208	12.326	13.449	13.516	18.08	16.313	14.419	13.733	12.915	13.86	13.646	12.938	13.281	12.184	
Sleeping Giant	P95	18.668	17.975	21.404	18.924	17.073	16.907	16.459	15.938	17.443	17.009	18.333	14.755	17.837	21.486	18.885	17.45	16.856	16.038	16.981	17.45	16.252	16.586	16.251	17.355	
	MEAN	1.1	2.425	2.749	2.429	2.492	2.621	2.543	0.6	0.673	0.308	0.294	0.41	1.048	2.428	2.748	2.428	2.492	2.542	2.545	0.63	0.643	0.293	0.28		
	PS	1.083	2.398	2.717	2.4	2.461	2.59	2.501	0.592	0.661	0.304	0.28	0.405	1.035	2.396	2.719	2.397	2.462	2.592	2.593	0.623	0.633	0.29			
Thompson Falls	P95	1.117	2.452	2.778	2.46	2.533	2.647	2.577	0.608	0.684	0.312	0.308	0.415	1.062	2.453	2.777	2.455	2.523	2.646	2.582	0.638	0.655	0.297	0.293		
	MEAN	17.619	22.435	28.297	24.626	23.384	14.869	12.369	13.752	16.982	18.534	18.097	15.71	16.744	22.39	28.281	24.701	23.444	14.91	12.33	14.475	16.208	17.621	17.36		
	PS	13.504	18.078	22.243	19.792	18.882	11.843	9.418	10.759	13.149	13.903	13.184	12.98	13.618	17.069	22.215	19.741	17.58	11.131	11.861	11.92	12.973	13.256	13.663		
Hydro - Total	P95	22.478	27.704	35.652	31.465	28.606	18.326	16.341	17.621	22.042	23.023	22.489	18.973	21.298	27.951	35.313	29.653	29.476	18.466	15.053	17.898	20.171	21.583	21.886		
	MEAN	92.161	99.726	112.811	103.098	90.233	80.206	76.658	87.305	89.25	91.205	79.106	97.478	123.782	113.245	103.338	90.532	79.92	80.806	83.205	84.757	87.626	78.757	87.744		
	PS	66.979	77.102	92.355	86.451	80.164	69.788	59.509	58.499	65.51	64.518	63.446	63.012	67.364	71.958	92.211	87.345	74.681	66.67	61.397	64.138	64.859	61.293	65.568		
Load	P95	128.833	131.47	162.677	155.955	134.126	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451	118.451			
	MEAN	-209.151	-185.585	-203.313	-187.362	-202.652	-207.707	-190.231	-184.776	-228.699	-241.531	-230.279	-207.433	-196.114	-185.354	-202.753	-186.697	-200.974	-208.014	-190.154	-196.755	-216.352	-227.83	-216.867		
	PS	-215.478	-190.909	-208.578	-190.29	-212.969	-212.969	-193.283	-189.62	-234.876	-251.492	-245.766	-214.571	-203.246	-190.595	-206.967	-189.863	-208.064	-213.307	-193.505	-202.807	-225.504	-225.27	-229.624		
Small QF1	P95	-202.684	-180.372	-199.185	-184.379	-196.093	-201.931	-187.242	-180.077	-222.421	-233.563	-214.332	-200.764	-189.861	-180.729	-198.352	-184.208	-194.196	-203.681	-187.091	-191.931	-211.097	-219.832	-202.426		
	MEAN	0.704	0.623	0.655	1.224	3.885	0.967	1.693	0.909	0.762	0.598	0.493	0.272	0.622	0.575	0.603	1.177	3.838	0.917	1.643	0.906	0.676	0.569	0.47		
	PS	0.704	0.623	0.655	1.224	3.885	0.967	1.693	0.909	0.762	0.598	0.493	0.272	0.622	0.575	0.603	1.177	3.838	0.917	1.643	0.906	0.676	0.569			
Small Tier II	P95	2.252	2.338	2.282	2.853	2.801	2.434	2.688	2.882	2.613	2.049	1.851	2.411	2.338	2.282	2.852	2.53	2.149	2.4	2.745	2.201	1.678	1.479	1.06		
	MEAN	1.831	1.737																							
	PS	1.831	1.737																							
Tiber	P95	1.831	1.737																							
	MEAN	0.005	1.736	1.685	1.877	1.576	1.742	1.737	0.005	1.654	1.603	1.79	1.576	1.742	1.737	0.005	1.654	1.603	1.79	1.576	1.742	1.742	1.742			
	PS	0.005	1.736	1.685	1.877	1.576	1.742	1.737	0.005	1.654	1.603	1.79	1.576	1.742	1.737	0.005	1.654	1.603	1.79	1.576	1.742	1.742	1.742			
Turnbull	P95	1.831	1.737																							
	MEAN	0.005	1.697																							

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2020-03	2020-04	2020-05	2020-06	2020-07	2020-08	2020-09	2020-10	2020-11	2020-12	2021	2021-02	2021-03	2021-04	2021-05	2021-06	2021-07	2021-08	2021-09	2021-10	2021-11	2021-12	2022	2022-02	2022-03
Judith Gap	PS	13.688	11.85	9.635	7.476	5.161	7.105	7.391	12.76	17.869	18.739	24.773	13.956	13.055	11.675	9.82	7.512	5.723	6.871	6.771	13.282	16.986	17.485	23.	13.628	12.902
	P95	22.965	19.285	18.206	14.533	12.212	14.098	15.218	21.423	26.376	28.156	35.178	22.452	21.604	19.908	18.979	15.107	11.611	14.262	15.051	21.709	25.906	26.928	31.791	22.885	20.939
	MEAN	1.075	1.106	0.696	0.732	0.481	0.533	0.648	0.823	1.171	1.171	1.517	1.254	0.994	1.11	0.705	0.734	0.469	0.527	0.651	0.875	1.106	1.102	1.41	1.254	0.998
Musselshell 1	PS	0.796	0.898	0.436	0.534	0.319	0.367	0.458	0.555	0.799	0.786	1.146	0.972	0.687	0.897	0.471	0.532	0.352	0.385	0.447	0.599	0.741	0.703	1.105	0.972	0.751
	P95	1.358	1.338	0.932	0.974	0.677	0.701	0.874	1.079	1.432	1.567	1.93	1.517	1.336	1.366	0.975	0.936	0.622	0.723	0.884	1.171	1.475	1.528	1.715	1.555	1.237
	MEAN	1.251	1.33	0.884	0.871	0.58	0.675	0.809	0.956	1.432	1.343	1.681	1.41	1.159	1.333	0.895	0.873	0.567	0.669	0.811	1.013	1.354	1.266	1.563	1.41	1.163
Musselshell 2	PS	0.932	1.072	0.594	0.633	0.395	0.49	0.585	0.664	1.023	0.95	1.262	1.112	0.825	1.067	0.623	0.643	0.429	0.499	0.569	0.703	0.946	0.866	1.244	1.101	0.905
	P95	1.58	1.584	1.139	1.14	0.821	0.906	1.063	1.267	1.716	1.772	2.139	1.695	1.523	1.624	1.188	1.127	0.748	0.877	1.071	1.351	1.735	1.699	1.88	1.74	1.427
	MEAN	0.097	0.109	0.172	0.15	0.161	0.147	0.124	0.061	0.046	0.033	0.049	0.054	0.077	0.107	0.171	0.149	0.16	0.146	0.124	0.078	0.039	0.026	0.041	0.052	0.076
Ragen Ranch Solar	PS	0.026	0.026	0.07	0.02	0.079	0.047	0.015	0.009	0.014	0.016	0.009	0.011	0.026	0.033	0.059	0.024	0.072	0.04	0.012	0.012	0.01	0.012	0.007	0.01	0.018
	P95	0.168	0.193	0.289	0.292	0.225	0.216	0.226	0.119	0.118	0.061	0.102	0.115	0.139	0.195	0.287	0.286	0.23	0.217	0.227	0.146	0.098	0.043	0.096	0.116	0.134
	MEAN	0.063	0.054	0.11	0.089	0.096	0.083	0.068	0.034	0.031	0.02	0.025	0.029	0.051	0.054	0.11	0.09	0.095	0.083	0.073	0.044	0.025	0.015	0.02	0.028	0.05
River Bend Solar	PS	0.	0.	0.038	0.019	0.052	0.031	0.	0.	0.	0.004	0.	0.	0.	0.001	0.038	0.026	0.052	0.032	0.001	0.	0.	0.003	0.	0.	0.
	P95	0.117	0.097	0.169	0.15	0.133	0.126	0.122	0.077	0.085	0.048	0.066	0.066	0.097	0.094	0.17	0.15	0.135	0.125	0.134	0.096	0.07	0.038	0.057	0.067	0.097
	MEAN	0.1	0.103	0.186	0.162	0.178	0.149	0.126	0.059	0.054	0.033	0.044	0.05	0.08	0.103	0.185	0.161	0.177	0.146	0.126	0.074	0.045	0.025	0.035	0.048	0.079
South Mills Solar	PS	0.016	0.014	0.072	0.025	0.096	0.052	0.003	0.002	0.015	0.015	0.004	0.006	0.017	0.026	0.062	0.035	0.098	0.042	0.009	0.005	0.013	0.011	0.002	0.007	0.013
	P95	0.176	0.189	0.289	0.277	0.239	0.211	0.227	0.122	0.123	0.06	0.101	0.116	0.145	0.189	0.288	0.274	0.242	0.214	0.225	0.15	0.101	0.04	0.099	0.117	0.144
	MEAN	5.98	4.371	3.034	2.826	2.851	2.466	3.865	4.568	6.723	7.428	8.1	5.935	5.568	4.395	3.095	2.846	2.842	2.436	3.893	4.881	6.354	7.011	7.713	5.907	5.566
Spion Kop	PS	4.491	3.009	1.606	1.867	1.895	1.703	2.874	3.268	4.763	5.835	6.549	3.98	4.	2.967	1.975	1.724	1.92	1.749	2.666	3.317	4.748	5.238	6.275	4.182	4.332
	P95	7.572	5.72	4.17	4.117	4.086	3.306	5.195	5.771	7.902	9.265	9.648	7.365	7.067	6.002	4.704	4.076	3.858	3.295	5.304	6.601	7.97	8.9	8.961	7.56	6.83
	MEAN	1.495	1.4	0.544	0.946	0.631	0.627	0.771	1.413	1.793	1.574	2.211	1.323	1.397	1.405	0.55	0.946	0.616	0.621	0.78	1.495	1.7	1.484	2.037	1.324	1.403
Two Dot Wind	PS	1.182	1.186	0.285	0.724	0.41	0.427	0.559	1.172	1.453	1.151	1.843	0.997	1.046	1.17	0.522	0.731	0.452	0.45	0.532	1.221	1.334	1.104	1.715	0.999	1.119
	P95	1.829	1.632	0.775	1.227	0.888	0.809	1.039	1.705	2.081	2.017	2.6	1.611	1.73	1.673	0.83	1.224	0.806	0.835	1.024	1.786	2.079	2.307	1.674	1.719	
	MEAN	53.203	44.991	37.192	33.043	26.281	27.795	33.379	48.207	67.738	68.473	80.287	51.854	49.308	45.192	37.625	33.16	26.022	27.479	33.634	51.391	64.195	64.691	86.199	60.643	57.354
Wind/Solar Asset - Total	PS	42.547	34.75	27.198	24.208	18.669	20.563	25.018	39.043	56.04	57.311	69.788	40.249	39.06	35.131	28.161	24.461	19.665	20.796	24.187	40.345	53.262	53.615	75.091	46.895	46.192
	P95	63.859	54.142	45.876	43.215	35.313	37.081	43.285	58.781	75.971	79.52	92.153	60.849	61.24	56.895	48.442	42.813	33.718	36.056	43.501	62.602	75.185	77.014	96.062	74.15	67.074
	MEAN	58.084	54.676	34.118	3.919	24.704	31.332	37.186	50.933	58.023	53.529	80.426	34.738	51.472	54.313	49.77	14.584	24.725	28.216	34.803	49.926	54.159	48.761	91.659	43.14	56.753
Total	PS	25.262	24.015	-0.428	-27.148	-4.84	2.867	10.937	25.649	32.144	17.774	44.508	7.202	24.143	27.302	16.826	-13.557	-6.138	-4.228	9.891	21.514	28.991	16.662	56.495	15.178	26.085
	P95	93.054	87.268	72.112	43.014	58.026	62.7	70.361	79.242	103.603	91.599	121.967	63.491	78.515	88.931	84.214	44.76	66.803	61.626	66.552	74.988	86.108	81.797	129.234	77.291	95.796
	MEAN																									

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2022-04	2022-05	2022-06	2022-07	2022-08	2022-09	2022-10	2022-11	2022-12	2023	2023-02	2023-03	2023-04	2023-05	2023-06	2023-07	2023-08	2023-09	2023-10	2023-11	2023-12	2024	2024-02	2024-03	2024-04											
Basin Creek	MEAN	0.1	0.04	0.104	0.774	0.205	0.069	0.396	1.023	0.978	0.519	0.378	0.119	0.007	0.133	0.834	0.181	0.09	0.413	1.119	1.1	0.647	0.367	0.098													
	PS	0.	0.	0.	0.078	0.	0.	0.045	0.223	0.201	0.022	0.	0.	0.	0.156	0.	0.	0.022	0.283	0.257	0.034	0.	0.														
	P95	0.335	0.056		0.453	1.838	1.055	0.302	0.994	2.447	2.018	1.511	1.167	0.561	0.045	0.527	1.667	0.603	0.268	1.213	2.261	2.797	1.551	0.906	0.48												
CELLP	MEAN	10.186	11.386	4.361	7.347	6.901	9.746	11.251	11.16	11.76	10.664	8.045	10.752	10.695	4.288	7.309	6.839	9.716	11.798	11.201	12.43	11.787	10.472	10.068													
	PS	9.572	11.053	3.802	6.309	6.103	9.514	11.531	10.665	10.738	11.129	10.193	7	10.13	10.392	3.678	6.309	6.094	9.486	11.511	10.685	11.915	11.233	9.898	7.434	9.366											
	P95	10.805	11.858	5.062	8.56	7.744	10.134	12.296	11.821	11.75	12.266	11.084	8.966	11.301	11.135	4.856	8.462	7.705	10.209	12.296	11.693	12.999	12.224	11.01	9.527	10.561											
Colstrip 3	MEAN	19.576	15.249	10.337	22.062	25.375	27.037	29.572	29.772	29.923	31.414	27.471	26.993	21.298	0.948	2.454	22.423	25.691	27.285	30.064	29.777	33.155	31.263	28.025	28.639	20.567											
	PS	13.051	10.188	7.348	11.726	18.858	18.257	20.456	23.073	23.1	25.097	22.692	19.622	13.389	0.662	1.95	13.049	19.469	19.892	24.663	22.685	25.96	23.442	21.162	19.082	11.807											
	P95	26.365	23.277	17.494	34.607	31.096	32.972	34.617	34.398	33.523	35.73	30.603	31.564	28.771	1.896	3.715	34.656	31.348	32.679	34.916	34.477	37.145	35.432	31.779	33.858	27.735											
Colstrip 4	MEAN	19.597	2.692	1.15	21.813	25.385	26.436	29.352	29.992	30.15	31.467	27.449	27.008	20.966	15.22	10.484	22.224	25.4	27.078	29.868	30.519	33.628	31.419	28.008	29.037	20.633											
	PS	12.892	1.852	0.581	11.066	20.073	18.175	21.026	22.523	24.441	24.478	20.972	19.997	12.302	9.936	7.039	11.961	19.274	18.477	21.378	23.821	28.938	25.331	21.335	21.83	12.375											
	P95	27.132	4.646	1.9	34.632	31.261	32.078	34.617	34.398	33.611	35.648	31.248	31.395	28.619	22.715	17.123	34.656	31.325	32.886	34.916	34.552	37.043	35.299	32.107	34.086	27.735											
CX FrameCT1	MEAN																																				
	PS																																				
	P95																																				
CX FrameCT1	MEAN																																				
	PS																																				
	P95																																				
CX Recip1	MEAN																																				
	PS																																				
	P95																																				
CX Recip10	MEAN																																				
	PS																																				
	P95																																				
CX Recip2	MEAN																																				
	PS																																				
	P95																																				
CX Recip3	MEAN																																				
	PS																																				
	P95																																				
CX Recip4	MEAN																																				
	PS																																				
	P95																																				
CX Recip5	MEAN																																				
	PS																																				
	P95																																				
CX Recip6	MEAN																																				
	PS																																				
	P95																																				
CX Recip7	MEAN																																				
	PS																																				
	P95																																				
CX Recip8	MEAN																																				
	PS																																				
	P95																																				
CX Recip9	MEAN																																				
	PS																																				
	P95																																				
David Gates Generating Station	MEAN	10.05	10.444	9.12	10.992	13.891	11.827	11.065	13.025	15.489	16.038	12.401	11.991	10.697	9.927	9.12	11.123	14.19	11.834	11.352	13.348	17.377	16.47	13.264	12.552	10.094											
	PS	9.12	10.32	9.12	10.32	11.285	9.8	9.94	10.875	12.523	12.865	9.89	9.71	9.6	9.84	9.12	10.32	12.148	9.8	10.04	10.875	14.22	13.453	10.33	10.578	9.12											
	P95	11.47	11.145	9.12	12.995	16.91	15.475	12.778	15.975	19.36	18.578	15.678	14.498	12.875	10.29	9.12	13.195	16.46	14.413	13.253	16.238	20.42	20.715	16.243	15.065	11.833											
FrameCT_ram p_2018	MEAN	0.025	0.013	0.	0.226	2.304	0.327	0.025	0.531	1.445	2.982	0.974	0.345	0.041	0.014	0.001	0.272	2.41	0.223	0.	0.513	1.592	3.443	1.481	0.291	0.025											
	PS	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.115	0.	0.	0.	0.	0.	0.	0.	0.	0.										
	P95	0.177	0.129	0.	1.044																																

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2022-04	2022-05	2022-06	2022-07	2022-08	2022-09	2022-10	2022-11	2022-12	2023	2023-02	2023-03	2023-04	2023-05	2023-06	2023-07	2023-08	2023-09	2023-10	2023-11	2023-12	2024	2024-02	2024-03	2024-04
Hauser	MEAN	4.558	4.978	4.604	5.325	4.927	4.847	4.884	4.675	4.737	4.462	4.605	4.787	4.747	4.604	5.313	4.915	4.852	4.669	5.031	4.725	4.227	4.856	4.563		
	PS	4.353	4.707	4.424	5.098	4.7	4.598	4.641	4.427	4.336	4.464	4.026	4.4	4.489	4.499	4.378	5.034	4.7	4.643	4.627	4.431	4.771	4.517	3.991	4.634	4.356
	P95	4.247	4.528	4.295	5.244	5.116	5.088	5.322	4.895	4.992	4.512	4.416	4.917	4.608	4.546	5.095	5.077	5.343	4.907	5.327	4.927	4.497	4.927	4.407	4.725	4.25
Holter	MEAN	10.694	12.628	11.475	11.808	9.259	9.165	9.349	9.804	10.056	10.465	9.267	9.808	11.257	12.045	11.467	11.78	9.263	9.172	9.364	9.779	10.454	9.185	10.448	10.688	
	PS	9.151	10.526	9.716	9.789	7.663	7.78	7.894	8.028	8.403	8.697	7.663	8.239	9.035	9.717	9.376	9.519	7.849	7.641	7.873	8.063	9.267	8.848	7.639	8.672	8.935
	P95	12.7	14.634	13.317	13.722	11.195	10.953	11.316	11.579	11.877	12.479	10.784	11.636	13.52	14.408	13.901	13.971	10.711	10.644	11.104	11.502	13.748	12.185	11.07	11.981	12.225
Madison	MEAN	2.207	2.563	2.279	2.631	2.305	2.25	2.411	2.384	2.313	2.445	2.208	2.398	2.32	2.444	2.276	2.62	2.301	2.253	2.417	2.381	2.547	2.441	2.191	2.529	2.207
	PS	2.085	2.392	2.157	2.458	2.149	2.116	2.255	2.221	2.171	2.285	2.108	2.264	2.152	2.278	2.207	2.407	2.163	2.284	2.226	2.389	2.232	2.126	2.057	2.374	2.082
	P95	2.338	2.706	2.406	2.784	2.464	2.396	2.578	2.541	2.477	2.608	2.376	2.535	2.467	2.594	2.424	2.789	2.416	2.387	2.602	2.537	2.749	2.589	2.344	2.675	2.328
Morony	MEAN	9.856	12.758	11.682	11.516	8.879	8.679	9.007	8.963	8.437	9.652	8.813	9.078	11.661	11.431	8.874	8.658	9.039	9.068	8.915	9.908	9.639	8.365	9.419	9.848	
	PS	8.204	10.172	9.716	9.186	7.02	7.056	7.198	6.98	6.986	7.628	6.817	7.093	8.044	7.13	9.088	8.632	7.287	7.03	7.171	6.995	7.685	6.625	7.489	8.067	
	P95	12.071	15.25	13.673	13.636	11.111	10.545	11.304	11.023	11.422	12.198	10.361	10.425	12.677	15.113	10.158	13.813	10.583	10.319	11.196	10.814	13.06	11.688	10.342	11.185	11.588
Mystic	MEAN	0.554	1.252	2.282	3.814	2.997	2.034	1.61	1.515	1.395	1.407	1.129	0.902	0.583	1.15	2.269	2.969	2.044	1.622	1.504	1.592	1.383	1.113	0.977	0.556	
	PS	0.492	1.086	1.935	3.553	2.313	1.677	1.264	1.184	0.932	0.969	0.823	0.713	0.514	1.019	1.935	3.501	2.312	1.703	1.142	1.035	1.003	0.819	0.802	0.493	
	P95	0.64	1.447	2.618	4.056	3.585	2.483	2.097	1.896	1.958	1.929	1.525	1.092	0.668	1.356	2.617	4.04	3.503	2.409	2.118	1.844	2.352	1.844	1.511	1.17	0.624
Rainbow	MEAN	14.053	17.894	16.566	15.245	12.196	11.122	11.629	11.564	11.826	12.389	11.325	12.75	14.773	17.018	16.575	15.222	12.218	11.1	11.663	11.508	13.092	12.392	11.187	13.464	14.039
	PS	7.148	7.859	8.867	6.652	5.794	6.082	6.06	5.414	5.038	4.989	5.678	5.615	6.082	7.187	6.789	6.226	5.802	5.541	5.275	5.551	5.503	5.658	5.103	6.058	
	P95	25.185	31.187	28.672	26.654	21.604	20.357	20.284	21.05	22.707	23.568	18.313	23.825	27.465	31.943	30.805	28.688	18.51	19.417	20.638	19.442	25.61	23.366	20.216	22.983	22.964
Ryan	MEAN	16.053	19.712	17.583	17.483	14.632	14.632	14.566	15.226	15.081	14.456	15.733	15.285	16.455	18.797	17.574	17.364	14.573	14.475	14.475	15.023	16.002	15.319	14.762	16.128	16.079
	PS	14.053	17.723	16.204	15.763	12.98	12.907	13.593	13.298	13.011	12.715	12.823	13.179	14.026	17.013	15.826	15.317	13.132	13.021	13.396	13.402	14.172	13.355	12.094	13.981	14.057
	P95	18.046	21.195	19.05	18.982	16.219	16.117	17.126	16.715	16.177	17.958	15.472	17.158	19.145	20.232	19.056	19.109	15.71	16.115	17.186	16.81	18.225	17.424	16.069	17.995	
Sleeping Giant	MEAN	2.427	2.747	2.428	2.748	2.491	2.547	0.63	0.643	0.293	0.279	0.41	1.047	2.556	2.621	2.43	2.746	2.491	2.546	0.63	0.643	0.323	0.279	0.407	1.101	2.427
	PS	2.394	2.713	2.396	2.722	2.465	2.508	0.62	0.631	0.29	0.267	0.404	1.035	2.524	2.587	2.403	2.709	2.47	2.511	0.623	0.631	0.319	0.267	0.407	1.087	2.399
	P95	2.454	2.781	2.454	2.776	2.519	2.582	0.639	0.655	0.297	0.292	0.416	1.06	2.586	2.647	2.456	2.777	2.52	2.585	0.639	0.656	0.328	0.294	0.413	1.115	2.458
Thompson Falls	MEAN	22.371	28.265	24.658	25.81	14.15	12.382	14.454	16.244	17.614	17.381	15.726	16.685	23.539	29.933	24.654	25.745	14.152	12.395	14.482	16.198	19.412	17.382	15.584	17.593	22.34
	PS	17.941	21.688	19.607	19.493	10.966	9.881	11.46	12.366	13.564	13.073	12.237	12.876	17.272	19.936	18.725	19.143	11.294	9.662	11.291	12.481	14.972	13.799	12.183	13.506	17.334
	P95	27.799	34.727	29.595	31.621	17.926	15.718	18.299	20.112	22.179	22.256	19.287	20.433	29.569	33.908	31.245	32.053	16.986	15.068	17.925	20.221	25.51	21.152	19.959	20.794	26.602
Hydro - Total	MEAN	99.399	123.795	113.03	113.862	85.845	87.746	80.259	80.583	83.569	84.656	87.746	87.215	104.533	118.022	112.978	113.415	85.785	80.309	80.839	83.237	93.469	87.399	92.1	99.363	
	PS	78.159	91.122	87.789	83.689	64.878	63.577	62.489	62.229	61.701	63.687	59.291	64.218	74.558	85.565	84.905	81.849	66.315	62.572	61.702	62.399	68.627	66.343	60.028	67.865	74.058
	P95	129.96	159.748	143.807	147.898	112.761	106.212	107.37	110.463	115.928	120.573	102.858	110.769	139.964	160.359	154.367	148.964	104.669	102.331	105.019	106.175	129.262	116.277	107.136	115.682	122.274
Load	MEAN	-185.913	-202.259	-187.15	-229.269	-195.087	-190.359	-197.566	-216.677	-227.099	-214.349	-207.905	-196.513	-197.094	-191.846	-187.061	-230.431	-195.25	-190.718	-196.843	-216.679	-256.742	-215.141	-201.952	-209.287	-185.297
	PS	-190.63	-206.732	-190.291	-239.501	-200.217	-194.324	-203.412	-222.118	-235.135	-227.266	-214.304	-204.281	-202.861	-196.556	-190.268	-239.696	-201.848	-194.777	-201.955	-223.082	-267.93	-231.028	-210.761	-216.084	-190.429
	P95	-181.274	-196.279	-183.784	-220.227	-189.861	-186.569	-211.414	-213.671	-219.927	-199.721	-188.333	-192.164	-187.766	-183.803	-221.519	-192.448	-207.688	-246.227	-207.438	-232.682	-282.229	-232.042	-202.129	-218.766	
Small QF1	MEAN	0.575	0.603	1.177	1.177	0.813	1.58	0.844	0.613	0.51	0.408	0.212	0.563	0.543	0.513	1.117	1.168	0.813	1.58	0.844	0.613	0.562	0.408	0.211	0.592	0.516
	PS	0.575	0.603	1.177	1.177	0.813	1.58	0.844	0.613	0.51	0.408	0.212	0.563	0.543	0.513	1.117	1.168	0.813	1.58	0.844	0.613	0.562	0.408	0.211	0.592	0.516
	P95	0.575	0.603	1.177	1.177	0.813	1.58	0.844	0.613	0.51	0.408	0.212	0.563	0.543	0.513	1.117	1.168	0.813	1.58	0.844	0.613	0.562	0.408	0.211	0.592	0.516
Small Tier II	MEAN	2.065	1.984	2.58	2.79	2.044	2.4	2.745	2.201	1.678	1.479	1.06	1.871	2.174	1.891	2.58	2.732	1.991	2.344	2.69	2.144	1.792	1.423	0.998	1.911	2.012
	PS	2.065	1.984	2.58	2.79	2.044	2.4	2.745	2.201	1.678	1.479	1.06	1.871	2.174	1.891	2.58	2.732	1.991	2.344	2.69	2.144	1.792	1.423	0.998	1.911	2.012
	P95	2.065	1.984	2.58	2.79	2.044	2.4	2.745	2.201	1.678	1.479	1.06	1.871	2.174	1.891	2.58	2.732	1.991	2.344	2.69	2.144	1.792	1.423	0.998	1.911	2.012
Tiber	MEAN	1.737						0.005	1.654	1.603	1.79	1.576	1.742	1.828				0.005	1.654	1.767	1.79	1.564	1.831	1.737		
	PS	1.737						0.005	1.654	1.603	1.79	1.576	1.742	1.828				0.005	1.654	1.767	1.79	1.564	1.831	1.737		
	P95	1.737						0.005	1.654	1.603	1.79	1.576	1.742	1.828				0.005	1.654	1.767	1.79	1.564	1.831	1.737		
Turnbull	MEAN	0.005	1.697	3.401	4.411	2.985	1.106	0.014	0.005	1.618	3.401	4.411	2.985	1.106	0.014	0.005	1.618	3.401	4.411	2.985	1.106	0.014	0.005	1.618	3.401	4.411
	PS	0.005	1.697	3.401	4.411	2.985	1.106	0.014	0.005	1.618	3.401	4.411	2.985	1.106	0.014	0.005	1.618	3.401	4.411	2.985	1.106	0.014	0.005	1.618	3.401	4.411

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2022-04	2022-05	2022-06	2022-07	2022-08	2022-09	2022-10	2022-11	2022-12	2023	2023-02	2023-03	2023-04	2023-05	2023-06	2023-07	2023-08	2023-09	2023-10	2023-11	2023-12	2024	2024-02	2024-03	2024-04
Judith Gap	PS	11.761	9.535	7.629	5.686	6.487	7.568	13.36	16.976	18.203	23.093	14.558	13.379	13.11	8.788	7.91	6.527	6.279	7.47	11.643	17.455	20.088	22.467	13.757	13.866	11.409
	P95	19.346	19.608	15.183	13.728	12.58	15.235	22.084	25.189	27.183	33.657	22.152	21.923	20.583	17.422	14.618	13.699	13.497	15.149	22.477	25.008	30.607	33.983	22.994	22.393	19.629
	MEAN	1.111	0.703	0.74	0.526	0.507	0.668	0.885	1.106	1.113	1.483	1.257	1.011	1.182	0.649	0.735	0.533	0.507	0.658	0.864	1.101	1.235	1.48	1.255	1.058	1.113
Musselshell 1	PS	0.891	0.456	0.535	0.342	0.356	0.461	0.61	0.865	0.764	1.123	1.002	0.723	0.956	0.406	0.548	0.344	0.334	0.483	0.574	0.794	0.859	0.991	0.972	0.779	0.901
	P95	1.32	1.022	0.963	0.738	0.676	0.872	1.16	1.417	1.522	1.891	1.498	1.285	1.407	0.894	0.944	0.725	0.676	0.846	1.179	1.426	1.698	1.829	1.559	1.368	1.339
	MEAN	1.335	0.892	0.881	0.635	0.644	0.829	1.024	1.354	1.277	1.646	1.413	1.179	1.417	0.83	0.874	0.643	0.643	0.82	1	1.346	1.418	1.643	1.41	1.233	1.336
Musselshell 2	PS	1.078	0.608	0.64	0.415	0.467	0.602	0.708	1.077	0.936	1.23	1.144	0.872	1.165	0.557	0.659	0.429	0.44	0.598	0.655	1.018	1.024	1.089	1.101	0.928	1.104
	P95	1.591	1.248	1.127	0.874	0.843	1.085	1.336	1.698	1.678	2.059	1.677	1.47	1.68	1.112	1.116	0.865	0.845	1.042	1.339	1.659	1.898	2.028	1.712	1.576	1.597
	MEAN	0.108	0.171	0.145	0.213	0.119	0.124	0.078	0.038	0.026	0.041	0.051	0.075	0.13	0.146	0.143	0.211	0.118	0.12	0.076	0.038	0.039	0.04	0.05	0.094	0.105
Ragen Ranch Solar	PS	0.036	0.063	0.013	0.092	0.03	0.014	0.011	0.009	0.013	0.005	0.011	0.017	0.043	0.047	0.001	0.077	0.028	0.005	0.008	0.009	0.018	0.009	0.013	0.033	0.035
	P95	0.207	0.287	0.287	0.303	0.181	0.226	0.147	0.097	0.046	0.086	0.111	0.137	0.221	0.256	0.288	0.309	0.177	0.232	0.148	0.094	0.074	0.098	0.112	0.164	0.201
	MEAN	0.055	0.111	0.091	0.132	0.066	0.067	0.043	0.025	0.015	0.022	0.028	0.049	0.069	0.093	0.091	0.132	0.067	0.072	0.042	0.026	0.024	0.021	0.026	0.059	0.054
River Bend Solar	PS	0.001	0.041	0.028	0.077	0.025	0.	0.	0.	0.004	0.	0.	0.	0.005	0.034	0.03	0.073	0.027	0.001	0.	0.	0.	0.	0.	0.	0.001
	P95	0.095	0.169	0.15	0.183	0.101	0.121	0.096	0.067	0.037	0.057	0.065	0.093	0.119	0.144	0.148	0.183	0.1	0.132	0.092	0.072	0.059	0.06	0.062	0.115	0.093
	MEAN	0.103	0.184	0.159	0.231	0.12	0.126	0.075	0.044	0.026	0.038	0.048	0.078	0.125	0.158	0.159	0.23	0.119	0.123	0.073	0.044	0.039	0.037	0.046	0.098	0.1
South Mills Solar	PS	0.025	0.061	0.029	0.114	0.037	0.005	0.005	0.011	0.013	0.002	0.006	0.008	0.033	0.046	0.027	0.097	0.035	0.002	0.005	0.011	0.018	0.004	0.009	0.032	0.02
	P95	0.191	0.292	0.275	0.321	0.176	0.228	0.151	0.1	0.046	0.09	0.108	0.143	0.222	0.255	0.271	0.328	0.174	0.229	0.151	0.102	0.073	0.1	0.113	0.174	0.19
	MEAN	4.417	3.072	2.867	3.138	2.326	3.956	4.922	6.368	7.114	7.825	5.958	5.669	4.733	2.846	2.836	3.173	2.334	3.929	4.833	6.319	7.786	7.761	5.905	5.91	4.421
Spion Kop	PS	2.948	1.736	1.779	1.905	1.597	2.753	3.303	4.912	5.711	6.304	4.416	4.267	3.288	1.619	1.841	1.899	1.514	2.719	3.342	4.885	5.883	6.219	4.098	4.61	3.091
	P95	5.893	4.703	3.974	4.44	3.125	5.298	6.506	7.613	8.613	9.378	7.46	7.047	6.175	4.076	3.826	4.401	3.35	5.298	6.602	7.654	9.658	9.151	7.567	7.41	5.783
	MEAN	1.406	0.546	0.954	0.691	0.596	0.795	1.504	1.697	1.489	2.144	1.326	1.416	1.491	0.496	0.949	0.7	0.594	0.786	1.481	1.689	1.652	2.139	1.327	1.48	1.407
Two Dot Wind	PS	1.168	0.294	0.728	0.46	0.421	0.576	1.231	1.41	1.086	1.769	1.025	1.104	1.281	0.286	0.724	0.464	0.407	0.564	1.171	1.396	1.267	1.655	1.025	1.147	1.151
	P95	1.638	0.85	1.206	0.953	0.794	1.048	1.792	1.995	1.874	2.484	1.6	1.738	1.722	0.725	1.155	0.924	0.781	1.011	1.802	2.01	2.155	2.493	1.648	1.795	1.655
	MEAN	52.755	43.494	38.826	34.181	30.187	39.777	60.973	76.077	77.312	90.816	60.898	58.114	56.453	40.529	38.662	34.662	30.291	39.471	60.097	75.868	85.602	103.352	69.574	69.538	60.108
Wind/Solar Asset - Total	PS	49.993	31.334	27.805	23.164	21.977	29.016	48.741	65.118	66.865	76.453	48.998	46.472	45.287	29.557	29.135	24.168	21.034	28.958	45.383	65.92	72.331	84.343	55.448	56.424	45.386
	P95	65.188	56.869	49.255	45.592	38.277	51.394	72.613	86.118	89.534	103.518	72.305	69.973	68.393	59.961	48.444	45.229	40.072	49.995	74.237	84.945	100.3	116.023	83.869	83.727	73.423
	MEAN	51.76	35.085	6.156	14.585	29.6	37.213	56.173	65.148	63.421	100.234	45.053	57.821	55.388	31.988	7.312	14.429	30.347	37.069	57.63	65.408	65.654	119.034	66.374	70.912	61.934
Total	PS	17.95	-5.949	-25.309	-26.657	4.697	11.136	28.815	37.897	31.896	65.945	14.254	24.124	24.857	-5.859	-27.055	-24.567	0.299	4.562	31.245	37.5	28.755	72.833	40.122	37.799	29.976
	P95	90.703	70.971	36.703	58.221	63.103	71.711	85.414	95.215	98.976	148.186	79.278	95.426	94.865	74.663	47.309	61.252	56.5	64.79	89.848	100.479	107.623	168.293	101.575	110.988	92.837

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2024-05	2024-06	2024-07	2024-08	2024-09	2024-10	2024-11	2024-12	2025	2025-02	2025-03	2025-04	2025-05	2025-06	2025-07	2025-08	2025-09	2025-10	2025-11	2025-12	2026	2026-02	2026-03	2026-04	2026-05	
Basin Creek	MEAN	0.011	0.155	0.883	0.217	0.106	0.439	1.199	1.083	0.449	0.359	0.124	0.008	0.121	0.915	0.264	0.106	0.47	1.322	1.042	0.526	0.448	0.128	0.009			
	PS	0.	0.168	0.	0.	0.	0.022	0.224	0.212	0.045	0.	0.	0.	0.	0.212	0.	0.	0.022	0.283	0.242	0.	0.	0.	0.			
	P95	0.089	0.735	2.001	0.949	0.439	1.127	2.73	2.388	1.088	1.142	0.443	0.045	0.483	1.883	1.132	0.447	1.21	2.828	2.233	1.369	1.389	0.551	0.045			
CELP	MEAN	10.743	4.895																								
	PS	10.412	4.919																								
	P95	11.481	5.637																								
Colstrip 3	MEAN	15.309	11.033	21.751	26.099	28.938	28.545	30.148	33.368	31.433	27.681	29.357	20.963	15.742	11.198	22.502	27.44	27.335	28.377	31.845	31.909	31.816	27.782	29.477	21.242	4.217	
	PS	9.989	7.816	11.524	19.301	20.804	21.023	24.645	26.784	22.964	21.822	22.298	17.712	10.041	8.017	11.877	19.816	16.933	20.752	25.462	25.734	26.312	22.91	22.461	13.673	2.423	
	P95	23.07	19.031	33.047	31.734	34.191	33.179	34.198	37.38	37.38	35.714	31.411	34.16	27.233	23.043	17.412	33.024	33.078	32.839	33.291	36.364	35.555	35.657	31.383	34.273	28.556	7.373
Colstrip 4	MEAN	15.339	11.131	21.343	25.775	28.365	28.248	30.703	33.733	31.914	28.068	29.095	20.721	4.156	2.894	22.109	27.648	27.046	28.58	32.26	31.961	32.014	28.006	29.138	20.702	16.525	
	PS	9.971	7.526	11.051	18.361	19.442	19.907	24.841	28.077	24.293	22.202	22.298	11.868	2.243	1.506	10.569	18.515	18.452	20.95	22.138	26.293	24.726	21.995	22.684	13.271	10.399	
	P95	22.666	18.76	33.024	31.149	33.99	33.179	34.198	37.434	35.733	31.507	34.12	28.149	6.639	5.193	33.024	33.078	33.341	33.186	36.38	35.404	35.88	31.433	34.418	27.337	25.133	
CX FrameCT1	MEAN																										
	PS																										
	P95																										
CX FrameCT1	MEAN																										
	PS																										
	P95																										
CX Recip1	MEAN																										
	PS																										
	P95																										
CX Recip10	MEAN																										
	PS																										
	P95																										
CX Recip2	MEAN																										
	PS																										
	P95																										
CX Recip3	MEAN																										
	PS																										
	P95																										
CX Recip4	MEAN																										
	PS																										
	P95																										
CX Recip5	MEAN																										
	PS																										
	P95																										
CX Recip6	MEAN																										
	PS																										
	P95																										
CX Recip7	MEAN																										
	PS																										
	P95																										
CX Recip8	MEAN																										
	PS																										
	P95																										
CX Recip9	MEAN																										
	PS																										
	P95																										
David Gates Generating Station	MEAN	10.017	9.6	10.724	14.219	12.661	11.148	13.455	18.007	16.389	12.297	12.603	10.299	9.977	9.6	10.717	15.063	12.587	11.039	14.315	17.758	16.525	12.678	12.893	10.455	10.467	
	PS	9.84	9.6	9.84	11.91	10.405	9.835	11.088	14.02	13.34	9.79	10.39	9.12	9.84	9.6	9.84	12.365	10.4	9.61	11.005	13.815	12.678	9.74	10.578	9.17	10.32	
	P95	10.765	9.6	12.79	16.86	15.73	13.373	16.525	21.883	19.778	14.79	15.628	11.995	10.515	9.6	12.59	17.678	16.825	13.035	17.255	22.54	20.215	15.928	16.265	12.345	11.02	
FrameCT_ram p_2018	MEAN	0.025	0.002	0.367	2.259	0.198	0.763	1.583	3.334	0.968	0.335	0.069	0.021	0.362	2.408	0.308	0.037	0.876	2.095	3.524	1.181	0.448	0.056	0.015			
	PS	0.	0.	0.	0.009	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	P95	0.154	0.	1.416	5.065	0.897	4.107	6.142	7.582	3.982	2.377	0.323	0.141	0.379	2.497	1.694	0.	4.111	7.027	7.691	4.5	2.504	0.391	0.15			
FrameCT_ram p_2020	MEAN	0.025	0.002	0.365	2.236	0.187	0.735	1.635	3.37	0.954	0.32	0.069	0.017	0.362	2.408	0.308	0.037	0.876	2.095	3.524	1.181	0.448	0.056	0.015			
	PS	0.	0.	0.	0.058	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	P95	0.154	0.	1.619	4.898	0.909	4.107	6.239	6.875	4.078	2.429	0.319	0.136	1.531	5.326	1.781	0.	4.111	6.65	8.174	4.415	3.129	0.391	0.138			
FrameCT_ram p_2022	MEAN	0.025	0.002	0.365	2.308	0.192	0.738	1.6	3.276	0.897	0.339	0.056	0.018	0.362	2.419	0.302	0.037	0.806	2.067	3.525	1.176	0.407	0.056	0.014			
	PS	0.	0.	0.	0.058	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	
	P95	0.154	0.	1.407	4.979	0.918	3.644	5.967	6.932	3.46	2.429	0.288	0.15	1.304	5.336	1.503	0.	3.614	6.947	8.095	4.5	3.129	0.391	0.142			
Recip_ramp_2 018	MEAN	0.03	0.231	1.134	0.841	1.224	1.949	2.694	2.613	1.931	1.552	0.311	0.022	0.219	1.229	0.916	1.196	2.0									

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2024-05	2024-06	2024-07	2024-08	2024-09	2024-10	2024-11	2024-12	2025	2025-02	2025-03	2025-04	2025-05	2025-06	2025-07	2025-08	2025-09	2025-10	2025-11	2025-12	2026	2026-02	2026-03	2026-04	2026-05
Hauser	P95	23.494	24.227	22.407	16.172	14.431	13.004	12.959	17.444	16.536	14.436	17.072	17.646	24.407	23.258	19.709	18.608	14.504	11.227	12.912	16.736	16.063	14.572	15.613	19.329	24.561
	MEAN	4.744	4.823	5.08	4.924	5.084	4.651	4.744	4.667	4.534	4.849	4.57	4.737	4.466	4.849	5.069	5.175	4.847	4.564	4.809	4.809	4.728	4.26	4.853	4.556	4.98
	PS	4.513	4.603	4.844	4.655	4.847	4.41	4.479	4.799	4.461	4.005	4.657	4.416	4.481	4.65	4.817	4.921	4.571	4.423	4.658	4.504	4.449	4.065	4.65	4.298	4.705
Holter	P95	4.935	5.049	5.201	5.117	5.263	5.629	5.917	9.779	11.074	10.442	9.257	10.445	24.712	12.026	12.088	11.252	5.398	5.941	4.864	5.122	5.004	4.929	4.447	5.048	6.768
	MEAN	12.068	12.039	11.27	9.263	8.917	9.779	11.074	10.442	10.442	10.442	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445	10.445
	PS	10.091	10.056	9.49	7.375	8.21	7.408	8.422	9.176	8.696	7.718	8.648	9.327	9.702	10.225	9.011	8.059	7.396	7.524	8.815	8.33	8.633	7.714	9	8.719	10.35
Madison	P95	14.248	14.28	13.501	11.113	11.302	10.974	11.535	13.098	12.325	11.167	12.235	12.294	14.448	14.011	13.071	11.707	10.823	10.52	12.034	12.568	12.276	10.824	12.142	12.409	14.934
	MEAN	2.445	2.388	2.508	2.303	2.364	2.3	2.379	2.542	2.443	2.204	2.529	2.213	2.438	2.396	2.504	2.421	2.255	2.297	2.503	2.431	2.439	2.207	2.53	2.204	2.562
	PS	2.298	2.259	2.34	2.14	2.229	2.136	2.258	2.391	2.272	2.391	2.113	2.275	2.287	2.258	2.391	2.275	2.287	2.359	2.233	2.287	2.101	2.314	2.259	2.046	2.391
Morony	P95	2.594	2.544	2.693	2.452	2.516	2.503	2.517	2.682	2.578	2.362	2.678	2.322	2.577	2.5	2.652	2.581	2.377	2.438	2.658	2.579	2.575	2.336	2.656	2.322	2.749
	MEAN	12.212	12.202	10.98	8.882	9.13	8.618	8.915	9.836	9.214	8.416	9.222	11.239	10.946	9.392	9.222	9.392	9.222	9.392	9.222	9.392	9.222	9.392	9.222	9.392	9.222
	PS	9.723	10.236	8.944	6.575	7.428	6.701	7.379	7.578	7.567	6.695	7.54	8.381	9.267	10.107	8.36	7.363	6.676	6.95	7.807	6.783	7.542	6.81	7.832	7.616	9.691
Mystic	P95	14.943	14.611	13.561	11.022	10.989	11.086	10.851	12.609	11.837	10.434	11.488	11.585	14.978	14.065	13.094	11.52	10.674	10.27	11.264	11.162	11.592	10.218	11.253	11.628	15.836
	MEAN	1.193	2.375	3.62	2.988	2.157	1.526	1.5	1.57	1.403	1.124	0.969	0.556	1.18	2.396	3.617	3.155	2.042	1.524	1.606	1.501	1.403	1.129	0.976	0.554	1.246
	PS	1.094	2.102	3.393	2.272	1.738	1.113	1.211	1.081	0.983	0.817	0.792	0.495	1.018	2.034	3.276	2.486	1.639	1.173	1.267	0.933	0.964	0.839	0.81	0.478	1.049
Rainbow	P95	1.363	2.755	3.843	3.608	2.549	2.071	1.876	2.154	1.891	1.488	1.186	0.629	1.331	2.705	3.845	3.877	2.458	1.912	2.013	2.091	1.865	1.427	1.161	0.624	1.474
	MEAN	17.331	17.389	14.564	12.217	11.744	11.11	11.507	13.008	12.338	11.306	13.477	14.105	16.989	17.534	14.573	12.821	11.097	11.073	12.135	12.476	12.337	11.271	13.668	13.971	17.953
	PS	7.345	8.651	6.868	5.247	5.688	5.493	5.985	5.702	5.396	5.715	7.416	6.59	8.982	5.974	5.492	5.822	5.167	4.979	6.131	4.708	4.584	5.291	6.656	6.637	7.854
Ryan	P95	30.419	30.742	26.064	21.943	18.673	24.021	18.88	25.3	23.36	20.54	23.701	23.36	32.305	28.747	23.964	24.81	19.667	19.022	20.869	23.519	23.497	19.796	20.645	25.541	30.46
	MEAN	18.792	18.387	16.667	14.624	15.17	14.537	15.024	15.931	15.318	14.663	16.311	16.17	18.739	18.469	16.604	15.343	14.486	15.291	15.836	15.291	15.291	16.604	15.743	16.031	19.751
	PS	17.013	16.772	15.018	12.855	13.567	12.734	13.72	14.187	13.041	12.131	13.959	14.585	17.018	16.982	14.822	13.536	12.592	12.928	14.182	13.069	12.974	12.445	14.168	13.342	17.964
Sleeping Giant	P95	20.189	19.822	18.3	16.086	16.771	16.461	16.444	17.456	17.437	15.282	18.378	18.015	20.222	19.649	18.074	17.088	15.924	16.143	17.436	16.943	17.481	15.675	17.988	17.977	21.599
	MEAN	2.617	2.555	2.619	2.492	2.673	0.6	0.643	0.323	0.281	0.409	0.91	2.428	2.62	2.558	2.619	2.62	2.544	0.6	0.674	0.308	0.28	0.406	1.099	2.426	2.749
	PS	2.582	2.518	2.585	2.462	2.633	0.593	0.632	0.319	0.267	0.404	1.084	2.397	2.582	2.527	2.585	2.588	2.491	0.593	0.66	0.304	0.268	0.401	1.085	2.395	2.717
Thompson Falls	P95	2.644	2.589	2.652	2.514	2.609	0.656	0.656	0.327	0.297	0.415	1.114	2.457	2.647	2.585	2.653	2.648	2.584	0.608	0.685	0.313	0.295	0.415	1.114	2.458	2.779
	MEAN	27.048	25.873	24.643	14.162	13.012	13.795	16.206	19.377	17.368	15.711	17.598	22.442	26.912	25.993	24.599	14.865	12.379	13.776	17.039	18.55	17.364	15.689	17.594	22.29	28.379
	PS	20.59	20.408	19.32	10.23	10.4	10.731	13.078	15.003	13.463	12.173	13.549	18.499	19.738	20.806	17.955	14.456	9.183	10.945	13.821	13.329	13.314	12.316	14.852	16.912	21.161
Hydro - Total	P95	33.385	31.627	31.228	18.021	15.917	17.754	20.008	24.274	21.655	19.457	21.743	26.685	33.981	30.905	29.932	19.134	15.241	17.073	20.667	23.313	21.341	19.247	21.135	27.212	35.292
	MEAN	118.382	118.442	108.641	85.892	84.441	76.948	83.238	93.406	87.555	79.023	92.113	99.848	117.685	119.171	108.482	90.185	80.297	87.681	89.224	87.477	87.781	92.137	99.056	124.167	
	PS	86.123	90.225	81.496	61.192	65.385	59.029	65.965	68.347	65.005	58.696	67.518	79.216	88.773	90.361	75.587	67.39	59.301	59.202	69.607	60.307	63.525	59.808	71.167	72.006	90.191
Load	P95	154.669	152.958	145.183	114.083	105.765	105.722	106.435	123.354	118.386	102.638	125.284	125.284	157.936	149.504	136.896	124.224	104.044	98.648	109.109	120.267	116.049	114.535	130.044	163.712	
	MEAN	-191.335	-199.2	-213.96	-196	-202.396	-184.771	-216.269	-256.635	-217.738	-211.236	-212.507	-187.879	-194.98	-202.05	-216.138	-211.753	-194.049	-187.35	-233.066	-245.323	-222.093	-214.631	-216.441	-191.032	-209.582
	PS	-197.049	-202.714	-223.961	-201.118	-205.99	-190.827	-221.703	-268.421	-238.599	-219.044	-220.134	-199.441	-199.892	-204.677	-226.559	-218.971	-197.431	-192.172	-239.367	-255.443	-237.887	-222.429	-223.177	-196.367	-218.807
Small QF1	P95	-191.214	-195.877	-208.022	-193.135	-198.172	-208.26	-210.851	-244.972	-218.266	-210.851	-210.851	-208.992	-198.921	-207.09	-206.083	-190.621	-182.144	-226.792	-234.129	-207.338	-203.822	-209.286	-185.85	-209.079	
	MEAN	0.513	1.176	3.974	0.813	1.659	0.803	0.613	0.562	0.408	0.212	0.592	0.516	0.513	1.176	3.974	0.855	1.58	0.803	0.644	0.536	0.408	0.212	0.592	0.516	0.538
	PS	0.513	1.176	3.974	0.813	1.659	0.803	0.613	0.562	0.408	0.212	0.592	0.516	0.513	1.176	3.974	0.855	1.58	0.803	0.644	0.536	0.408	0.212	0.592	0.516	0.538
Small Tier II	P95	1.835	2.652	0.09	0.095	0.097	0.063	0.048	0.012	0.012	0.011	0.02	0.051	0.066	0.099	0.09	0.1	0.092	0.063	0.05	0.011	0.012	0.011	0.02	0.051	0.069
	MEAN	1.835	2.652	0.09	0.095	0.097	0.063	0.048	0.012	0.012	0.011	0.02	0.051	0.066	0.099	0.09	0.1	0.092	0.063	0.05	0.011	0.012	0.011	0.02	0.051	0.069
	PS	1.835	2.652	0.09	0.095	0.097	0.063	0.048	0.012	0.012	0.011	0.02	0.051	0.066	0.099	0.09	0.1	0.092	0.063	0.05	0.011	0.012	0.011	0.02	0.051	0.069
Turnbull	P95	1.618	3.58	4.206	2.985	1.161	0.013	0.005	1.618	3.58	4.206	3.139	1.106	0.013	1.618	3.58	4.206	3.139	1.106	0.013	1.618	3.58	4.206	3.139	1.106	0.013
	MEAN	1.618	3.58	4.206	2.985	1.161	0.013	0.005	1.618	3.58	4.206	3.139	1.106	0.013	1.618	3.58	4.206	3.139	1.106	0.013	1.618	3.58	4.206	3.139	1.106	0.013
	PS	1.618	3.58	4.206	2.985	1.161	0.013	0.005	1.618	3.58	4.206	3.139	1.106	0.013	1.618	3.58	4.206	3.139	1.106	0.013	1.618	3.58	4.206	3.139	1.106	0.013
Physical Instrument - Total	P95	3.967	7.407	8.27	3.893	2.917	0.879	0.661	0.574	0.42	0.223	0.612	0.572	2.198	4.855	8.27	4.093	2.778	0.879	0.694	0.547	0.42	0.223</			

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2024-05	2024-06	2024-07	2024-08	2024-09	2024-10	2024-11	2024-12	2025	2025-02	2025-03	2025-04	2025-05	2025-06	2025-07	2025-08	2025-09	2025-10	2025-11	2025-12	2026	2026-02	2026-03	2026-04	2026-05
Judith Gap	PS	8.533	7.403	6.057	6.224	7.803	12.505	17.226	20.961	24.297	13.767	12.647	11.672	9.611	7.653	5.996	6.702	6.718	12.021	17.894	18.889	23.41	13.221	13.494	11.817	9.758
	P95	17.715	16.057	14.115	13.137	16.505	21.052	26.031	29.448	34.502	22.771	22.947	20.02	17.678	16.251	14.144	15.083	14.539	20.763	26.707	27.768	33.641	23.018	22.213	18.681	19.399
	MEAN	0.664	0.778	0.508	0.508	0.69	0.833	1.113	1.251	1.478	1.242	1.052	1.109	0.668	0.774	0.509	0.542	0.649	0.84	1.181	1.171	1.469	1.249	1.05	1.098	0.699
Musselshell 1	PS	0.41	0.545	0.337	0.329	0.508	0.577	0.792	0.907	1.083	0.972	0.736	0.856	0.43	0.546	0.343	0.348	0.452	0.577	0.86	0.82	1.066	0.951	0.758	0.885	0.47
	P95	0.908	0.996	0.763	0.673	0.93	1.113	1.433	1.665	1.904	1.522	1.383	1.356	0.889	1.031	0.775	0.745	0.837	1.117	1.507	1.57	1.817	1.588	1.351	1.33	0.99
	MEAN	0.846	0.924	0.613	0.645	0.858	0.964	1.362	1.434	1.638	1.398	1.227	1.332	0.849	0.921	0.632	0.687	0.808	0.972	1.444	1.347	1.628	1.404	1.226	1.32	0.89
Musselshell 2	PS	0.547	0.644	0.417	0.436	0.64	0.657	1.015	1.102	1.224	1.101	0.855	1.047	0.59	0.63	0.421	0.46	0.58	0.662	1.053	0.975	1.168	1.075	0.896	1.066	0.634
	P95	1.118	1.179	0.886	0.835	1.155	1.281	1.734	1.836	2.078	1.72	1.586	1.616	1.132	1.23	0.914	0.924	1.037	1.278	1.781	1.711	2.01	1.762	1.579	1.571	1.233
	MEAN	0.146	0.171	0.183	0.117	0.142	0.061	0.038	0.041	0.04	0.049	0.092	0.103	0.144	0.169	0.181	0.142	0.117	0.062	0.044	0.031	0.039	0.05	0.089	0.103	0.166
Ragen Ranch Solar	PS	0.05	0.018	0.077	0.033	0.005	0.006	0.009	0.021	0.008	0.008	0.02	0.031	0.045	0.017	0.066	0.035	0.	0.007	0.009	0.016	0.006	0.006	0.021	0.03	0.041
	P95	0.257	0.324	0.262	0.177	0.263	0.122	0.095	0.073	0.09	0.111	0.166	0.196	0.256	0.323	0.268	0.214	0.231	0.12	0.112	0.056	0.101	0.111	0.165	0.192	0.292
	MEAN	0.095	0.106	0.113	0.066	0.082	0.034	0.026	0.025	0.021	0.027	0.061	0.054	0.092	0.105	0.113	0.081	0.068	0.035	0.03	0.019	0.02	0.027	0.058	0.053	0.108
River Bend Solar	PS	0.036	0.033	0.065	0.027	0.001	0.	0.	0.006	0.	0.	0.002	0.03	0.031	0.031	0.064	0.029	0.001	0.	0.	0.	0.	0.	0.	0.002	0.038
	P95	0.143	0.173	0.156	0.1	0.148	0.074	0.066	0.058	0.054	0.065	0.115	0.095	0.143	0.17	0.157	0.125	0.123	0.076	0.081	0.044	0.053	0.065	0.112	0.093	0.165
	MEAN	0.159	0.186	0.2	0.121	0.143	0.058	0.044	0.041	0.037	0.045	0.096	0.101	0.156	0.184	0.198	0.141	0.121	0.06	0.052	0.031	0.035	0.046	0.093	0.099	0.18
South Mills Solar	PS	0.049	0.042	0.093	0.045	0.001	0.004	0.014	0.02	0.003	0.004	0.013	0.019	0.04	0.043	0.086	0.033	0.001	0.003	0.01	0.016	0.002	0.003	0.017	0.014	0.043
	P95	0.258	0.309	0.282	0.173	0.262	0.126	0.102	0.073	0.092	0.103	0.178	0.188	0.259	0.307	0.286	0.213	0.224	0.122	0.122	0.055	0.097	0.115	0.172	0.184	0.293
	MEAN	2.871	3.039	3.042	2.337	4.082	4.613	6.415	7.878	7.772	5.872	5.867	4.41	2.928	3.004	3.053	2.506	3.855	4.649	6.769	7.436	7.754	5.898	5.882	4.325	3.052
Spion Kop	PS	1.657	1.722	1.799	1.424	2.856	3.205	4.927	6.561	6.193	4.293	4.338	2.981	1.56	1.794	1.971	1.621	2.715	3.239	4.929	5.63	6.253	3.983	4.419	2.99	1.707
	P95	4.192	4.265	4.563	3.139	5.879	6.024	7.971	9.438	9.387	7.558	7.533	5.995	4.229	4.329	4.405	3.618	5.157	5.948	8.257	9.082	9.145	7.683	7.336	5.637	4.585
	MEAN	0.513	1.005	0.665	0.597	0.823	1.418	1.706	1.668	2.131	1.308	1.473	1.404	0.52	0.999	0.665	0.637	0.775	1.428	1.8	1.575	2.125	1.32	1.475	1.392	0.541
Two Dot Wind	PS	0.278	0.733	0.448	0.394	0.6	1.166	1.362	1.331	1.743	1.039	1.123	1.121	0.3	0.736	0.464	0.442	0.568	1.141	1.448	1.247	1.731	0.954	1.16	1.138	0.324
	P95	0.739	1.27	0.963	0.777	1.134	1.717	2.039	2.038	2.545	1.665	1.838	1.653	0.757	1.272	0.97	0.863	1.002	1.691	2.146	1.959	2.471	1.704	1.823	1.649	0.802
	MEAN	46.544	47.227	37.299	34.357	47.282	66.193	88.371	99.75	103.401	69.077	69.123	60.085	47.037	47.091	37.29	36.804	44.509	66.437	93.169	94.324	102.969	69.317	69.144	59.474	49.391
Wind/Solar Asset - Total	PS	34.734	32.881	25.652	24.309	35.823	53.472	76.476	86.752	89.509	53.877	52.429	45.82	36.005	33.466	26.558	26.203	32.764	52.895	78.967	80.424	87.181	53.619	54.997	46.975	37.099
	P95	58.753	59.875	53.231	43.951	61.72	78.535	101.465	112.777	119.84	84.042	85.819	74.128	58.205	60.847	50.61	51.41	56.16	80.783	107.059	108.558	117.509	86.28	82.362	72.121	63.885
	MEAN	53.625	20.41	16.171	27.844	32.618	55.378	68.847	69.913	101.652	41.148	55.979	47.036	26.55	2.565	15.12	25.234	30.209	52.842	67.725	68.373	98.307	39.284	53.357	43.095	23.566
Total	PS	14.029	-9.412	-21.272	-6.374	2.542	28.761	42.721	28.803	55.72	12.047	24.322	15.736	-12.967	-31.564	-27.86	-12.683	1.035	27.993	38.441	27.646	56.389	11.932	24.679	4.994	-16.817
	P95	96.348	58.267	61.258	65.299	63.108	85.506	100.885	112.562	148.678	69.069	92.443	78.773	67.249	40.96	63.771	68.287	62.614	81.117	97.69	105.238	145.748	70.793	86.176	79.929	64.858
	MEAN																									

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2026-06	2026-07	2026-08	2026-09	2026-10	2026-11	2026-12	2027	2027-02	2027-03	2027-04	2027-05	2027-06	2027-07	2027-08	2027-09	2027-10	2027-11	2027-12	2028	2028-02	2028-03	2028-04	2028-05	2028-06	
Basin Creek	MEAN		0.144	1.034	0.234	0.081	0.517	1.146	1.004	0.507	0.355	0.12	0.022	0.126	1.169	0.226	0.089	0.505	1.129	1.023	0.673	0.401	0.161	0.017			
	P5		0.	0.145	0.	0.	0.022	0.268	0.134	0.022	0.	0.	0.	0.	0.216	0.	0.	0.022	0.224	0.145	0.089	0.	0.	0.			
	P95		0.706	2.189	0.961	0.346	1.299	2.284	2.31	1.498	1.067	0.506	0.134		0.638	2.095	0.808	0.335	1.269	2.472	2.369	1.549	1.067	0.713	0.056		
CELP	MEAN																										
	P5																										
	P95																										
Colstrip 3	MEAN	3.019	21.865	27.595	27.821	28.583	32.1	32.107	33.63	28.101	28.297	21.958	16.965	11.341	22.558	27.977	28.287	30.715	30.808	30.831	32.301	28.63	28.194	23.238	16.815	11.785	
	P5	2.296	12.456	19.714	19.873	20.003	23.555	25.793	26.996	22.	20.943	13.692	10.434	7.59	12.308	20.27	19.874	23.444	25.053	24.976	23.828	20.719	20.801	14.802	10.152	8.107	
	P95	5.752	31.392	33.332	33.426	33.481	36.209	35.733	37.644	31.101	32.499	27.676	24.212	19.122	31.428	33.354	33.452	34.986	34.091	33.924	35.959	32.327	32.614	30.866	25.917	21.827	
Colstrip 4	MEAN	11.33	21.405	27.829	27.953	28.865	32.448	32.476	34.197	28.338	28.154	21.617	16.927	11.301	22.264	28.001	28.063	30.666	31.217	30.799	32.589	28.822	28.496	23.016	2.302	1.3	
	P5	7.799	11.073	19.219	19.093	21.198	26.637	27.134	27.319	20.798	19.929	13.002	10.6	8.144	11.561	20.906	19.567	24.038	25.102	24.884	26.8	21.46	21.827	13.879	0.907	0.273	
	P95	20.81	31.392	33.175	33.426	33.575	36.327	35.728	37.435	31.351	32.643	27.88	25.045	19.122	31.464	33.578	33.452	34.667	34.392	33.778	35.968	32.243	32.826	30.866	3.862	2.607	
CX FrameCT1	MEAN																				3.465	1.406	0.354	0.052	0.021		
	P5																				0.	0.	0.	0.	0.		
	P95																				9.438	4.749	1.97	0.277	0.156		
CX FrameCT1	MEAN																										
	P5																										
	P95																										
CX Recip1	MEAN																				3.034	2.345	1.751	0.428	0.032		
	P5																				1.941	1.463	1.067	0.092	0.		
	P95																				4.14	3.1	2.456	0.883	0.221		
CX Recip10	MEAN																				2.813	2.169	1.618	0.393	0.03		
	P5																				1.794	1.352	0.995	0.068	0.		
	P95																				3.791	2.899	2.253	0.804	0.204		
CX Recip2	MEAN																				3.042	2.356	1.74	0.427	0.032		
	P5																				2.015	1.463	1.067	0.092	0.		
	P95																				4.122	3.137	2.447	0.883	0.221		
CX Recip3	MEAN																				3.056	2.347	1.749	0.425	0.032		
	P5																				2.024	1.463	1.076	0.092	0.		
	P95																				4.14	3.091	2.42	0.883	0.221		
CX Recip4	MEAN																				3.038	2.353	1.741	0.425	0.032		
	P5																				1.969	1.463	1.076	0.083	0.		
	P95																				4.14	3.137	2.447	0.883	0.221		
CX Recip5	MEAN																				3.044	2.35	1.745	0.427	0.032		
	P5																				2.024	1.463	1.076	0.092	0.		
	P95																				4.103	3.11	2.456	0.883	0.221		
CX Recip6	MEAN																				3.043	2.357	1.744	0.423	0.032		
	P5																				2.024	1.463	1.067	0.074	0.		
	P95																				4.103	3.137	2.456	0.883	0.221		
CX Recip7	MEAN																				3.032	2.349	1.745	0.429	0.032		
	P5																				2.024	1.444	1.076	0.092	0.		
	P95																				4.14	3.082	2.456	0.883	0.221		
CX Recip8	MEAN																				2.811	2.171	1.623	0.394	0.03		
	P5																				1.87	1.352	0.995	0.085	0.		
	P95																				3.825	2.873	2.227	0.816	0.204		
CX Recip9	MEAN																				2.812	2.17	1.608	0.394	0.03		
	P5																				1.794	1.352	0.995	0.085	0.		
	P95																				3.825	2.899	2.27	0.816	0.204		
David Gates Generating Station	MEAN	9.12	10.21	15.465	12.547	11.115	14.718	17.744	17.09	12.669	12.285	10.346	10.541	9.12	10.168	16.017	12.785	11.81	14.271	17.015	16.678	13.8	12.441	11.154	10.036	9.12	
	P5	9.12	9.36	12.315	9.85	9.46	11.33	13.615	14.37	9.89	10.06	9.12	10.32	9.12	9.36	13.203	10.338	10.253	11.25	13.635	13.328	10.818	10.01	9.7	9.84	9.12	
	P95	9.12	12.96	18.053	16.188	13.335	18.98	21.603	20.333	16.49	15.21	12.195	11.32	9.12	12.135	18.365	15.725	15.153	17.125	20.773	21.803	16.855	15.223	13.238	10.965	9.12	
FrameCT_ram p_2018	MEAN	0.	0.397	2.472	0.3	0.013	1.03	1.777	3.5	0.954	0.241	0.036	0.019	0.374	2.805	0.269	0.001	0.847	1.829	3.156	1.297	0.358	0.036	0.018			
	P5	0.	0.	0.053	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.33	0.	0.	0.	0.	0.	0.	0.	0.	0.			
	P95	0.	1.839	5.681	1.732	0.	5.457	6.236	7.661	4.048	1.899	0.286	0.171	1.574	5.33	1.266	0.	4.659	6.252	9.368	4.796	2.074	0.158	0.156			
FrameCT_ram p_2020	MEAN	0.	0.387	2.463	0.298	0.013	1.065	1.745	3.423	1.014	0.237	0.033	0.019	0.365	2.811	0.269	0.	0.834	1.818	3.073	1.339	0.336	0.037	0.017			
	P5	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.362	0.	0.	0.	0.	0.	0.	0.	0.	0.			
	P95	0.	1.793	5.555	1.747	0.	5.314	6.225	7.651	4.005	1.64	0.278	0.18	1.493	5.36	1.406	0.	4.505	5.891	9.164	4.806	1.795	0.158	0.156			
FrameCT_ram p_2022	MEAN	0.	0.385	2.468	0.3	0.013	1.039	1.81	3.515	1.02	0.253	0.033	0.018	0.351	2.784	0.27	0.001	0.814	1.83	3.19	1.339	0.354	0.037	0.019			
	P5	0.	0.	0.053	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.343	0.	0.	0.	0.	0.	0.	0.	0.	0.			
	P95	0.	1.839	5.548	1.594	0.	5.137	6.222	7.777	3.879																	

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2026-06	2026-07	2026-08	2026-09	2026-10	2026-11	2026-12	2027	2027-02	2027-03	2027-04	2027-05	2027-06	2027-07	2027-08	2027-09	2027-10	2027-11	2027-12	2028	2028-02	2028-03	2028-04	2028-05	2028-06	
Judith Gap	PS	7.219	5.462	6.322	6.974	12.009	17.957	18.566																			
	P95	15.672	12.406	14.794	14.987	20.384	27.43	27.744																			
	MEAN	0.733	0.477	0.54	0.658	0.831	1.172	1.147	1.524	1.245	0.991	1.101	0.708	0.721	0.473	0.548	0.658	0.874	1.108	1.121	1.405	1.23	0.986	1.179	0.662	0.731	
Musselshell 1	PS	0.503	0.304	0.335	0.436	0.54	0.797	0.743	1.112	0.996	0.718	0.879	0.467	0.531	0.322	0.369	0.494	0.639	0.767	0.771	1.005	0.974	0.679	0.91	0.43	0.522	
	P95	0.954	0.661	0.774	0.867	1.041	1.546	1.502	1.897	1.604	1.259	1.368	0.973	0.959	0.651	0.753	0.868	1.166	1.402	1.55	1.786	1.495	1.361	1.45	0.905	0.982	
	MEAN	0.873	0.575	0.683	0.819	0.964	1.434	1.323	1.689	1.4	1.157	1.324	0.899	0.858	0.571	0.693	0.819	1.012	1.354	1.286	1.555	1.383	1.15	1.113	0.844	0.869	
Musselshell 2	PS	0.612	0.381	0.458	0.566	0.653	1.042	0.925	1.233	1.125	0.866	1.081	0.641	0.628	0.396	0.485	0.626	0.733	0.964	0.934	1.115	1.094	0.8	1.11	0.575	0.638	
	P95	1.14	0.755	0.938	1.074	1.261	1.858	1.696	2.049	1.776	1.481	1.608	1.185	1.127	0.766	0.951	1.085	1.341	1.711	1.643	1.948	1.685	1.543	1.721	1.102	1.156	
	MEAN	0.142	0.152	0.14	0.119	0.062	0.044	0.032	0.046	0.05	0.073	0.099	0.165	0.138	0.151	0.139	0.121	0.075	0.037	0.025	0.039	0.047	0.073	0.123	0.141	0.138	
Ragen Ranch Solar	PS	0.006	0.061	0.026	0.001	0.009	0.013	0.016	0.008	0.012	0.016	0.017	0.044	0.001	0.056	0.028	0.004	0.007	0.008	0.013	0.007	0.008	0.018	0.043	0.037	0.004	
	P95	0.284	0.228	0.214	0.234	0.114	0.092	0.058	0.118	0.116	0.14	0.189	0.288	0.283	0.227	0.212	0.23	0.148	0.085	0.047	0.099	0.111	0.134	0.228	0.256	0.279	
	MEAN	0.09	0.093	0.081	0.069	0.034	0.03	0.019	0.025	0.028	0.048	0.051	0.108	0.087	0.093	0.081	0.067	0.042	0.025	0.014	0.019	0.026	0.049	0.067	0.091	0.087	
River Bend Solar	PS	0.03	0.052	0.03	0.001	0.	0.	0.004	0.	0.	0.001	0.037	0.022	0.05	0.033	0.	0.	0.	0.004	0.	0.	0.	0.	0.005	0.029	0.025	
	P95	0.146	0.131	0.123	0.125	0.075	0.079	0.043	0.068	0.066	0.094	0.092	0.163	0.145	0.13	0.121	0.121	0.091	0.065	0.036	0.053	0.061	0.094	0.115	0.14	0.144	
	MEAN	0.154	0.169	0.142	0.122	0.059	0.053	0.031	0.042	0.047	0.076	0.096	0.178	0.154	0.166	0.141	0.121	0.072	0.043	0.023	0.032	0.044	0.076	0.118	0.153	0.15	
South Mills Solar	PS	0.021	0.075	0.039	0.	0.005	0.014	0.016	0.004	0.007	0.009	0.041	0.022	0.072	0.04	0.	0.003	0.011	0.013	0.002	0.004	0.01	0.021	0.031	0.014	0.014	
	P95	0.275	0.245	0.21	0.228	0.117	0.11	0.053	0.121	0.114	0.145	0.186	0.289	0.27	0.243	0.208	0.227	0.147	0.094	0.043	0.094	0.104	0.149	0.22	0.257	0.274	
	MEAN	2.849	2.831	2.497	3.899	4.624	6.743	7.331	8.089	5.891	5.568	4.38	3.106	2.779	2.86	2.52	3.925	4.862	6.361	7.112	7.7	5.827	5.533	4.7	2.917	2.82	
Spion Kop	PS	1.628	1.628	1.584	2.462	3.111	4.911	5.679	6.631	4.454	4.239	2.962	1.899	1.728	1.941	1.594	2.921	3.496	4.56	5.456	5.852	4.051	4.079	3.096	1.659	1.738	
	P95	3.939	4.055	3.601	5.413	6.076	8.317	8.846	9.624	7.83	6.851	5.882	4.509	3.951	3.995	3.637	5.212	6.415	7.902	8.592	9.171	7.377	7.268	6.275	4.141	4.065	
	MEAN	0.948	0.625	0.637	0.782	1.421	1.795	1.555	2.215	1.311	1.395	1.393	0.553	0.931	0.622	0.647	0.783	1.493	1.699	1.503	2.03	1.297	1.39	1.487	0.514	0.942	
Two Dot Wind	PS	0.685	0.412	0.393	0.52	1.077	1.421	1.104	1.818	1.02	1.074	1.135	0.324	0.696	0.433	0.435	0.595	1.251	1.336	1.132	1.659	0.973	1.003	1.187	0.292	0.722	
	P95	1.182	0.88	0.885	1.007	1.677	2.17	1.937	2.535	1.74	1.707	1.683	0.787	1.215	0.855	0.902	1.004	1.813	2.009	1.889	2.374	1.61	1.771	1.761	0.761	1.203	
	MEAN	44.427	34.642	36.994	44.797	66.031	92.943	93.464	77.713	50.944	48.364	44.052	35.705	32.647	26.111	26.813	33.957	52.293	66.692	67.296	70.972	50.475	48.053	47.88	33.46	33.199	
Wind/Solar Asset - Total	PS	32.307	23.409	25.142	29.94	51.634	76.566	79.06	66.311	42.592	40.16	34.15	26.899	23.856	18.791	18.087	26.506	43.191	55.82	57.571	59.704	40.271	37.48	35.96	25.373	25.78	
	P95	54.854	46	49.432	58.866	77.915	108.546	107.342	87.138	63.907	57.598	55.835	44.764	40.208	33.302	37.006	42.879	62.852	75.8	76.432	80.28	59.796	59.446	59.609	41.047	41.842	
	MEAN	1.632	12.976	23.964	27.979	49.804	66.091	62.899	64.128	18.193	33.065	26.335	19.613	-5.286	-4.814	-11.615	15.826	30.656	39.537	37.199	90.953	49.381	48.064	29.151	2.901	-18.064	
Total	PS	-34.091	-23.728	-8.413	2.536	20.09	32.152	27.213	28.069	-7.808	0.095	-8.953	-21.752	-35.297	-26.43	-22.602	-9.291	3.574	11.69	2.747	50.811	15.145	13.788	-7.735	-22.332	-46.064	
	P95	38.429	51.271	51.631	56.396	83.91	103.689	99.646	99.24	51.328	72.599	69.304	64.535	32.668	43.017	37.052	46.315	58.18	72.688	81.403	158.984	81.702	84.256	69.344	42.55	24.291	
	MEAN																										

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2028-07	2028-08	2028-09	2028-10	2028-11	2028-12	2029	2029-02	2029-03	2029-04	2029-05	2029-06	2029-07	2029-08	2029-09	2029-10	2029-11	2029-12	2030	2030-02	2030-03	2030-04	2030-05	2030-06	2030-07
Basin Creek	MEAN	0.195	0.986	0.282	0.113	0.428	1.266	0.977	0.536	0.432	0.106	0.013	0.268	0.999	0.272	0.131	0.458	1.266	0.99	0.59	0.453	0.128	0.021	0.24	0.0	0.24
	PS	0.	0.112	0.	0.	0.	0.32	0.138	0.011	0.	0.	0.	0.	0.134	0.	0.	0.045	0.279	0.101	0.	0.045	0.	0.	0.	0.	0.
	P95	0.899	2.101	0.967	0.603	1.372	2.978	2.24	1.469	1.209	0.506	0.078	1.172	2.129	1.062	0.655	1.453	3.088	2.381	1.514	1.449	0.476	0.112	0.845	0.	0.845
CELP	MEAN																									
	PS																									
	P95																									
Colstrip 3	MEAN	24.278	26.69	28.099	30.806	30.89	33.987	32.519	28.197	28.652	23.298	1.104	2.774	24.887	27.317	30.422	29.472	31.22	34.143	32.656	28.286	30.467	22.669	17.361	12.67	24.403
	PS	12.594	17.632	19.128	22.333	25.032	27.939	26.666	22.229	21.727	14.11	0.668	1.175	12.53	20.039	20.35	22.771	26.571	27.037	25.619	22.052	23.17	14.517	9.954	8.187	14.977
	P95	34.679	32.425	33.991	35.384	34.833	37.472	35.118	32.521	34.656	32.333	35.852	5.212	34.656	32.333	35.852	33.314	34.886	37.829	36.131	31.619	35.054	29.483	25.707	22.921	33.024
Colstrip 4	MEAN	24.299	26.762	27.789	30.41	31.357	34.313	32.784	28.75	28.628	23.608	17.014	11.789	24.519	27.352	29.908	29.464	31.409	34.366	33.028	28.514	29.981	22.261	17.302	12.753	24.126
	PS	11.195	19.858	18.296	21.498	25.317	28.53	27.629	23.351	21.755	20.756	10.3	8.47	12.755	20.756	21.31	22.155	23.93	27.794	24.511	23.462	14.205	10.433	6.971	13.879	
	P95	34.679	31.928	33.525	35.288	34.821	37.69	35.986	31.582	32.844	30.719	25.619	18.566	34.728	32.345	35.249	33.673	34.778	37.461	36.066	31.622	34.485	29.05	25.694	24.034	33.024
CX FrameCT1	MEAN	0.433	2.644	0.361	0.043	0.668	1.975	3.289	1.105	0.386	0.024	0.016	0.451	2.547	0.307	0.027	0.668	1.913	3.273	1.275	0.43	0.04	0.03	0.001	0.556	
	PS	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.075	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	
	P95	1.9	5.921	2.017	0.061	4.412	6.772	8.296	4.025	2.487	0.171	0.121	1.946	5.479	1.619	0.	3.647	7.591	8.228	4.006	2.533	0.285	0.185	0.	2.037	
CX FrameCT1	MEAN																									
	PS																									
	P95																									
CX Recip1	MEAN	0.329	1.465	1.113	1.647	2.403	3.18	3.139	2.326	1.786	0.381	0.046	0.399	1.416	1.202	1.61	2.423	3.229	3.219	2.351	1.968	0.441	0.055	0.353		
	PS	0.	0.902	0.294	0.672	1.398	2.153	1.564	1.113	0.046	0.	0.	0.	0.708	0.368	0.57	1.509	0.068	0.57	2.282	1.389	1.196	0.046	0.	0.	
	P95	0.948	2.07	1.868	2.797	3.266	4.103	3.965	3.073	2.493	0.837	0.258	1.141	2.015	1.978	2.631	3.349	3.91	4.122	3.22	2.898	0.984	0.258	0.948		
CX Recip10	MEAN	0.299	1.355	1.032	1.524	2.23	2.934	2.905	2.159	1.644	0.352	0.043	0.311	1.316	1.102	1.49	2.247	3.297	2.964	2.181	1.803	0.41	0.053	0.329		
	PS	0.	0.825	0.315	0.621	1.437	2.083	1.998	1.513	1.046	0.034	0.	0.	0.672	0.349	0.527	1.352	2.049	2.108	1.284	1.105	0.051	0.	0.		
	P95	0.876	1.887	1.743	2.584	3.026	3.9	3.604	2.839	2.287	0.782	0.238	1.054	1.87	1.819	2.499	3.094	3.655	3.868	2.967	2.605	0.927	0.238	0.884		
CX Recip2	MEAN	0.326	1.467	1.114	1.643	2.411	3.185	3.146	2.318	1.774	0.378	0.046	0.4	1.414	1.199	1.621	2.442	3.222	3.217	2.342	1.955	0.442	0.056	0.381		
	PS	0.	0.883	0.34	0.708	1.518	2.217	2.144	1.582	1.141	0.046	0.	0.	0.727	0.377	0.57	1.509	2.199	2.254	1.389	1.141	0.055	0.	0.		
	P95	0.938	2.061	1.886	2.76	3.275	4.094	3.965	3.027	2.493	0.837	0.258	1.141	2.024	1.969	2.705	3.349	3.956	3.137	2.87	0.984	0.258	0.975			
CX Recip3	MEAN	0.328	1.466	1.103	1.641	2.412	3.171	3.124	2.332	1.775	0.374	0.046	0.4	1.424	1.198	1.611	2.436	3.226	3.202	2.357	1.967	0.443	0.057	0.356		
	PS	0.	0.929	0.267	0.699	1.527	2.208	2.162	1.582	1.141	0.046	0.	0.	0.727	0.34	0.543	1.509	0.068	0.57	2.254	1.417	1.187	0.046	0.		
	P95	0.948	2.061	1.886	2.797	3.275	4.112	3.892	3.073	2.475	0.837	0.258	1.141	2.033	1.969	2.705	3.294	3.956	4.122	3.22	2.916	1.003	0.258	0.975		
CX Recip4	MEAN	0.324	1.467	1.119	1.647	2.403	3.179	3.134	2.325	1.787	0.374	0.046	0.399	1.418	1.197	1.615	2.442	3.212	3.21	2.364	1.964	0.441	0.056	0.359		
	PS	0.	0.865	0.267	0.708	1.536	2.226	2.162	1.61	1.141	0.046	0.	0.	0.727	0.359	0.57	1.509	2.272	2.254	1.417	1.187	0.046	0.	0.		
	P95	0.948	2.086	1.886	2.797	3.257	4.112	3.965	3.073	2.493	0.846	0.258	1.104	2.024	1.978	2.686	3.321	3.956	4.122	3.22	2.916	1.003	0.258	0.975		
CX Recip5	MEAN	0.329	1.459	1.12	1.653	2.402	3.179	3.128	2.324	1.787	0.377	0.046	0.4	1.419	1.202	1.616	2.444	3.222	3.199	2.35	1.956	0.441	0.056	0.357		
	PS	0.	0.927	0.322	0.708	1.527	2.199	2.162	1.527	1.141	0.046	0.	0.	0.727	0.377	0.57	1.509	2.245	2.272	1.417	1.168	0.055	0.	0.		
	P95	0.948	2.079	1.886	2.751	3.275	4.103	3.965	3.027	2.493	0.846	0.258	1.122	2.006	1.978	2.64	3.34	3.928	4.048	3.128	2.899	1.003	0.258	0.975		
CX Recip6	MEAN	0.323	1.459	1.11	1.646	2.398	3.176	3.131	2.336	1.771	0.382	0.046	0.394	1.423	1.194	1.617	2.429	3.229	3.215	2.356	1.964	0.443	0.056	0.358		
	PS	0.	0.911	0.304	0.672	1.408	2.217	2.162	1.638	1.086	0.046	0.	0.	0.727	0.355	0.57	1.509	0.068	0.57	2.282	1.389	1.196	0.046	0.		
	P95	0.948	2.061	1.877	2.778	3.275	4.112	3.938	3.073	2.484	0.846	0.258	1.095	2.042	1.96	2.705	3.349	3.919	4.076	3.174	2.916	1.003	0.239	0.966		
CX Recip7	MEAN	0.327	1.467	1.117	1.628	2.401	3.181	3.137	2.316	1.768	0.382	0.046	0.4	1.421	1.199	1.611	2.431	3.214	3.206	2.352	1.964	0.441	0.056	0.36		
	PS	0.	0.929	0.313	0.708	1.5	2.254	2.162	1.638	1.132	0.046	0.	0.	0.708	0.377	0.57	1.509	2.226	2.254	1.408	1.168	0.055	0.	0.		
	P95	0.948	2.079	1.886	2.64	3.257	4.112	3.901	3.073	2.466	0.837	0.258	1.141	2.042	1.969	2.64	3.321	3.926	4.066	3.146	2.916	1.003	0.258	0.975		
CX Recip8	MEAN	0.304	1.355	1.032	1.518	2.217	2.943	2.893	2.151	1.638	0.351	0.043	0.364	1.318	1.109	1.49	2.23	2.97	2.96	2.177	1.811	0.404	0.052	0.329		
	PS	0.	0.859	0.315	0.655	1.309	2.074	1.989	1.475	1.052	0.026	0.	0.	0.612	0.349	0.519	1.352	1.998	2.108	1.309	1.105	0.051	0.	0.		
	P95	0.876	1.879	1.743	2.584	3.035	3.766	3.647	2.839	2.304	0.782	0.238	1.037	1.897	1.828	2.499	3.094	3.621	3.757	2.975	2.695	0.984	0.238	0.901		
CX Recip9	MEAN	0.3	1.36	1.029	1.519	2.223	2.948	2.888	2.15	1.641	0.351	0.043	0.37	1.314	1.104	1.493	2.24	2.977	2.961	2.173	1.82	0.406	0.053	0.332		
	PS	0.	0.859	0.289	0.655	1.352	2.091	1.998	1.513	1.054	0.043	0.	0.	0.672	0.315	0.527	1.394	2.032	2.083	1.284	1.105	0.051	0.	0.		
	P95	0.867																								

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2028-07	2028-08	2028-09	2028-10	2028-11	2028-12	2029	2029-02	2029-03	2029-04	2029-05	2029-06	2029-07	2029-08	2029-09	2029-10	2029-11	2029-12	2030	2030-02	2030-03	2030-04	2030-05	2030-06	2030-07
Hauser	P95	21.947	15.44	14.401	14.167	13.449	16.785	16.662	15.045	17.733	18.02	22.673	23.942	25.182	15.594	15.253	12.431	12.944	15.964	16.259	16.28	19.467	18.414	23.682	24.264	22.798
	MEAN	5.319	4.921	4.849	4.889	4.673	5.027	4.724	4.253	4.464	4.739	4.603	4.739	4.531	4.022	5.084	4.655	4.661	5.039	4.47	4.27	4.849	4.551	4.744	4.487	5.074
	PS	5.116	4.698	4.604	4.673	4.456	4.819	4.531	4.046	4.414	4.563	4.493	4.396	5.057	4.744	4.793	4.475	4.408	4.769	4.505	4.558	4.61	4.307	4.505	4.621	4.842
Holter	P95	5.221	5.427	5.032	5.115	4.875	5.279	4.955	4.479	4.811	5.002	4.975	4.984	4.955	5.299	4.95	4.87	5.294	4.376	4.558	5.099	4.999	4.999	4.999	4.999	5.062
	MEAN	11.798	9.261	9.147	9.147	9.324	9.35	11.079	12.057	11.1	10.479	11.475	11.805	9.248	9.639	9.818	9.792	11.079	10.454	9.29	10.454	10.564	12.052	12.052	11.251	
	PS	10.114	7.624	7.481	7.822	8.092	9.548	8.838	7.89	8.446	9.568	9.899	9.509	9.806	7.871	7.9	7.672	8.057	9.263	8.826	7.926	8.967	8.878	10.138	10.045	9.429
Madison	P95	13.653	10.811	10.993	11.452	11.659	13.013	12.445	10.988	12.019	12.916	14.038	13.529	14.24	10.906	11.358	10.66	11.626	12.894	12.404	11.27	12.546	12.417	14.645	14.398	13.568
	MEAN	2.627	2.304	2.251	2.415	2.383	2.545	2.45	2.204	2.404	2.324	2.442	2.277	2.624	2.304	2.364	2.302	2.378	2.546	2.442	2.214	2.527	2.202	2.442	2.4	
	PS	2.47	2.144	2.1	2.258	2.247	2.324	2.089	2.275	2.181	2.286	2.132	2.43	2.304	2.208	2.182	2.312	2.208	2.376	2.312	2.087	2.374	2.054	2.202	2.247	
Morony	P95	2.785	2.446	2.373	2.586	2.526	2.719	2.579	2.325	2.548	2.437	2.595	2.411	2.807	2.429	2.511	2.445	2.526	2.709	2.587	2.358	2.683	2.351	2.619	2.553	
	MEAN	11.489	8.896	8.656	9.037	8.941	9.887	9.702	8.888	8.783	9.702	11.677	11.677	11.677	11.677	11.677	11.677	11.677	11.677	11.677	11.677	11.677	11.677	11.677	11.677	
	PS	9.655	6.766	6.759	7.292	7.172	8.077	7.789	7.004	7.331	8.395	9.22	9.325	9.051	7.288	7.121	7.235	7.059	7.511	7.657	6.829	7.859	7.715	9.636	9.788	
Mystic	P95	13.74	10.942	10.379	11.275	10.75	12.057	11.831	10.12	11.001	12.225	15.002	14.031	14.281	10.711	11.197	10.396	10.967	12.199	11.753	10.629	11.779	11.929	15.274	14.833	
	MEAN	3.795	2.968	2.038	1.609	1.515	1.589	1.396	1.114	0.907	0.586	1.187	2.273	3.788	2.982	2.151	1.53	1.508	1.602	1.386	1.138	0.973	0.551	1.188	2.41	
	PS	3.577	2.339	1.663	1.213	1.164	1.131	1.008	0.849	0.747	0.599	1.01	1.935	3.485	2.441	1.715	1.239	1.152	1.089	0.837	0.776	0.476	1.033	2.049		
Rainbow	P95	4.026	3.579	2.406	2.095	1.872	2.155	1.9	1.43	1.119	0.66	1.348	2.667	4.046	3.579	2.555	1.957	1.906	2.196	1.868	1.569	1.241	0.63	1.388	2.751	
	MEAN	15.227	12.204	11.058	11.649	11.537	13.052	12.43	11.26	12.845	16.913	17.127	16.576	15.265	12.157	11.707	11.127	11.559	13.047	13.077	13.377	14.663	14.027	17.09	17.482	
	PS	8.639	5.853	5.355	5.196	4.953	6.787	5.671	5.588	6.787	5.671	5.588	6.787	5.671	5.588	6.787	5.671	5.588	6.787	5.671	5.588	6.787	5.671	5.588	6.787	
Ryan	P95	25.182	21.414	18.42	23.418	21.016	21.333	22.624	20.229	23.345	23.213	29.815	29.589	29.399	22.278	20.464	20.743	18.896	21.285	23.658	21.389	26.718	24.17	30.571	29.552	
	MEAN	17.418	14.603	14.449	15.075	15.062	15.429	13.648	15.429	13.648	15.355	16.718	17.552	17.136	15.778	15.752	14.733	14.993	15.276	16.123	16.123	16.123	16.123	16.123	16.123	
	PS	16.03	12.871	12.774	13.574	13.672	14.464	13.444	12.314	13.43	14.759	17.08	16.016	15.498	13.333	13.362	13.314	13.406	14.066	13.128	12.304	14.025	13.623	17.07	16.89	
Sleeping Giant	P95	19.024	16.147	15.765	16.664	17.008	16.664	17.775	17.407	18.884	20.316	18.884	20.316	18.884	20.316	18.884	20.316	18.884	20.316	18.884	20.316	18.884	20.316	18.884	20.316	
	MEAN	2.748	2.491	2.547	0.63	0.643	0.323	0.279	0.409	1.047	2.555	2.621	2.428	2.749	2.493	2.67	0.6	0.643	0.323	0.279	0.41	1.1	2.427	2.621		
	PS	2.714	2.456	2.503	0.632	0.631	0.319	0.268	0.404	1.035	2.528	2.589	2.403	2.721	2.461	2.621	0.594	0.631	0.32	0.267	0.404	1.085	2.589	2.524		
Thompson Falls	P95	2.781	2.152	2.576	0.638	0.638	0.327	0.293	0.415	1.06	2.583	2.646	2.453	2.779	2.521	2.708	0.607	0.656	0.328	0.292	0.415	1.115	2.461	2.589		
	MEAN	25.812	14.156	12.357	14.469	16.214	19.404	17.442	15.652	16.764	23.553	27.015	24.68	25.789	14.128	13.019	13.805	16.23	19.402	17.371	15.786	17.596	22.306	29.98		
	PS	20.665	10.685	11.155	12.965	14.965	15.708	13.749	12.656	13.423	18.973	19.91	19.072	19.848	11.17	9.848	11.243	12.249	14.895	13.698	12.875	14.349	17.412	20.903		
Hydro - Total	P95	31.858	17.562	15.448	18.649	20.347	23.857	21.688	19.595	21.233	28.227	33.116	30.763	32.757	17.888	16.344	17.368	20.125	23.626	21.37	20.163	22.319	27.073	33.782		
	MEAN	113.658	85.833	80.055	80.713	83.4	93.317	88.068	84.772	87.712	118.24	113.043	113.652	85.681	84.426	77.064	83.33	93.279	87.508	79.532	92.064	118.126	119.245	108.363		
	PS	87.898	63.998	59.68	61.283	62.277	72.938	65.553	61.703	66.993	80.269	85.511	82.907	83.245	66.333	63.485	61.643	61.379	69.643	65.245	60.975	71.788	73.413	88.314		
Load	P95	146.333	110.645	102.658	113.501	109.394	117.622	104.297	120.042	130.11	153.545	150.402	111.084	109.91	102.388	106.894	119.229	117.161	109.94	127.791	127.221	153.825	153.882	148.271		
	MEAN	-241.07	-207.989	-203.264	-210.18	-230.584	-272.473	-233.867	-242.532	-213.245	-213.46	-207.634	-201.147	-242.497	-211.627	-218.708	-200.846	-233.216	-276.913	-237.863	-227.993	-229.334	-203.171	-210.334		
	PS	-248.782	-212.794	-207.098	-215.561	-236.639	-282.999	-251.189	-224.663	-219.772	-219.031	-212.115	-203.559	-250.798	-217.431	-223.128	-205.192	-239.415	-285.945	-253.082	-235.434	-237.495	-208.024	-215.117		
Small QF1	P95	0.01	0.009	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01		
	MEAN	0.01	0.009	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01		
	PS	0.01	0.009	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01		
Small Tier II	P95	0.095	0.095	0.092	0.066	0.048	0.012	0.011	0.019	0.054	0.066	0.094	0.095	0.095	0.095	0.097	0.063	0.048	0.012	0.012	0.012	0.011	0.02	0.051		
	MEAN	0.095	0.095	0.092	0.066	0.048	0.012	0.011	0.019	0.054	0.066	0.094	0.095	0.095	0.097	0.063	0.048	0.012	0.012	0.012	0.011	0.02	0.051			
	PS	0.095	0.095	0.092	0.066	0.048	0.012	0.011	0.019	0.054	0.066	0.094	0.095	0.095	0.097	0.063	0.048	0.012	0.012	0.012	0.011	0.02	0.051			
Turnbull	P95	4.411	2.985	1.106	0.014	0.014	0.005	1.618	3.401	4.411	2.985	1.161	0.013	0.005	1.618	3.401	4.411	2.985	1.161	0.013	0.005	1.618	3.58	4.206		
	MEAN	4.411	2.985	1.106	0.014	0.014	0.005	1.618	3.401	4.411	2.985	1.161	0.013	0.005	1.618	3.401	4.411	2.985	1.161	0.013	0.005	1.618	3.58	4.206		
	PS	4.411	2.985	1.106	0.014	0.014	0.005	1.618	3.401	4.411	2.985	1.161	0.013	0.005	1.618	3.401	4.411	2.985								

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2028-07	2028-08	2028-09	2028-10	2028-11	2028-12	2029	2029-02	2029-03	2029-04	2029-05	2029-06	2029-07	2029-08	2029-09	2029-10	2029-11	2029-12	2030	2030-02	2030-03	2030-04	2030-05	2030-06	2030-07		
Judith Gap	PS																											
	P95																											
	MEAN	0.54	0.51	0.652	0.877	1.119	1.222	1.446	1.26	1.002	1.169	0.659	0.741	0.54	0.504	0.695	0.834	1.123	1.237	1.478	1.256	1.052	1.094	0.671	0.782	0.503		
Musselshell 1	PS	0.382	0.346	0.462	0.596	0.855	0.852	1.062	0.977	0.686	0.917	0.452	0.536	0.353	0.336	0.517	0.575	0.851	0.883	1.128	0.995	0.725	0.881	0.469	0.549	0.333		
	P95	0.709	0.7	0.898	1.12	1.462	1.694	1.83	1.523	1.276	1.426	0.918	0.97	0.749	0.744	0.911	1.165	1.538	1.614	1.878	1.466	1.396	1.341	0.866	1.012	0.736		
	MEAN	0.65	0.648	0.811	1.015	1.369	1.404	1.601	1.416	1.165	1.402	0.84	0.882	0.65	0.64	0.864	0.967	1.372	1.419	1.641	1.414	1.225	1.318	0.854	0.928	0.605		
Musselshell 2	PS	0.471	0.451	0.582	0.705	1.066	1.021	1.158	1.127	0.813	1.103	0.604	0.638	0.427	0.432	0.655	0.648	1.055	1.065	1.235	1.134	0.847	1.068	0.629	0.646	0.41		
	P95	0.857	0.888	1.108	1.288	1.739	1.82	2.04	1.704	1.47	1.684	1.123	1.149	0.889	0.917	1.128	1.303	1.81	1.797	2.083	1.649	1.603	1.584	1.199	1.227	0.864		
	MEAN	0.205	0.114	0.116	0.076	0.037	0.038	0.052	0.072	0.122	0.14	0.138	0.202	0.113	0.138	0.06	0.038	0.039	0.039	0.051	0.091	0.098	0.141	0.161	0.176	0.176		
Rageni Ranch Solar	PS	0.079	0.026	0.001	0.01	0.007	0.018	0.006	0.01	0.013	0.037	0.036	0.005	0.066	0.027	0.003	0.006	0.007	0.02	0.007	0.007	0.017	0.021	0.04	0.002	0.061		
	P95	0.297	0.174	0.224	0.152	0.094	0.071	0.093	0.117	0.13	0.219	0.257	0.276	0.304	0.174	0.265	0.115	0.098	0.069	0.097	0.104	0.169	0.192	0.256	0.314	0.265		
	MEAN	0.128	0.065	0.067	0.042	0.025	0.023	0.02	0.028	0.046	0.067	0.091	0.089	0.128	0.064	0.08	0.033	0.025	0.023	0.02	0.027	0.058	0.052	0.091	0.102	0.11		
River Bend Solar	PS	0.075	0.026	0.	0.	0.	0.006	0.	0.	0.	0.004	0.033	0.029	0.075	0.021	0.001	0.	0.	0.006	0.001	0.	0.	0.001	0.031	0.028	0.062		
	P95	0.175	0.097	0.122	0.092	0.063	0.054	0.051	0.065	0.091	0.114	0.138	0.14	0.178	0.1	0.149	0.071	0.067	0.053	0.057	0.062	0.11	0.091	0.14	0.167	0.153		
	MEAN	0.222	0.112	0.119	0.072	0.044	0.038	0.035	0.048	0.074	0.119	0.151	0.122	0.114	0.14	0.057	0.044	0.039	0.036	0.047	0.094	0.095	0.152	0.175	0.192	0.192		
South Mills Solar	PS	0.095	0.026	0.	0.004	0.009	0.017	0.003	0.006	0.008	0.016	0.03	0.013	0.087	0.028	0.002	0.005	0.01	0.019	0.004	0.004	0.01	0.016	0.031	0.026	0.077		
	P95	0.315	0.169	0.229	0.151	0.101	0.067	0.091	0.119	0.14	0.219	0.257	0.266	0.321	0.17	0.261	0.116	0.107	0.064	0.101	0.109	0.172	0.186	0.258	0.304	0.283		
	MEAN	3.203	2.345	3.874	4.927	6.434	7.742	7.663	5.959	5.563	4.63	2.871	2.851	3.187	2.298	4.085	4.615	6.438	7.806	7.857	5.975	5.875	4.339	2.911	3.051	3.012		
Spion Kop	PS	2.088	1.543	2.675	3.419	4.984	5.833	6.002	4.446	4.171	3.117	1.799	1.84	1.655	1.599	2.89	2.915	4.877	6.292	6.434	4.432	4.103	2.918	1.722	1.873	1.762		
	P95	4.397	3.374	5.52	6.299	8.036	9.438	9.128	7.467	6.883	6.136	4.215	4.154	4.471	3.421	5.42	6.423	8.286	9.703	9.561	7.497	7.492	5.753	4.367	4.214	4.637		
	MEAN	0.706	0.599	0.778	1.498	1.712	1.637	2.101	1.328	1.404	1.478	0.506	0.953	0.704	0.589	0.825	1.423	1.713	1.653	2.133	1.324	1.471	1.389	0.52	1.008	0.66		
Two Dot Wind	PS	0.519	0.41	0.538	1.176	1.442	1.218	1.724	1.02	1.033	1.217	0.307	0.733	0.472	0.406	0.62	1.134	1.412	1.277	1.768	1.038	1.092	1.146	0.311	0.732	0.435		
	P95	0.903	0.855	1.051	1.747	2.053	2.043	2.496	1.607	1.712	1.759	0.751	1.232	0.943	0.834	1.077	1.749	2.128	2.079	2.54	1.566	1.832	1.657	0.792	1.32	0.949		
	MEAN	29.874	24.855	33.682	52.551	67.14	74.045	74.08	51.412	48.79	47.365	33.219	29.955	24.486	35.802	49.538	67.159	74.409	74.822	51.391	51.458	44.41	33.577	35.711	28.037	28.037		
Wind/Solar Asset - Total	PS	21.637	18.08	25.244	42.118	58.794	63.446	63.852	41.274	39.558	35.437	26.36	23.757	20.661	17.805	26.763	38.851	58.513	66.307	64.09	43.167	39.336	34.833	25.375	25.201	18.801		
	P95	38.269	33.323	44.742	61.294	75.736	84.802	84.531	61.315	57.679	58.018	41.107	43.299	40.703	34.027	46.13	60.342	78.522	83.809	86.791	59.014	62.434	53.306	42.954	45.689	38.987		
	MEAN	-5.274	27.024	22.235	43.369	59.954	65.473	82.878	23.692	30.259	6.432	-15.617	-18.673	-14.527	15.052	5.879	29.16	42.301	45.467	80.209	22.449	28.474	7.188	-1.36	-15.355	-13.861		
Total	PS	-36.675	-9.084	-10.906	13.345	21.351	26.97	32.292	-8.982	-0.231	-26.015	-48.996	-52.73	-54.8	-24.91	-27.478	3.698	3.259	3.017	33.995	-7.394	-2.68	-24.165	-44.04	-48.516	-60.762		
	P95	32.632	67.601	60.177	80.512	100.545	115.364	134.212	69.122	62.614	42.59	22.212	19.554	33.569	53.127	37.434	53.914	84.777	94.59	136.1	60.141	67.184	44.518	43.758	28.851	35.227		
	MEAN																											

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2030-08	2030-09	2030-10	2030-11	2030-12	2031	2031-02	2031-03	2031-04	2031-05	2031-06	2031-07	2031-08	2031-09	2031-10	2031-11	2031-12	2032	2032-02	2032-03	2032-04	2032-05	2032-06	2032-07	2032-08	
Basin Creek	MEAN	1.036	0.277	0.111	0.498	1.363	1.019	0.569	0.446	0.172	0.016	0.199	1.086	0.392	0.118	0.539	1.443	1.024	0.724	0.463	0.188	0.024	0.21	1.304	0.21	1.304	
	PS	0.246	0.	0.	0.011	0.328	0.123	0.	0.	0.	0.	0.	0.101	0.	0.	0.045	0.123	0.045	0.034	0.	0.	0.	0.	0.	0.	0.067	0.
	P95	2.118	0.965	0.443	1.504	3.072	2.448	1.83	1.258	0.703	0.112	0.802	2.547	1.554	0.559	1.615	3.981	2.405	1.691	1.273	0.788	0.134	0.93	2.994	0.93	2.994	
CELP	MEAN																										
	PS																										
	P95																										
Colstrip 3	MEAN	27.6	30.076	29.541	31.346	34.101	32.736	28.743	30.636	22.869	17.867	12.911	24.349	29.128	28.843	29.977	32.772	32.644	32.581	30.396	29.04	22.633	5.747	3.468	23.779	28.877	
	PS	21.438	19.981	22.545	25.977	27.899	25.576	22.01	24.403	15.385	11.122	8.304	13.954	20.97	21.458	22.678	26.182	25.666	25.011	24.188	21.836	13.809	3.082	1.694	13.392	20.448	
	P95	32.46	35.632	33.612	34.746	37.454	36.111	31.37	35.165	29.225	25.765	23.429	33.137	34.196	33.563	33.834	36.784	35.849	36.224	34.27	33.326	33.622	8.878	7.034	31.621	34.287	
Colstrip 4	MEAN	27.329	30.038	29.807	31.805	34.367	33.24	29.175	30.347	22.302	4.802	3.193	24.048	29.295	28.82	30.149	33.071	32.702	33.197	30.96	28.829	22.541	18.86	13.143	23.14	29.023	
	PS	19.991	21.612	24.26	26.438	29.377	27.774	25.479	23.264	13.833	2.635	2.06	14.255	22.174	22.141	25.017	26.561	27.216	25.876	23.686	22.033	13.441	9.582	7.604	13.378	22.592	
	P95	32.447	35.439	33.553	34.757	37.454	36.152	31.631	35.047	29.062	7.574	5.939	33.06	34.325	33.796	33.89	36.784	35.751	36.264	34.259	33.418	29.937	27.932	23.818	31.536	34.688	
CX FrameCT1	MEAN	2.706	0.268	0.037	0.797	2.227	3.579	1.443	0.409	0.09	0.026	0.	0.437	2.551	0.455	0.	0.825	2.54	3.395	1.565	0.337	0.13	0.027	0.004	0.545	2.913	
	PS	0.171	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.053	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	
	P95	6.269	1.933	0.	3.761	7.841	9.118	5.515	2.528	0.677	0.208	0.	1.567	5.85	3.096	0.	4.611	8.707	8.291	5.492	2.078	0.818	0.202	0.045	1.778	6.54	
CX FrameCT1	MEAN	2.667	0.254	0.016	0.819	2.323	3.617	1.479	0.432	0.08	0.023	0.	0.449	2.501	0.463	0.	0.814	2.6	3.399	1.552	0.345	0.098	0.024	0.004	0.554	2.944	
	PS	0.11	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.053	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	
	P95	6.344	1.728	0.	3.761	7.016	9.188	5.413	2.528	0.61	0.179	0.	1.596	5.801	3.177	0.	3.68	8.879	8.277	5.195	1.977	0.503	0.186	0.045	1.955	6.741	
CX Recip1	MEAN	1.495	1.281	1.754	2.513	3.35	3.269	2.436	1.975	0.472	0.038	0.347	1.589	1.274	1.764	2.699	3.259	3.359	2.664	1.943	0.527	0.057	0.365	1.671	0.365	1.671	
	PS	0.938	0.552	0.644	1.444	2.162	2.282	1.178	0.428	0.	0.	0.8	0.34	0.718	1.546	2.208	2.585	1.702	1.15	0.064	0.	0.	0.	0.	0.	0.1095	
	P95	2.217	2.07	2.769	3.551	4.342	4.204	3.468	2.714	1.012	0.166	0.957	2.447	2.328	2.815	3.956	4.158	4.177	3.422	2.723	1.095	0.258	0.938	2.254	0.938	2.254	
CX Recip10	MEAN	1.373	1.166	1.619	2.323	3.099	3.027	2.258	1.833	0.316	0.036	0.316	1.636	1.243	1.776	2.694	3.264	3.364	2.589	1.957	0.526	0.057	0.368	1.658	0.368	1.658	
	PS	0.833	0.51	0.604	1.335	1.998	2.108	1.488	0.663	0.034	0.	0.	0.774	0.349	0.638	1.513	2.04	2.355	1.556	1.063	0.06	0.	0.	0.	0.	0.102	
	P95	2.022	1.913	2.593	3.273	3.885	3.895	3.196	2.465	0.935	0.153	0.893	2.261	2.023	2.652	3.655	3.859	3.935	3.205	2.567	1.139	0.064	0.938	2.254	0.938	2.254	
CX Recip2	MEAN	1.48	1.279	1.751	2.527	3.367	3.276	2.45	1.984	0.468	0.038	0.347	1.578	1.282	1.767	2.683	3.274	3.373	2.672	1.947	0.521	0.057	0.366	1.649	0.366	1.649	
	PS	0.938	0.552	0.635	1.444	2.19	2.282	1.582	1.178	0.046	0.	0.	0.773	0.414	0.653	1.61	2.245	2.613	1.684	1.15	0.064	0.	0.	0.	0.	0.1104	
	P95	2.162	2.07	2.769	3.56	4.342	4.204	3.468	2.64	1.012	0.166	0.966	2.447	2.392	2.788	3.938	4.177	4.26	3.422	2.705	1.076	0.258	0.938	2.254	0.938	2.254	
CX Recip3	MEAN	1.487	1.279	1.752	2.519	3.364	3.259	2.445	1.978	0.47	0.038	0.346	1.589	1.288	1.758	2.683	3.281	3.372	2.682	1.952	0.528	0.057	0.367	1.659	0.367	1.659	
	PS	0.929	0.543	0.635	1.444	2.19	2.282	1.582	1.178	0.028	0.	0.81	0.414	0.639	1.638	2.245	2.539	1.766	1.113	0.064	0.	0.	0.	0.	0.	0.1021	
	P95	2.171	2.07	2.806	3.56	4.342	4.158	3.468	2.742	1.012	0.166	0.966	2.42	2.392	2.852	3.827	4.168	4.26	3.496	2.686	1.067	0.258	0.938	2.254	0.938	2.254	
CX Recip4	MEAN	1.479	1.274	1.758	2.512	3.349	3.257	2.442	1.98	0.447	0.038	0.345	1.586	1.29	1.772	2.694	3.276	3.372	2.692	1.956	0.526	0.057	0.367	1.664	0.367	1.664	
	PS	0.902	0.543	0.653	1.435	2.162	2.282	1.628	1.178	0.046	0.	0.837	0.414	0.718	1.582	2.245	2.585	1.766	1.15	0.064	0.	0.	0.	0.	0.	0.1104	
	P95	2.18	2.07	2.806	3.56	4.342	4.204	3.432	2.76	1.046	0.166	0.966	2.427	2.392	2.87	3.892	4.149	4.25	3.367	2.723	1.049	0.258	0.938	2.254	0.938	2.254	
CX Recip5	MEAN	1.492	1.28	1.752	2.529	3.353	3.27	2.433	1.991	0.471	0.038	0.346	1.586	1.273	1.776	2.694	3.264	3.364	2.689	1.957	0.526	0.057	0.368	1.658	0.368	1.658	
	PS	0.911	0.552	0.653	1.426	2.18	2.282	1.628	1.178	0.046	0.	0.837	0.396	0.699	1.536	2.208	2.567	1.739	1.122	0.064	0.	0.	0.	0.	0.	0.1104	
	P95	2.217	2.07	2.732	3.579	4.25	4.204	3.441	2.769	1.012	0.166	0.957	2.447	2.328	2.87	3.956	4.177	4.186	3.441	2.723	1.086	0.258	0.938	2.254	0.938	2.254	
CX Recip6	MEAN	1.482	1.28	1.745	2.523	3.361	3.265	2.448	1.984	0.469	0.038	0.348	1.58	1.285	1.775	2.685	3.267	3.364	2.692	1.956	0.526	0.057	0.367	1.669	0.367	1.669	
	PS	0.938	0.552	0.653	1.408	2.19	2.282	1.582	1.159	0.046	0.	0.828	0.414	0.708	1.638	2.245	2.622	1.766	1.113	0.064	0.	0.	0.	0.	0.	0.1095	
	P95	2.19	2.07	2.778	3.579	4.315	4.177	3.468	2.677	0.994	0.166	0.957	2.447	2.309	2.852	3.956	4.177	4.204	3.34	2.714	1.095	0.258	0.938	2.236	0.938	2.236	
CX Recip7	MEAN	1.489	1.274	1.752	2.513	3.364	3.255	2.444	1.989	0.47	0.038	0.343	1.592	1.289	1.767	2.683	3.245	3.357	2.689	1.952	0.53	0.057	0.368	1.674	0.368	1.674	
	PS	0.938	0.552	0.653	1.444	2.19	2.217	1.628	1.178	0.046	0.	0.837	0.414	0.718	1.61	2.199	2.594	1.766	1.15	0.064	0.	0.	0.	0.	0.	0.1104	
	P95	2.171	2.052	2.788	3.57	4.342	4.14	3.441	2.769	1.003	0.166	0.966	2.427	2.392	2.87	3.947	4.177	4.204	3.496	2.714	1.095	0.258	0.929	2.236	0.929	2.236	
CX Recip8	MEAN	1.367	1.185	1.612	2.324	3.1	3.017	2.26	1.821	0.438	0.036	0.321	1.467	1.19	1.643	2.49	3.011	3.105	2.478	1.8	0.49	0.053	0.338	1.539	0.338	1.539	
	PS	0.859	0.51	0.604	1.326	2.023	2.049	1.505	1.071	0.043	0.	0.774	0.383	0.638	1.479												

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2030-08	2030-09	2030-10	2030-11	2030-12	2031	2031-02	2031-03	2031-04	2031-05	2031-06	2031-07	2031-08	2031-09	2031-10	2031-11	2031-12	2032	2032-02	2032-03	2032-04	2032-05	2032-06	2032-07	2032-08		
Judith Gap	PS																											
	P95																											
	MEAN	0.508	0.696	0.835	1.123	1.214	1.472	1.259	1.038	1.116	0.657	0.78	0.494	0.535	0.668	0.828	1.157	1.167	1.484	1.319	1.006	1.111	0.697	0.735	0.481	0.526		
Musselshell 1	PS	0.345	0.51	0.594	0.826	0.828	1.095	1.012	0.739	0.87	0.441	0.576	0.327	0.351	0.483	0.558	0.862	0.724	1.176	1.053	0.712	0.866	0.461	0.566	0.311	0.366		
	P95	0.71	0.932	1.128	1.481	1.56	1.833	1.519	1.318	1.357	0.912	1.03	0.677	0.697	0.909	1.131	1.587	1.692	1.892	1.613	1.309	1.375	0.94	0.97	0.656	0.692		
	MEAN	0.645	0.864	0.968	1.372	1.396	1.634	1.417	1.212	1.339	0.837	0.928	0.596	0.68	0.829	0.96	1.416	1.341	1.643	1.482	1.17	1.333	0.888	0.877	0.579	0.567		
Musselshell 2	PS	0.447	0.638	0.696	1.03	0.997	1.22	1.148	0.874	1.063	0.578	0.687	0.417	0.456	0.619	0.639	1.092	0.906	1.234	1.185	0.849	1.053	0.621	0.679	0.383	0.465		
	P95	0.883	1.14	1.31	1.763	1.731	2.028	1.718	1.529	1.65	1.132	1.212	0.786	0.896	1.127	1.309	1.906	1.865	2.082	1.808	1.515	1.631	1.148	1.134	0.787	0.856		
	MEAN	0.113	0.135	0.06	0.038	0.038	0.039	0.051	0.09	0.101	0.139	0.157	0.173	0.136	0.116	0.059	0.043	0.03	0.037	0.06	0.072	0.096	0.161	0.135	0.145	0.132		
Ragen Ranch Solar	PS	0.021	0.002	0.004	0.01	0.018	0.005	0.009	0.025	0.024	0.033	0.001	0.047	0.024	0.001	0.005	0.009	0.015	0.005	0.011	0.015	0.032	0.043	0.	0.049	0.015		
	P95	0.175	0.262	0.116	0.091	0.069	0.093	0.113	0.163	0.19	0.256	0.311	0.267	0.211	0.226	0.118	0.109	0.058	0.084	0.147	0.142	0.191	0.289	0.273	0.222	0.211		
	MEAN	0.064	0.078	0.034	0.025	0.023	0.02	0.027	0.056	0.054	0.089	0.102	0.109	0.079	0.067	0.033	0.029	0.018	0.019	0.033	0.048	0.051	0.105	0.086	0.09	0.08		
River Bend Solar	PS	0.024	0.001	0.	0.	0.006	0.001	0.	0.	0.004	0.026	0.031	0.062	0.032	0.001	0.	0.	0.005	0.	0.	0.002	0.037	0.024	0.052	0.035	0.035		
	P95	0.097	0.141	0.073	0.066	0.052	0.054	0.064	0.11	0.092	0.139	0.165	0.152	0.12	0.122	0.072	0.073	0.042	0.052	0.08	0.094	0.09	0.161	0.14	0.126	0.119		
	MEAN	0.115	0.139	0.058	0.043	0.037	0.036	0.047	0.093	0.098	0.149	0.171	0.19	0.137	0.119	0.057	0.05	0.03	0.033	0.056	0.075	0.093	0.172	0.144	0.16	0.134		
South Mills Solar	PS	0.031	0.	0.004	0.01	0.017	0.003	0.005	0.016	0.009	0.024	0.007	0.068	0.03	0.001	0.002	0.011	0.014	0.002	0.006	0.009	0.016	0.037	0.001	0.062	0.024		
	P95	0.169	0.26	0.118	0.098	0.066	0.094	0.114	0.174	0.186	0.257	0.305	0.285	0.208	0.224	0.12	0.112	0.057	0.09	0.15	0.148	0.184	0.29	0.265	0.241	0.208		
	MEAN	2.333	4.119	4.609	6.455	7.713	7.82	5.964	5.833	4.429	2.873	3.034	2.975	2.474	3.952	4.589	6.647	7.415	7.815	6.24	5.647	4.404	3.036	2.854	2.901	2.43		
Spion Kop	PS	1.553	2.877	3.118	5.02	5.975	6.299	4.375	4.456	2.968	1.574	1.952	1.974	1.552	2.886	3.21	5.053	5.615	6.308	4.56	4.184	3.048	1.677	1.927	1.836	1.595		
	P95	3.137	5.696	6.143	8.039	9.363	9.279	7.525	7.293	6.088	4.158	4.307	3.967	3.448	5.453	6.13	8.586	9.723	9.402	7.877	7.001	5.982	4.385	3.941	3.955	3.354		
	MEAN	0.596	0.829	1.423	1.715	1.628	2.133	1.329	1.461	1.411	0.508	1.006	0.649	0.63	0.795	1.416	1.781	1.569	2.136	1.388	1.406	1.406	0.536	0.95	0.632	0.618		
Two Dot Wind	PS	0.426	0.608	1.14	1.402	1.242	1.781	1.06	1.123	1.121	0.302	0.741	0.458	0.42	0.566	1.123	1.491	1.134	1.757	1.049	1.11	1.129	0.308	0.75	0.421	0.431		
	P95	0.802	1.083	1.755	2.05	1.975	2.461	1.603	1.783	1.695	0.775	1.277	0.885	0.827	1.077	1.753	2.19	2.115	2.503	1.739	1.787	1.682	0.777	1.223	0.879	0.808		
	MEAN	24.862	36.063	49.654	67.359	73.937	74.822	51.841	51.483	44.859	33.262	35.615	27.867	26.556	34.332	49.604	70.126	70.741	74.826	53.907	48.696	44.643	35.507	33.222	26.562	26.227		
Wind/Solar Asset - Total	PS	17.579	26.779	39.513	58.969	63.204	65.987	40.642	41.913	33.856	24.241	25.552	20.	19.097	26.532	39.942	59.903	62.583	64.737	43.971	39.209	35.092	26.12	26.731	18.351	18.397		
	P95	32.172	46.873	60.894	76.278	83.788	83.363	60.331	61.556	55.372	41.114	46.451	34.962	35.124	44.681	60.194	81.485	82.064	83.983	62.972	59.668	55.849	44.473	42.024	34.103	34.538		
	MEAN	13.277	3.724	28.455	42.453	46.631	80.998	21.874	26.772	6.068	-17.309	-27.712	-16.837	8.546	5.584	26.933	38.263	45.63	76.985	27.347	24.856	4.39	-22.083	-27.295	-13.322	8.998		
Total	PS	-23.258	-28.54	1.037	11.959	6.879	30.159	-10.894	-7.353	-32.467	-56.949	-61.545	-54.595	-29.636	-25.396	-2.532	2.019	-10.038	28.882	-9.516	-10.543	-30.804	-56.618	-57.199	-48.601	-31.929		
	P95	56.709	35.482	65.447	72.076	100.189	137.579	62.212	62.547	40.342	21.389	15.27	33.885	54.295	45.489	63.021	80.613	109.41	143.772	67.685	55.531	45.429	24.681	12.619	21.738	49.634		

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2032-09	2032-10	2032-11	2032-12	2033	2033-02	2033-03	2033-04	2033-05	2033-06	2033-07	2033-08	2033-09	2033-10	2033-11	2033-12	2034	2034-02	2034-03	2034-04	2034-05	2034-06	2034-07	2034-08	2034-09	
Basin Creek	MEAN	0.385	0.145	0.596	1.284	0.978	0.644	0.467	0.186	0.025	0.311	1.187	0.357	0.127	0.588	1.381	1.073	0.65	0.468	0.169	0.015	0.289	1.178	0.463			
	PS	0.	0.	0.	0.179	0.089	0.022	0.022	0.	0.	0.235	0.	0.	0.235	0.	0.168	0.156	0.011	0.	0.	0.	0.	0.	0.201	0.		
	P95	1.497	0.808	1.828	3.266	2.637	1.722	1.252	0.674	0.123	1.131	2.341	1.095	0.458	1.487	3.058	2.521	1.715	1.244	0.631	0.123	0.982	2.714	1.84			
CELP	MEAN																										
	PS																										
	P95																										
Colstrip 3	MEAN	29.31	31.641	31.68	31.231	32.703	28.958	29.316	23.725	19.221	12.997	26.401	28.136	29.283	31.771	31.068	31.329	33.015	28.709	29.496	24.889	18.811	13.543	26.824	28.107	29.346	
	PS	20.487	22.416	25.754	25.012	25.42	23.552	20.578	14.365	11.666	8.732	14.257	21.439	21.224	25.63	25.401	25.644	26.574	22.127	21.669	16.357	10.807	7.717	17.45	20.619	21.29	
	P95	34.094	35.914	34.932	34.225	36.282	31.869	33.476	30.066	28.301	23.299	34.764	32.728	33.775	35.678	34.928	34.407	36.192	31.17	33.885	31.7	27.643	24.954	34.914	32.919	34.218	
Colstrip 4	MEAN	28.768	31.604	31.905	31.176	33.378	29.081	29.13	23.374	19.157	13.005	26.311	28.187	29.054	31.75	31.609	31.168	33.439	29.049	29.208	24.583	2.62	1.423	26.715	27.992	29.162	
	PS	19.768	24.086	25.973	25.96	27.325	23.929	22.793	15.209	11.252	7.865	14.166	22.568	21.307	27.102	23.773	25.758	28.027	23.657	22.07	15.207	1.434	0.277	16.87	22.962	21.48	
	P95	33.925	35.846	34.941	34.305	36.251	31.869	33.615	30.023	27.966	23.299	34.814	33.014	33.775	35.738	34.987	34.313	36.224	31.57	33.907	33.471	4.352	2.665	35.108	32.647	34.218	
CX FrameCT1	MEAN	0.355	0.043	0.805	1.926	3.26	1.37	0.413	0.078	0.029	0.002	0.662	2.844	0.339	0.065	0.878	2.19	3.674	1.408	0.433	0.085	0.02	0.001	0.489	2.827	0.454	
	PS	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.438	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.142	0.	
	P95	1.745	0.009	3.581	7.185	7.738	5.186	2.64	0.384	0.15	0.	1.994	5.8	1.592	0.014	4.666	7.175	8.974	5.113	2.498	0.732	0.177	0.	1.745	6.31	2.747	
CX FrameCT1	MEAN	0.357	0.054	0.751	1.922	3.205	1.385	0.431	0.077	0.031	0.001	0.651	2.797	0.341	0.065	0.803	2.24	3.646	1.429	0.449	0.083	0.02	0.001	0.538	2.864	0.453	
	PS	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.465	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.142	
	P95	1.723	0.07	3.81	7.311	7.517	5.186	2.423	0.384	0.15	0.	2.13	5.751	1.598	0.009	4.44	7.723	8.774	4.863	2.544	0.578	0.176	0.	2.265	6.5	2.703	
CX Recip1	MEAN	1.354	1.913	2.663	3.212	3.438	2.533	2.012	0.503	0.064	0.443	1.634	1.393	2.008	2.783	3.267	3.539	2.663	2.059	0.526	0.039	0.461	1.695	1.538			
	PS	0.35	0.828	1.5	2.236	2.622	1.72	1.214	0.11	0.	1.104	0.414	0.128	0.237	0.521	1.279	1.01	0.	0.	0.	0.	0.	1.003	0.69			
	P95	2.263	2.926	3.625	4.011	4.342	3.349	2.886	1.113	0.313	1.095	2.364	2.282	3.027	3.717	4.057	4.333	3.321	2.815	1.095	0.248	1.178	2.355	2.475			
CX Recip10	MEAN	1.245	1.764	2.472	2.965	3.174	2.344	1.86	0.466	0.058	0.409	1.517	1.281	1.848	2.589	3.019	3.259	2.742	1.898	0.40	0.035	0.419	1.563	1.416			
	PS	0.323	0.765	1.428	2.083	2.372	1.607	1.114	0.102	0.	1.054	0.383	0.723	1.505	2.193	2.27	1.53	1.122	0.094	0.	0.	0.	0.952	0.638			
	P95	2.04	2.703	3.281	3.664	4.046	3.12	2.491	1.029	0.289	1.012	2.168	2.108	2.797	3.426	3.757	4.004	3.111	2.601	1.093	0.23	1.088	2.126	2.312			
CX Recip2	MEAN	1.36	1.906	2.679	3.214	3.453	2.553	2.009	0.503	0.064	0.446	1.628	1.383	2.011	2.796	3.267	3.53	2.68	2.052	0.535	0.039	0.457	1.687	1.533			
	PS	0.35	0.828	1.546	2.254	2.548	1.748	1.15	0.11	0.	1.104	0.396	0.782	1.628	2.429	2.521	1.711	1.178	0.101	0.	0.	0.	0.966	0.69			
	P95	2.272	2.889	3.625	3.984	4.379	3.349	2.686	1.113	0.313	1.104	2.291	2.245	3.036	3.689	4.057	4.306	3.767	2.788	1.095	0.248	1.168	2.429	2.502			
CX Recip3	MEAN	1.351	1.906	2.666	3.202	3.457	2.548	2.025	0.502	0.064	0.441	1.635	1.389	2.007	2.784	3.262	3.531	2.684	2.063	0.53	0.039	0.453	1.689	1.535			
	PS	0.35	0.828	1.546	2.208	2.631	1.739	1.178	0.11	0.	1.104	0.386	0.782	1.628	2.429	2.521	1.693	1.279	0.101	0.	0.	0.	1.03	0.69			
	P95	2.263	2.916	3.625	3.938	4.379	3.376	2.696	1.113	0.313	1.095	2.337	2.282	3.036	3.708	4.048	4.333	3.367	2.815	1.095	0.248	1.159	2.337	2.502			
CX Recip4	MEAN	1.356	1.917	2.668	3.205	3.442	2.548	2.007	0.505	0.064	0.438	1.631	1.402	2.007	2.791	3.258	3.538	2.664	2.063	0.532	0.039	0.458	1.692	1.53			
	PS	0.35	0.819	1.546	2.217	2.631	1.739	1.178	0.11	0.	1.104	0.414	0.764	1.592	2.355	2.521	1.711	1.279	0.101	0.	0.	0.	1.03	0.662			
	P95	2.272	2.926	3.524	3.938	4.379	3.358	2.677	1.113	0.313	1.086	2.309	2.265	3.027	3.717	4.048	4.333	3.367	2.815	1.095	0.248	1.168	2.346	2.502			
CX Recip5	MEAN	1.263	1.916	2.667	3.215	3.438	2.552	2.015	0.502	0.063	0.446	1.632	1.398	2.004	2.797	3.272	3.508	2.671	2.054	0.53	0.038	0.459	1.693	1.533			
	PS	0.35	0.828	1.546	2.254	2.548	1.739	1.124	0.11	0.	1.124	0.405	0.782	1.628	2.446	2.521	1.678	1.251	1.031	0.535	0.039	0.457	1.687	1.533			
	P95	2.272	2.926	3.524	3.956	4.333	3.376	2.686	1.113	0.313	1.104	2.263	2.282	3.027	3.689	4.048	4.324	3.34	2.815	1.076	0.23	1.168	2.355	2.42			
CX Recip6	MEAN	1.35	1.908	2.676	3.208	3.447	2.543	2.014	0.502	0.063	0.445	1.632	1.384	2.006	2.803	3.266	3.535	2.672	2.053	0.534	0.039	0.455	1.692	1.534			
	PS	0.35	0.819	1.546	2.254	2.631	1.73	1.224	0.101	0.	1.104	0.414	0.782	1.628	2.401	2.502	1.711	1.279	0.101	0.	0.	0.	1.03	0.69			
	P95	2.153	2.926	3.625	3.984	4.342	3.358	2.696	1.113	0.313	1.104	2.383	2.282	3.008	3.689	4.048	4.333	3.367	2.742	1.095	0.248	1.178	2.41	2.502			
CX Recip7	MEAN	1.358	1.907	2.669	3.183	3.436	2.554	2.009	0.504	0.064	0.438	1.633	1.393	2.009	2.778	3.265	3.524	2.674	2.045	0.533	0.039	0.457	1.702	1.537			
	PS	0.35	0.819	1.546	2.236	2.594	1.702	1.224	0.11	0.	1.141	0.414	0.782	1.619	2.346	2.429	1.711	1.279	0.101	0.	0.	0.	1.03	0.681			
	P95	2.236	2.926	3.625	3.984	4.379	3.376	2.696	1.113	0.313	1.095	2.383	2.292	3.062	3.711	4.094	4.333	3.34	2.778	1.058	0.248	1.168	2.42	2.466			
CX Recip8	MEAN	1.25	1.764	2.476	2.957	3.18	2.335	1.859	0.458	0.059	0.406	1.516	1.283	1.855	2.583	3.007	3.255	2.466	1.899	0.496	0.036	0.424	1.57	1.411			
	PS	0.323	0.765	1.403	2.033	2.423	1.607	1.131	0.104	0.058	0.	1.054	0.383	0.723	1.471	2.159	2.058	1.573	1.165	0.094	0.	0.	0.952	0.629			
	P95	2.1	2.669	3.249	3.681	4.046	3.111	2.491	1.086	0.289	1.012	2.202															

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2032-09	2032-10	2032-11	2032-12	2033	2033-02	2033-03	2033-04	2033-05	2033-06	2033-07	2033-08	2033-09	2033-10	2033-11	2033-12	2034	2034-02	2034-03	2034-04	2034-05	2034-06	2034-07	2034-08	2034-09	
Hauser	P95	14.668	12.94	13.673	15.112	16.651	14.559	18.702	18.431	25.64	22.878	24.526	15.174	16.047	13.556	13.899	17.984	14.804	15.877	15.311	21.321	25.254	23.01	21.283	16.355	15.36	
	MEAN	4.853	4.887	4.663	4.562	4.738	4.264	4.613	4.599	5.321	4.92	4.864	4.262	4.866	4.665	4.572	4.73	4.456	4.795	4.759	4.594	5.319	4.919	4.851	4.587	4.587	4.587
	P5	4.583	4.656	4.456	4.334	4.504	4.013	4.371	4.349	4.743	4.367	5.03	4.705	4.604	4.679	4.454	4.351	4.456	4.008	4.423	4.541	4.533	4.403	5.089	4.666	4.587	
Holter	P95	9.166	5.699	9.8	10.056	10.451	9.985	4.409	4.844	4.773	5.273	4.801	5.578	5.102	5.072	5.152	4.874	4.802	4.989	4.517	4.844	4.976	5	4.918	11.794	9.255	9.169
	MEAN	3.166	3.243	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	3.8	
	P5	7.76	7.696	8.448	8.405	9.076	7.582	8.247	8.862	10.605	9.452	9.737	7.937	7.766	8.029	8.233	8.688	8.667	7.628	8.489	9.424	10.395	9.759	9.8	7.498	7.675	
Madison	P95	10.748	11.271	11.434	11.674	12.355	10.764	12.284	12.68	15.165	13.435	14.359	10.694	10.979	11.539	11.65	12.344	12.002	11.268	11.524	13.474	14.371	13.508	13.662	11.21	11.061	
	MEAN	2.254	2.412	2.38	2.31	2.445	2.21	2.405	2.205	2.566	2.276	2.627	2.303	2.252	2.417	2.378	2.312	2.443	2.207	2.404	2.321	2.449	2.276	2.626	2.304	2.254	
	P5	2.109	2.25	2.249	2.152	2.313	2.073	2.237	2.069	2.416	2.132	2.45	2.167	2.237	2.186	2.237	2.186	2.275	2.068	2.274	2.173	2.309	2.152	2.449	2.153	2.103	
Morony	P95	2.384	2.594	2.512	2.442	2.588	2.329	2.572	2.327	2.766	2.409	2.815	2.429	2.406	2.611	2.51	2.463	2.583	2.443	2.443	2.602	2.418	2.763	2.466	2.432		
	MEAN	8.704	9.003	8.941	8.967	9.641	8.43	8.955	9.846	11.659	11.476	8.974	8.875	9.039	8.959	8.994	9.64	8.804	8.737	10.37	12.23	11.669	11.769	8.878	8.707		
	P5	7.096	7.097	7.312	6.868	7.881	6.738	7.164	7.838	10.212	9.185	8.942	7.142	7.112	7.379	7.233	7.434	7.474	7.514	8.326	9.935	9.579	9.258	6.829	6.907		
Mystic	P95	10.451	11.112	10.676	10.796	11.727	10.095	11.314	11.734	16.188	13.934	14.255	10.519	10.688	11.515	10.844	11.996	11.51	10.724	10.732	12.43	15.935	13.983	13.503	11.287	10.979	
	MEAN	2.04	1.62	1.504	1.371	1.408	1.116	0.911	0.551	1.251	2.269	3.797	2.993	2.027	1.618	1.502	1.386	1.394	1.122	0.911	1.585	1.196	2.272	3.796	2.04		
	P5	1.685	1.192	1.201	0.916	1.027	0.837	0.714	0.483	1.099	1.905	3.51	2.343	1.707	1.233	1.153	1.004	0.93	0.806	0.76	0.506	1.062	1.956	3.55	2.198		
Rainbow	P95	2.407	2.134	1.817	1.788	1.939	1.485	1.161	0.512	1.478	2.64	4.053	3.562	2.429	2.165	1.896	1.97	1.818	1.505	1.1	0.659	1.386	2.658	4.017	3.7	2.512	
	MEAN	11.106	11.6	11.544	11.84	12.374	11.255	12.819	14.081	18.052	16.582	15.165	12.196	11.135	11.621	11.502	11.88	12.346	11.248	12.866	14.793	17.096	16.572	15.2	12.202	11.085	
	P5	5.253	4.795	6.066	5.021	5.634	5.257	5.728	5.598	8.201	7.428	7.548	6.398	5.525	5.623	5.963	5.811	5.601	5.128	6.43	6.779	9.23	8.804	7.406	5.48	5.426	
Ryan	P95	19.596	22.765	21.502	20.837	23.653	19.59	24.542	25.609	33.292	28.942	28.068	20.419	20.012	15.745	20.735	24.957	21.061	20.443	21.262	27.527	33.627	27.917	25.473	22.411	20.155	
	MEAN	14.476	15.217	15.027	14.494	15.347	13.714	15.45	16.044	19.757	17.551	17.438	14.592	14.458	15.279	15.345	15.017	14.533	15.349	16.873	18.689	17.524	17.147	14.44	14.606	14.482	
	P5	12.711	13.518	13.561	12.789	13.388	12.125	12.997	13.741	18.124	15.837	15.554	13.086	13.04	13.727	13.476	13.022	12.681	12.123	13.361	14.41	17.358	16.153	15.72	12.919	12.712	
Sleeping Giant	P95	15.993	17.262	16.433	15.878	17.31	15.09	17.844	18.131	21.452	18.914	19.19	15.908	16.165	17.411	16.568	16.212	17.435	15.25	17.42	18.905	20.407	19.199	18.708	16.306	16.499	
	MEAN	2.548	0.63	0.643	0.293	0.28	0.409	1.047	2.429	2.748	2.431	2.749	2.489	2.544	0.63	0.642	0.293	0.279	0.41	1.048	2.556	2.621	2.428	2.75	2.491	2.544	
	P5	2.508	0.622	0.631	0.289	0.269	0.404	1.03	2.392	2.721	2.404	2.714	2.455	2.504	0.623	0.631	0.29	0.267	0.403	1.033	2.521	2.58	2.403	2.719	2.465		
Thompson Falls	P95	2.583	0.639	0.654	0.297	0.293	0.415	1.061	2.459	2.773	2.456	2.778	2.519	2.581	0.639	0.653	0.297	0.291	0.414	1.061	2.587	2.651	2.451	2.778	2.517	2.577	
	MEAN	12.384	14.427	16.247	17.598	17.372	15.704	16.731	22.371	28.449	24.642	25.716	14.147	12.392	14.558	16.181	17.636	17.366	15.673	16.785	23.5	27.057	24.675	25.775	14.14	12.392	
	P5	9.731	10.963	13.053	13.674	14.179	12.077	12.906	17.098	22.862	18.66	19.708	11.434	9.87	11.749	12.914	14.187	13.372	12.204	13.959	18.378	19.914	10.656	9.779			
Hydro - Total	P95	15.318	18.506	20.216	21.535	21.565	19.211	21.681	27.553	36.085	30.141	33.518	17.126	15.497	19.233	20.089	22.61	20.89	20.075	20.524	29.247	34.031	30.155	31.474	17.846	15.828	
	MEAN	80.307	80.501	83.411	84.566	87.698	78.999	87.603	99.421	124.506	112.953	113.391	85.789	80.297	80.693	83.16	84.813	87.613	87.796	104.523	118.442	112.974	113.572	85.783	80.293		
	P5	60.88	59.474	66.314	62.124	67.605	58.205	64.227	72.209	93.444	83.223	84.275	66.874	62.577	63.541	63.544	65.817	64.099	57.691	68.12	77.189	92.349	88.64	84.447	62.738	62.419	
Load	P95	104.572	109.268	110.111	108.859	118.702	102.786	122.784	130.306	165.92	145.632	156.878	108.105	109.852	110.679	109.128	120.404	112.078	107.679	110.75	139.993	159.673	144.651	144.985	113.576	107.335	
	MEAN	-215.696	-223.169	-244.038	-257.12	-249.253	-237.414	-225.296	-212.355	-232.273	-214.316	-257.286	-223.197	-219.096	-226.124	-246.431	-259.782	-250.576	-240.618	-228.444	-228.5	-223.13	-217.669	-259.672	-227.11	-221.179	
	P5	-197.728	-228.324	-250.41	-264.825	-247.395	-243.501	-232.061	-216.234	-237.567	-217.571	-265.683	-228.104	-222.199	-230.601	-252.315	-267.085	-263.281	-247.5	-235.955	-233.376	-228.095	-220.351	-268.021	-231.848	-225.077	
Small QF1	P95	-212.01	-217.671	-228.254	-242.372	-232.875	-231.616	-217.825	-208.844	-228.213	-241.93	-269.84	-216.274	-221.636	-239.464	-251.023	-235.397	-233.141	-241.666	-223.693	-219.444	-214.6	-211.224	-251.225	-223.035	-216.823	
	MEAN	0.01	0.01	0.01	0.009	0.01	0.009	0.009	0.009	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.01	0.009		
	P5	0.01	0.01	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.01	0.009			
Small Tier II	P95	0.01	0.01	0.01	0.009	0.01	0.009	0.009	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.01	0.009			
	MEAN	0.01	0.01	0.01	0.009	0.01	0.009	0.009	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.01	0.009			
	P5	0.01	0.01	0.01	0.009	0.01	0.009	0.009	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.009	0.01	0.01	0.009			
Tiber	P95	1.106	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014			
	MEAN	1.106	0.014	0.014	0.014	0.014																					

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2032-09	2032-10	2032-11	2032-12	2033	2033-02	2033-03	2033-04	2033-05	2033-06	2033-07	2033-08	2033-09	2033-10	2033-11	2033-12	2034	2034-02	2034-03	2034-04	2034-05	2034-06	2034-07	2034-08	2034-09	
Judith Gap	PS																										
	P95																										
	MEAN	0.654	0.875	1.106	1.109	1.406	1.259	1.007	1.102	0.684	0.743	0.531	0.5	0.654	0.882	1.102	1.124	1.465	1.262	0.997	1.171	0.65	0.745	0.538	0.509	0.652	
Musselshell 1	PS	0.45	0.591	0.781	0.768	1.057	0.994	0.716	0.905	0.505	0.502	0.35	0.347	0.415	0.624	0.711	0.738	1.087	0.953	0.721	0.896	0.449	0.57	0.334	0.332	0.442	
	P95	0.867	1.158	1.462	1.483	1.851	1.54	1.309	1.336	0.921	0.964	0.741	0.654	0.913	1.194	1.448	1.552	1.924	1.598	1.3	1.439	0.866	0.912	0.79	0.749	0.863	
	MEAN	0.813	1.012	1.352	1.274	1.559	1.415	1.173	1.325	0.872	0.884	0.641	0.636	0.813	1.022	1.348	1.289	1.623	1.419	1.163	1.404	0.829	0.886	0.648	0.645	0.812	
Musselshell 2	PS	0.577	0.672	0.976	0.949	1.16	1.114	0.851	1.078	0.643	0.601	0.427	0.473	0.53	0.734	0.871	0.896	1.247	1.084	0.854	1.101	0.599	0.678	0.413	0.437	0.58	
	P95	1.057	1.331	1.748	1.63	2.032	1.722	1.499	1.598	1.131	1.14	0.881	0.818	1.117	1.393	1.766	1.707	1.994	1.738	1.521	1.726	1.098	1.087	0.922	0.916	1.029	
	MEAN	0.115	0.072	0.036	0.024	0.036	0.051	0.072	0.099	0.156	0.133	0.197	0.106	0.117	0.074	0.035	0.025	0.038	0.05	0.069	0.118	0.135	0.13	0.195	0.108	0.116	
Ragen Ranch Solar	PS	0.	0.009	0.008	0.012	0.006	0.008	0.013	0.028	0.032	0.001	0.055	0.008	0.001	0.006	0.011	0.006	0.009	0.014	0.019	0.018	0.004	0.055	0.011	0.	0.	
	P95	0.227	0.146	0.092	0.042	0.092	0.115	0.135	0.197	0.291	0.271	0.303	0.171	0.227	0.15	0.095	0.048	0.1	0.113	0.131	0.229	0.253	0.266	0.299	0.172	0.228	
	MEAN	0.068	0.039	0.023	0.014	0.018	0.028	0.047	0.052	0.105	0.088	0.125	0.063	0.066	0.041	0.023	0.015	0.02	0.027	0.046	0.063	0.087	0.085	0.125	0.064	0.066	
River Bend Solar	PS	0.001	0.	0.	0.005	0.	0.	0.	0.003	0.039	0.032	0.073	0.025	0.001	0.	0.	0.004	0.001	0.	0.001	0.	0.001	0.027	0.023	0.071	0.025	0.001
	P95	0.125	0.09	0.067	0.035	0.056	0.064	0.092	0.09	0.159	0.14	0.172	0.095	0.122	0.089	0.064	0.035	0.057	0.061	0.089	0.11	0.135	0.14	0.173	0.094	0.122	
	MEAN	0.117	0.069	0.042	0.023	0.031	0.047	0.076	0.094	0.17	0.142	0.216	0.109	0.118	0.07	0.041	0.025	0.036	0.047	0.072	0.113	0.145	0.144	0.213	0.109	0.119	
South Mills Solar	PS	0.	0.004	0.009	0.011	0.002	0.004	0.006	0.017	0.022	0.001	0.085	0.019	0.	0.002	0.007	0.011	0.003	0.005	0.004	0.007	0.014	0.005	0.072	0.017	0.	
	P95	0.224	0.146	0.102	0.041	0.095	0.12	0.14	0.184	0.293	0.263	0.318	0.166	0.222	0.155	0.099	0.046	0.097	0.116	0.139	0.21	0.257	0.265	0.32	0.167	0.224	
	MEAN	3.904	4.875	6.364	7.04	7.711	5.963	5.613	4.366	2.977	2.875	3.163	2.291	3.898	4.922	6.337	7.171	7.759	5.974	5.584	4.646	2.835	2.881	3.197	2.343	3.884	
Spion Kop	PS	2.695	3.513	4.687	5.672	6.178	4.135	4.242	3.252	1.917	1.567	1.978	1.499	2.659	3.435	4.202	5.76	6.166	4.055	4.17	2.936	1.715	2.	1.841	1.457	2.654	
	P95	5.388	6.291	8.204	8.275	9.389	7.598	7.259	5.876	4.339	4.122	4.334	3.111	5.252	6.411	8.367	8.725	9.324	7.61	6.974	6.467	4.011	3.82	4.673	3.524	5.174	
	MEAN	0.784	1.495	1.697	1.497	2.039	1.331	1.407	1.397	0.53	0.954	0.697	0.586	0.782	1.502	1.695	1.505	2.119	1.329	1.397	1.48	0.501	0.957	0.705	0.598	0.779	
Two Dot Wind	PS	0.547	1.157	1.346	1.13	1.685	1.011	1.079	1.197	0.331	0.675	0.467	0.416	0.533	1.234	1.263	1.085	1.767	0.982	1.083	1.188	0.299	0.742	0.436	0.408	0.545	
	P95	1.053	1.906	2.032	1.851	2.449	1.656	1.764	1.646	0.743	1.243	0.948	0.789	1.043	1.829	2.07	1.971	2.472	1.671	1.759	1.781	0.732	1.178	1.052	0.817	1.059	
	MEAN	34.181	52.409	66.915	67.031	71.354	51.585	48.742	44.341	35.157	33.488	30.009	24.725	34.108	52.873	66.699	67.547	74.1	50.946	48.247	47.188	33.355	33.511	30.194	24.97	34.006	
Wind/Solar Asset - Total	PS	25.121	42.053	58.119	58.921	62.099	40.398	38.734	36.767	27.691	24.413	20.977	18.742	25.061	44.318	55.567	60.165	63.298	38.064	38.649	35.105	25.454	26.145	19.895	17.957	25.05	
	P95	42.831	62.484	76.304	73.988	80.697	61.357	59.847	55.401	44.222	43.729	39.468	31.963	44.747	63.32	76.657	76.701	83.997	61.053	59.28	60.484	41.393	41.194	41.722	33.967	42.742	
	MEAN	3.292	23.271	37.508	41.722	69.639	17.821	23.384	1.799	-12.181	-23.701	-28.858	8.092	-0.579	22.839	36.311	42.878	75.284	16.204	21.022	-2.424	-29.352	-37.851	-30.413	-5.547	0.916	
Total	PS	-34.811	-9.575	-0.759	4.619	25.827	-20.613	-11.148	-33.156	-48.467	-56.245	-71.094	-21.099	-32.165	-9.724	1.388	3.765	33.743	-27.36	-16.392	-34.853	-57.642	-66.136	-81.393	-39.775	-34.142	
	P95	39.282	60.755	76.772	89.839	116.76	58.46	57.253	40.104	32.04	18.166	17.083	52.651	36.828	61.115	70.836	86.35	131.994	55.252	61.191	37.127	13.64	-7.119	15.622	46.399	34.008	

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2034-10	2034-11	2034-12	2035	2035-02	2035-03	2035-04	2035-05	2035-06	2035-07	2035-08	2035-09	2035-10	2035-11	2035-12
Basin Creek	MEAN	0.147	0.597	1.568	1.112	0.594	0.386	0.19	0.021		0.316	1.171	0.467	0.183	0.566	1.585
	P5	0.	0.022	0.212	0.089	0.034	0.045	0.	0.		0.	0.134	0.	0.	0.011	0.112
	P95	0.648	1.968	4.045	2.732	1.718	1.23	0.688	0.123		1.153	2.566	1.435	0.793	1.624	3.593
CELP	MEAN															
	P5															
	P95															
Colstrip 3	MEAN	31.656	31.713	34.375	33.056	28.831	29.813	24.966	1.208	3.259	26.694	28.801	31.741	30.402	32.026	34.722
	P5	22.158	25.591	26.983	27.07	22.344	23.383	16.667	0.228	1.244	15.385	21.62	23.443	22.858	26.498	27.348
	P95	35.84	35.084	37.717	36.368	31.815	33.62	31.85	2.185	6.583	34.782	33.017	35.965	34.05	35.143	38.022
Colstrip 4	MEAN	31.688	31.997	34.512	33.638	29.33	30.004	24.905	19.063	13.778	26.27	28.382	30.924	30.075	32.132	34.627
	P5	25.7	25.05	27.607	28.073	23.716	24.055	16.253	11.562	8.01	13.67	22.386	23.111	23.756	26.405	29.201
	P95	35.84	35.125	37.708	36.368	31.761	33.72	31.85	28.132	25.581	34.722	33.07	36.142	34.031	35.089	37.986
CX FrameCT1	MEAN	0.06	0.708	2.403	3.86	1.359	0.331	0.042	0.024		0.584	2.6	0.45	0.05	0.566	2.126
	P5	0.	0.	0.	0.	0.	0.	0.	0.		0.	0.084	0.	0.	0.	0.
	P95	0.127	4.292	9.465	9.299	4.59	2.159	0.263	0.121		2.476	6.36	2.993	0.	3.085	8.152
CX FrameCT1	MEAN	0.064	0.708	2.394	3.844	1.35	0.32	0.04	0.022		0.589	2.6	0.449	0.06	0.647	2.068
	P5	0.	0.	0.	0.	0.	0.	0.	0.		0.	0.084	0.	0.	0.	0.
	P95	0.127	4.403	9.647	8.716	4.743	2.158	0.263	0.121		2.564	6.122	2.757	0.	3.36	7.658
CX Recip1	MEAN	2.155	2.819	3.661	3.594	2.648	2.055	0.522	0.061		0.474	1.688	1.637	2.147	2.931	3.732
	P5	0.902	1.711	2.392	2.493	1.757	1.343	0.074	0.		1.03	0.626	0.911	1.868	2.309	3.000
	P95	3.211	3.8	4.637	4.407	3.56	2.732	1.03	0.294		1.279	2.364	2.374	3.238	3.892	4.664
CX Recip10	MEAN	1.993	2.615	3.393	3.323	2.463	1.9	0.481	0.057		0.439	1.564	1.512	1.98	2.713	3.446
	P5	0.833	1.59	2.295	2.295	1.751	1.207	0.068	0.		0.	0.927	0.578	0.842	1.649	2.066
	P95	3.026	3.579	4.412	4.072	3.307	2.474	0.952	0.272		1.165	2.159	2.176	3.06	3.596	4.335
CX Recip2	MEAN	2.151	2.82	3.681	3.6	2.657	2.056	0.522	0.061		0.479	1.69	1.631	2.144	2.945	3.741
	P5	0.902	1.72	2.466	2.493	1.831	1.306	0.074	0.		1.03	0.626	0.911	1.914	2.309	3.000
	P95	3.275	3.818	4.793	4.444	3.533	2.686	1.03	0.294		1.26	2.364	2.374	3.238	3.892	4.683
CX Recip3	MEAN	2.146	2.82	3.669	3.572	2.667	2.047	0.517	0.061		0.476	1.698	1.635	2.144	2.941	3.753
	P5	0.902	1.72	2.484	2.493	1.877	1.343	0.074	0.		1.03	0.626	0.819	1.877	2.383	3.000
	P95	3.202	3.864	4.802	4.407	3.524	2.64	1.03	0.294		1.279	2.346	2.374	3.238	3.873	4.664
CX Recip4	MEAN	2.143	2.832	3.654	3.586	2.66	2.052	0.517	0.061		0.475	1.687	1.634	2.142	2.95	3.739
	P5	0.846	1.702	2.41	2.493	1.868	1.297	0.074	0.		1.03	0.626	0.911	1.886	2.383	3.000
	P95	3.192	3.873	4.738	4.425	3.57	2.677	0.966	0.294		1.251	2.364	2.355	3.312	3.882	4.618
CX Recip5	MEAN	2.157	2.818	3.671	3.593	2.653	2.057	0.515	0.061		0.476	1.685	1.641	2.13	2.945	3.742
	P5	0.902	1.72	2.411	2.475	1.895	1.343	0.074	0.		1.03	0.626	0.911	1.914	2.383	3.000
	P95	3.211	3.744	4.664	4.407	3.579	2.686	1.021	0.294		1.26	2.364	2.374	3.312	3.892	4.692
CX Recip6	MEAN	2.162	2.812	3.669	3.589	2.661	2.054	0.52	0.062		0.477	1.678	1.64	2.134	2.941	3.727
	P5	0.902	1.702	2.484	2.475	1.886	1.343	0.074	0.		1.03	0.607	0.883	1.914	2.383	3.000
	P95	3.275	3.864	4.664	4.379	3.542	2.732	1.03	0.294		1.26	2.364	2.392	3.312	3.892	4.609
CX Recip7	MEAN	2.15	2.814	3.669	3.588	2.658	2.055	0.52	0.062		0.48	1.697	1.636	2.14	2.946	3.734
	P5	0.902	1.72	2.456	2.493	1.895	1.325	0.074	0.		1.03	0.626	0.911	1.868	2.383	3.000
	P95	3.275	3.827	4.802	4.407	3.579	2.732	1.03	0.294		1.279	2.364	2.374	3.312	3.892	4.674
CX Recip8	MEAN	1.998	2.611	3.392	3.324	2.456	1.901	0.481	0.057		0.441	1.569	1.515	1.967	2.703	3.449
	P5	0.833	1.59	2.295	2.278	1.751	1.241	0.068	0.		0.952	0.578	0.842	1.768	2.066	2.666
	P95	3.026	3.579	4.31	4.06	3.307	2.525	0.952	0.272		1.182	2.176	2.159	2.926	3.587	4.335
CX Recip9	MEAN	1.985	2.602	3.392	3.295	2.448	1.9	0.475	0.056		0.443	1.563	1.521	1.98	2.707	3.464
	P5	0.833	1.581	2.295	2.287	1.726	1.241	0.068	0.		0.959	0.578	0.774	1.658	2.202	2.800
	P95	3.026	3.579	4.437	4.089	3.307	2.525	0.952	0.272		1.182	2.185	2.193	3.06	3.587	4.267
David Gates Generating Station	MEAN	13.286	15.826	21.167	18.841	14.381	13.148	11.621	10.253	9.12	12.285	16.529	15.866	13.326	15.976	21.711
	P5	10.44	11.675	15.158	14.24	11.49	10.91	9.8	9.84	9.12	10.32	13.36	11.48	9.66	11.738	15.108
	P95	17.89	20.788	26.733	24.328	18.628	16.398	13.838	11.615	9.12	15.77	19.66	20.78	18.823	20.475	26.92
FrameCT_ram p_2018	MEAN	0.059	0.69	2.307	3.707	1.219	0.301	0.033	0.021		0.595	2.689	0.409	0.065	0.578	1.99
	P5	0.	0.	0.	0.	0.	0.	0.	0.		0.	0.026	0.	0.	0.	0.
	P95	0.009	4.403	9.647	8.865	4.499	1.876	0.263	0.117		2.653	6.223	2.467	0.	3.581	8.25
FrameCT_ram p_2020	MEAN	0.062	0.67	2.231	3.694	1.19	0.309	0.035	0.021		0.578	2.631	0.462	0.063	0.611	2.068
	P5	0.	0.	0.	0.	0.	0.	0.	0.		0.	0.031	0.	0.	0.	0.
	P95	0.009	3.797	7.426	9.181	4.404	2.166	0.249	0.117		2.938	6.131	3.278	0.	3.581	7.949
FrameCT_ram p_2022	MEAN	0.063	0.654	2.229	3.723	1.185	0.31	0.036	0.021		0.59	2.608	0.453	0.061	0.573	1.971
	P5	0.	0.	0.	0.	0.	0.	0.	0.		0.	0.067	0.	0.	0.	0.
	P95	0.009	3.908	9.523	9.107	4.499	2.215	0.249	0.108		2.714	5.477	3.125	0.	3.581	7.518
Recip_ramp_2 018	MEAN	1.977	2.616	3.391	3.314	2.451	1.896	0.482	0.057		0.438	1.561	1.51	1.983	2.716	3.454
	P5	0.833	1.53	2.295	2.27	1.683	1.224	0.068	0.		0.893	0.561	0.842	1.734	2.202	2.800
	P95	3.026	3.579	4.437	4.072	3.307	2.474	0.952	0.272		1.182	2.185	2.193	2.992	3.596	4.327
Recip_ramp_2 020	MEAN	1.974	2.604	3.391	3.307	2.455	1.899	0.482	0.057		0.438	1.566	1.515	1.979	2.71	3.448
	P5	0.774	1.59	2.244	2.304	1.751	1.241	0.068	0.		0.944	0.527	0.816	1.717	2.202	2.800
	P95	3.026	3.511	4.369	4.08	3.307	2.457	0.952	0.272		1.182	2.176	2.176	2.916	3.528	4.335
Recip_ramp_2 022	MEAN	1.992	2.611	3.406	3.331	2.447	1.899	0.483	0.054		0.442	1.561	1.507	1.964	2.725	3.453
	P5	0.774	1.59	2.261	2.278	1.683	1.207	0.068	0.		0.91	0.527	0.816	1.768	2.202	2.800
	P95	3.026	3.579	4.429	4.106	3.307	2.525	0.952	0.272		1.165	2.176	2.21	2.992	3.596	4.276
Recip_ramp_2 024	MEAN	1.988	2.6	3.386	3.321	2.458	1.881	0.483	0.057		0.441	1.559	1.52	1.977	2.704	3.446
	P5	0.833	1.581	2.253	2.304	1.751	1.241	0.068	0.		0.952	0.578	0.79			

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2034-10	2034-11	2034-12	2035	2035-02	2035-03	2035-04	2035-05	2035-06	2035-07	2035-08	2035-09	2035-10	2035-11	2035-12
Hauser	P95	11.812	13.284	18.05	16.155	14.676	16.889	18.561	21.273	23.962	23.186	16.183	16.389	12.871	13.666	17.259
	MEAN	4.887	4.663	5.036	4.732	4.266	4.62	4.8	4.749	4.597	5.319	4.922	5.088	4.649	4.673	5.019
	P5	4.652	4.4	4.753	4.476	3.969	4.408	4.613	4.481	4.354	5.093	4.696	4.83	4.387	4.466	4.71
Holter	P95	5.145	4.931	5.263	4.975	4.502	4.812	5.027	4.975	4.864	5.54	5.088	5.327	4.865	4.921	5.262
	MEAN	9.265	9.8	11.102	10.44	9.26	9.941	11.266	12.062	11.467	11.806	9.25	9.636	8.802	9.811	11.06
	P5	7.849	8	9.017	8.812	7.274	8.233	9.597	9.989	9.7	9.728	7.714	7.807	7.329	8.21	9.338
Madison	P95	11.104	11.717	13.189	12.352	10.998	11.823	12.915	13.955	14.085	14.159	10.944	11.77	10.593	11.593	13.087
	MEAN	2.413	2.38	2.548	2.443	2.21	2.406	2.323	2.446	2.276	2.626	2.302	2.364	2.296	2.383	2.537
	P5	2.246	2.211	2.359	2.304	2.045	2.257	2.213	2.281	2.14	2.445	2.15	2.208	2.129	2.244	2.358
Morony	P95	2.583	2.56	2.7	2.608	2.349	2.548	2.461	2.594	2.448	2.803	2.439	2.524	2.457	2.542	2.702
	MEAN	9.031	8.94	9.916	9.633	8.445	8.959	10.382	12.213	11.67	11.477	8.865	9.139	8.574	8.963	9.847
	P5	7.085	6.898	7.259	7.838	6.42	7.096	8.532	9.5	9.477	9.026	6.909	7.188	6.737	7.264	7.652
Mystic	P95	11.035	11.157	12.134	11.766	10.158	10.812	12.171	14.934	14.505	14.107	10.908	11.195	10.434	10.842	12.382
	MEAN	1.611	1.496	1.594	1.387	1.136	0.914	0.585	1.189	2.269	3.793	2.976	2.157	1.514	1.501	1.579
	P5	1.186	1.111	1.052	0.982	0.747	0.738	0.52	1.022	1.894	3.547	2.328	1.753	1.123	1.178	1.065
Rainbow	P95	2.102	1.896	2.096	1.852	1.474	1.105	0.653	1.246	2.688	4.035	3.574	2.622	1.956	1.882	2.122
	MEAN	11.673	11.568	13.062	12.345	11.284	12.809	14.805	17.075	16.587	15.237	12.157	11.691	11.049	11.559	13.053
	P5	6.022	4.829	5.621	5.321	4.632	5.964	7.925	8.173	7.62	6.515	6.064	5.073	5.305	5.284	5.45
Ryan	P95	20.688	20.772	26.311	22.107	20.637	21.942	24.116	29.014	30.806	29.071	22.012	21.35	20.565	20.341	23.868
	MEAN	15.233	15.02	16.022	15.322	13.713	15.385	16.904	18.837	17.525	17.426	14.597	15.172	14.507	15.066	15.914
	P5	13.461	13.161	13.931	13.219	11.917	13.221	15.219	16.965	15.775	15.682	12.981	13.32	12.67	13.51	13.908
Sleeping Giant	P95	17.228	16.915	17.56	17.752	15.264	17.52	18.667	20.345	19.252	19.104	16.078	16.975	16.238	16.836	17.838
	MEAN	0.629	0.642	0.323	0.279	0.41	1.048	2.555	2.623	2.43	2.748	2.494	2.676	0.6	0.642	0.322
	P5	0.62	0.631	0.32	0.266	0.403	1.034	2.524	2.592	2.397	2.716	2.468	2.639	0.591	0.629	0.318
Thompson Falls	P95	0.638	0.653	0.327	0.294	0.415	1.062	2.582	2.649	2.457	2.778	2.521	2.711	0.608	0.654	0.327
	MEAN	14.473	16.245	19.419	17.354	15.713	16.748	23.555	27.033	24.663	25.795	14.13	13.016	13.746	16.282	19.373
	P5	11.201	12.209	14.396	13.751	11.436	12.984	18.994	20.44	19.475	19.648	10.912	9.731	10.583	12.614	15.009
Hydro - Total	P95	18.06	20.248	24.436	21.758	19.638	20.984	27.953	32.975	31.487	32.258	17.538	16.37	17.403	20.497	24.154
	MEAN	80.752	83.424	93.475	87.54	79.119	87.663	104.689	118.312	112.972	113.665	85.664	84.394	76.658	83.57	93.115
	P5	62.028	60.955	66.631	65.256	54.556	65.894	82.06	88.93	85.082	83.477	64.957	61.792	57.818	63.219	70.074
Load	P95	104.635	108.695	127.774	116.926	103.942	115.871	131.223	147.524	148.958	151.851	112.093	112.692	103.836	109.25	123.051
	MEAN	-229.072	-250.045	-296.293	-253.573	-243.811	-232.013	-231.516	-225.48	-220.011	-262.405	-230.369	-237.701	-219.164	-252.486	-299.755
	P5	-234.102	-256.313	-303.457	-271.706	-250.311	-238.394	-236.237	-230.047	-222.684	-270.112	-235.356	-241.555	-222.868	-258.248	-308.628
Small QF1	P95	-224.541	-243.04	-287.912	-236.559	-237.091	-225.713	-227.15	-221.276	-217.2	-254.734	-224.944	-234.162	-215.02	-246.214	-291.316
	MEAN															
	P5															
Small Tier II	P95															
	MEAN															
	P5															
Tiber	P95															
	MEAN															
	P5															
Turnbull	P95															
	MEAN															
	P5															
Physical Instrument - Total	P95															
	MEAN															
	P5															
S6 MW Wind 2018	P95	9.12	11.817	13.378	12.961	8.739	7.824	7.615	5.334	5.115	4.321	3.838	5.564	8.608	11.861	13.29
	MEAN	7.691	10.626	11.645	11.403	7.173	6.369	5.854	4.068	3.98	3.021	2.597	4.309	7.289	10.318	11.656
	P5	10.805	13.043	14.773	14.499	10.331	9.786	9.833	6.661	6.463	5.887	5.305	6.97	9.691	13.412	15.044
S6 MW Wind 2020	P95	9.12	11.817	13.378	12.961	8.739	7.824	7.615	5.334	5.115	4.321	3.838	5.564	8.608	11.861	13.29
	MEAN	7.691	10.626	11.645	11.403	7.173	6.369	5.854	4.068	3.98	3.021	2.597	4.309	7.289	10.318	11.656
	P5	10.805	13.043	14.773	14.499	10.331	9.786	9.833	6.661	6.463	5.887	5.305	6.97	9.691	13.412	15.044
S6 MW Wind 2022	P95	9.12	11.817	13.378	12.961	8.739	7.824	7.615	5.334	5.115	4.321	3.838	5.564	8.608	11.861	13.29
	MEAN	7.691	10.626	11.645	11.403	7.173	6.369	5.854	4.068	3.98	3.021	2.597	4.309	7.289	10.318	11.656
	P5	10.805	13.043	14.773	14.499	10.331	9.786	9.833	6.661	6.463	5.887	5.305	6.97	9.691	13.412	15.044
S6 MW Wind 2024	P95	9.12	11.817	13.378	12.961	8.739	7.824	7.615	5.334	5.115	4.321	3.838	5.564	8.608	11.861	13.29
	MEAN	7.691	10.626	11.645	11.403	7.173	6.369	5.854	4.068	3.98	3.021	2.597	4.309	7.289	10.318	11.656
	P5	10.805	13.043	14.773	14.499	10.331	9.786	9.833	6.661	6.463	5.887	5.305	6.97	9.691	13.412	15.044
6 MW Solar 2018	P95	0.128	0.08	0.078	0.091	0.09	0.142	0.231	0.277	0.269	0.395	0.226	0.266	0.096	0.078	0.078
	MEAN	0.002	0.027	0.043	0.033	0.026	0.012	0.017	0.038	0	0.088	0.024	0	0.006	0.023	0.044
	P5	0.296	0.169	0.123	0.169	0.194	0.279	0.512	0.544	0.564	0.636	0.396	0.535	0.221	0.169	0.134
6 MW Solar 2020	P95	0.128	0.08	0.078	0.091	0.09	0.142	0.231	0.277	0.269	0.395	0.226	0.266	0.096	0.078	0.078
	MEAN	0.002	0.027	0.043	0.033	0.026	0.012	0.017	0.038	0	0.088	0.024	0	0.006	0.023	0.044
	P5	0.296	0.169	0.123	0.169	0.194	0.279	0.512	0.544	0.564	0.636	0.396	0.535	0.221	0.169	0.134
6 MW Solar 2022	P95	0.128	0.08	0.078	0.091	0.09	0.142	0.231	0.277	0.269	0.395	0.226	0.266	0.096	0.078	0.078
	MEAN	0.002	0.027	0.043	0.033	0.026	0.012	0.017	0.038	0	0.088	0.024	0	0.006	0.023	0.044
	P5	0.296	0.169	0.123	0.169	0.194	0.279	0.512	0.544	0.564	0.636	0.396	0.535	0.221	0.169	0.134
6 MW Solar 2024	P95	0.128	0.08	0.078	0.091	0.09	0.142	0.231	0.277	0.269	0.395	0.226	0.266	0.096	0.078	0.078
	MEAN	0.002	0.027	0.043	0.033	0.026	0.012	0.017	0.038	0	0.088	0.024	0	0.006	0.	

Net Position Report - Double Wind and Solar - Light Load Hours (GWh)

Net Position, GWh		2034-10	2034-11	2034-12	2035	2035-02	2035-03	2035-04	2035-05	2035-06	2035-07	2035-08	2035-09	2035-10	2035-11	2035-12
Judith Gap	PS															
	P95															
	MEAN															
Musselshell 1	PS	0.876	1.1	1.236	1.48	1.254	0.995	1.175	0.66	0.726	0.54	0.514	0.689	0.817	1.126	1.233
	P5	0.637	0.773	0.914	1.087	1	0.7	0.939	0.433	0.513	0.398	0.353	0.499	0.567	0.787	0.841
	P95	1.197	1.409	1.601	1.888	1.501	1.283	1.505	0.91	0.948	0.696	0.736	0.887	1.047	1.485	1.7
Musselshell 2	MEAN	1.015	1.346	1.419	1.643	1.409	1.16	1.411	0.841	0.864	0.65	0.651	0.857	0.947	1.376	1.417
	PS	0.717	0.981	1.081	1.208	1.123	0.805	1.136	0.59	0.619	0.482	0.45	0.638	0.653	0.994	1.004
	P95	1.387	1.718	1.768	2.071	1.68	1.487	1.79	1.14	1.137	0.848	0.898	1.082	1.215	1.796	1.894
Ragen Ranch Solar	MEAN	0.074	0.037	0.037	0.039	0.049	0.071	0.119	0.136	0.131	0.194	0.106	0.134	0.056	0.036	0.037
	PS	0.005	0.009	0.017	0.006	0.009	0.014	0.026	0.034	0.001	0.043	0.01	0.001	0.006	0.006	0.018
	P95	0.153	0.098	0.067	0.094	0.111	0.133	0.23	0.253	0.262	0.305	0.173	0.266	0.114	0.091	0.065
River Bend Solar	MEAN	0.041	0.025	0.022	0.02	0.027	0.047	0.065	0.088	0.085	0.124	0.063	0.079	0.031	0.024	0.022
	PS	0	0	0.005	0	0	0	0.003	0.03	0.023	0.07	0.025	0.001	0	0	0.005
	P95	0.089	0.062	0.052	0.053	0.062	0.088	0.113	0.135	0.136	0.172	0.094	0.144	0.07	0.065	0.055
South Mills Solar	MEAN	0.072	0.043	0.036	0.035	0.046	0.074	0.115	0.146	0.141	0.212	0.109	0.136	0.053	0.042	0.036
	PS	0.001	0.01	0.016	0.002	0.004	0.009	0.015	0.017	0.001	0.06	0.02	0	0.002	0.007	0.016
	P95	0.151	0.103	0.062	0.09	0.112	0.142	0.221	0.259	0.256	0.325	0.167	0.259	0.119	0.095	0.065
Spion Kop	MEAN	4.909	6.355	7.793	7.755	5.929	5.567	4.669	2.881	2.795	3.203	2.361	4.065	4.531	6.459	7.832
	PS	3.57	4.796	6.032	6.296	4.18	4.301	3.156	1.54	1.752	2.138	1.499	2.938	3.143	4.907	5.737
	P95	6.695	7.777	9.44	9.206	7.583	7.105	6.449	4.144	4.001	4.493	3.443	5.239	5.868	8.008	9.862
Two Dot Wind	MEAN	1.494	1.692	1.657	2.142	1.322	1.397	1.487	0.51	0.934	0.707	0.603	0.819	1.408	1.717	1.651
	PS	1.232	1.332	1.288	1.745	1.038	1.072	1.23	0.301	0.703	0.528	0.409	0.611	1.162	1.376	1.231
	P95	1.83	2.052	2.003	2.487	1.611	1.765	1.841	0.749	1.192	0.913	0.861	1.034	1.653	2.04	2.09
Wind/Solar Asset - Total	MEAN	52.434	66.824	74.507	74.429	51.186	48.372	47.458	33.627	33.09	30.285	25.209	35.884	49.14	67.2	74.188
	PS	44.001	58.706	64.241	64.064	40.636	39.44	36.585	25.524	24.9	22.187	17.216	28.523	41.012	57.346	63.105
	P95	62.785	75.276	83.834	84.363	61.359	59.39	60.206	42.647	42.159	39.597	34.151	43.347	56.231	77.391	86.241
Total	MEAN	21.918	33.878	37.91	75.278	12.705	17.731	-5.489	-32.265	-38.757	-32.865	2.112	-2.657	20.987	33.739	34.42
	PS	-7.807	-0.045	-13.502	30.226	-14.625	-14.938	-37.633	-65.145	-73.633	-78.063	-36.29	-32.065	-6.236	2.078	-11.511
	P95	60.151	73.138	99.366	126.76	41.836	53.111	38.225	5.014	10.204	7.278	33.596	38.272	54.967	69.566	84.592